

**2015 – 2016**

**ANNUAL COMPREHENSIVE  
SAFETY INSPECTION  
REPORTS**

**Leased or Off Campus Sites  
Broward County Public Schools**

**Submitted By:  
ENVIRONMENTAL HEALTH & SAFETY  
DEPARTMENT  
SCHOOL BOARD OF BROWARD COUNTY, FLORIDA  
<http://www.browardschools.com>**

**DURING AN EMERGENCY, IMPORTANT INFORMATION  
FOR SCHOOLS IS AVAILABLE ON:**

**WKPX AT 88.5 ON FM RADIO  
AND**

**“BECON” on CABLE TELEVISION**

**Please contact your cable television company for the proper channel.**

Broward County Public Schools  
The School Board of Broward County, Florida

Dr. Rosalind Osgood, Chair

Abby M. Freedman, Vice Chair

Robin Bartleman

Heather P. Brinkworth

Patricia Good

Donna P. Korn

Laurie Rich Levinson

Ann Murray

Nora Rupert

Robert W. Runcie  
Superintendent of Schools

**“The School Board of Broward County, Florida, prohibits any policy or procedure which results in discrimination on the basis of age, color, disability, gender identity, gender expression, national origin, marital status, race, religion, sex or sexual orientation. Individuals who wish to file a discrimination and/or harassment complaint may call the Executive Director, Benefits & EEO Compliance at 754-321-2150 or Teletype Machine (TTY) 754-321-2158”**

[www.browardschools.com](http://www.browardschools.com)  
[www.broward.k12.fl.us/safetydept](http://www.broward.k12.fl.us/safetydept)

In a declared emergency, (754) 321-4200 is monitored 24 hours a day.

**Fiscal Year: 2015-2016**  
**Leased or Off Campus Facilities**  
**Index**

6051	AMI Kids Greater Ft. Laud. Whiddon Rogers
8090	Atlantic Shores Hospital
7101	Broward Educational Foundation
6015	Broward Girl's Academy Equity and Academic Attainment
6011	Broward Juvenile Detention Center - Whiddon Rogers
6017	Broward Youth Treatment Center, Whiddon-Rogers
9393	Central Area Maintenance (PPO Zone 2)
8241	Central Park Swimming Pool
8095	Citrus Health Network
8052	College Plaza
8220	First Church of Christ, Scientist (Parking Lot Only)
8047	Hallandale OCLC – Off Campus Learning Centers (Lease Terminated)
7033	Hispanic Unity of Florida, Inc.
8240	Hope South– Parking Lot Only
8053	Jim Ward Community Center
6091	PACE Broward - Whiddon Rogers
6016	Pompano Substance Abuse Treatment Center
8049	Tamarac OCLC (Lease Terminated)
8033	Word of Living God Ministry – Pompano OCLC (Lease Terminated)
8036	YMCA OCLC – Off Campus Learning Centers (Lease Terminated)

fka = formerly known as

OCLA = Off Campus Learning Center

**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/16/2016

Safety Department  
1000 N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased

Loc. No. 6051 AMI Kids Greater Ft. Laud. Whiddon Rogers  
3220 SW 4 Ave  
Ft. Lauderdale, FL 33316  
Phone: (954)764-2733

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58		Location		Type Def	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	M-O-C						
* S5.10.12.a	B	1	0000			Install Fish/Room Number	2	3/17/2016		
N101.4.6.3.1	F	1	0000			Repair electric exit sign (bulbs)			C	
S5.8.c.5	E	1	CORRIDOR			Change of level at doors and thresholds to be 1/2 or less in height , at door to exterior, next to group RRs		4/16/2016		
S5.8.c.2/ S5.16.b.7. a/H64e	E	1	CORRIDOR			Install door closer , at door to exterior, next to group RRs, broken/missing closers		3/1/2016		
* N101.7.1.10.1	C	1	CORRIDOR			remove exit obstructions , in front of Group RRs, TV cart in corridor in front of exit		3/17/2016		
S5.8.d.1	B	1	DO OFFICE			Replace panel w/tempered glass , window between office and Large Group Area, within 4' of a door, has no visible etching		3/17/2016		
101.15.2.10	B	1	LANGUAGE ARTS			repair illuminated exit sign , test button broken, not able to test unit		3/17/2016		
* S5.12.b	B	1	LANGUAGE ARTS			Secure bookcase/cabinet/shelving to wall		3/17/2016		
S5.13x	E	1	LANGUAGE ARTS			Clean Area , Food prep area-dirty walls		2/21/2016		
S5.6.e.&b	E	1	LANGUAGE ARTS			Provide padding for sharp edges on furniture , Round off sharp corners on furniture, provide corner guards or remove		3/17/2016		
	A	1	LANGUAGE ARTS			Remove Padlock/Hasp from Door , Food prep area-remove hasp on the inside, Provide hardware that cannot be locked from the inside and permits		3/1/2016		
S5.12.h	A	1	LANGUAGE ARTS			Remove Padlock/Hasp from Door , Food prep area-remove padlock on exterior, Provide hardware that cant lock on the inside & permits exiting at all times		3/1/2016		
S5.12.h	B	1	LANGUAGE ARTS			Strap TV's to mobile cart		3/17/2016		
S5.9/64E-11.008	B	1	MEN GROUP RR			Install impervious material , Impervious floor material must wrap up 4" on wall		3/17/2016		
S5.9/64E-11.008	B	1	MEN GROUP RR			Install impervious material , repair casework/counter top, missing/peeled-off laminate		3/17/2016		
* N70E.410.2.4.b	B	1	PLAY AREA			install weatherproof cover , by vending machine		3/17/2016		
* S5.2.d.10	B	1	PLAY AREA			repair fence , barbs on bottom of fence, Fencing shall be kept free of sharp projections		3/17/2016		
S5.11	B	1	PLAY AREA			Repair unsafe/broken equipment , Metal Storage unit -Rusted, with sharp edges		3/17/2016		

**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/16/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Broward County School District - Leased

Loc. No. 6051 AMI Kids Greater Ft. Laud. Whiddon Rogers  
3220 SW 4 Ave

Sandra Kanner  
Municipal Firesafety Inspector

Ft. Lauderdale, FL 33316

Phone: (954)764-2733

Not Present  
Municipal Firesafety Inspector  
(\*Fire Deficiencies Only)

FireSafety    Casualty    Sanitation

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
S5.6.f	B	1	PLAY AREA			Repair Wood Floor , missing wood plank on deck		5/16/2016		
* N70E.410.2. B	B	1	SCIENC E			install gfci within 6 ft water supply , by sink		3/17/2016		
* N101.15.2.1 0	B	1	SCIENC E			repair illuminated exit sign , did not work on test		3/17/2016		
S5.12.b	B	1	SCIENC E			Secure bookcase/cabinet/shelving to wall		3/17/2016		
* S5.12.h	B	1	SCIENC E			Strap TV's to mobile cart		3/17/2016		
* N101.8/S5.9. a	A	1	SOCIAL STUDIES			Check Fire Rating , wood paneling		2/16/2016		
S5.10.b	E	1	SOCIAL STUDIES			Protect equip < 6' 8" in height , in office, low shelf		6/15/2016		
S5.11. f/H6a2-.0040 .3.c	A	1	SOCIAL STUDIES			repair cabinets/casework , missing/peeled-off laminates on computer desk casework		5/16/2016		
* N101.7.2.1.5	B	1	SOCIAL STUDIES			replace exit hardware , office has lock on the inside, , Provide hardware that cannot be locked from the inside and permits exiting at all times		3/17/2016		
S5.8.d.1	B	1	SOCIAL STUDIES			Replace panel w/tempered glass , window between office and classroom, within 4' of a door, has no visible etching		3/17/2016		
S5.6.e.&b	E	1	SOCIAL STUDIES			Provide padding for sharp edges on furniture , computer desk casework, Round off sharp corners on furniture. provide corner guards or remove		3/17/2016		
S5.12.h	B	1	SOCIAL STUDIES			Strap TV's to mobile cart		3/17/2016		
S5.13.x.2.b	B	1	STUDEN T RESTRO			install exhaust fan/vent to exterior	2	6/15/2016		
S5.9/64E -11.008	B	1	WOMEN GROUP RR			Install impervious material , Impervious floor material must wrap up 4" on wall		3/17/2016		
S5.9/64E -11.008	B	1	WOMEN GROUP RR			Install impervious material , repair casework/counter top, missing/peeled-off laminate		3/17/2016		

Comprehensive Safety Inspection
State Requirements for Educational Facilities

Inspection Date: 2/16/2016

Safety Department
4200A N.W. 10th Avenue
Oakland Park, FL 33309
(754)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased

Loc. No. 6051 AMI Kids Greater Ft. Laud. Whiddon Rogers
3220 SW 4 Ave

Fort Lauderdale Fire Rescue
528 NW 2nd Street
Fort Lauderdale, FL 33301
Phone: (954)828-5654 Fax: (954)828-5338

Sandra Kanner
Municipal Firesafety Inspector

Ft. Lauderdale, FL 33316
Phone: (954)764-2733

Not Present
Municipal Firesafety Inspector
(\*Fire Deficiencies Only)

[x]FireSafety [x]Casualty [x]Sanitation

Table with columns: R69A.58, Sub No. Para., Pri, Location (Bldg No., Room No.), Type Def M-O-C, Est Cost, Deficiency Description and Corrective Action Required, # of Times Cited, Schedule for Correction Not Later Than, Current Year Status, Work Order #

Total Non-Fire Safety Deficiencies.....21
Total Fire Safety Deficiencies (\*).....11 (Includes 0 Serious Life Safety Deficiencies\*\*)
Total Deficiencies Cited .....32

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;
Ten Fire Exit Drills during the School Year [X]YES [ ]NO (NFPA 101)

Signature of Facility Administrator

Cherisse Musley

Print Name Facility Administrator

Asst. Director

Title

2/25/16

Date

Signature of Facility Administrator attesting to fire exit drills and review of
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [X]YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.


**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/17/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District - Leased  
Loc. No. 8090 Atlantic Shores Hospital  
4545 North Federal Highway  
Ft. Lauderdale, FL 33308  
Phone: (954)771-2711

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
N13.26.1	F	1	0000			inspect fire sprinkler system , Inspection out of date			C	
N1.13.7.3.2. 4	b	1	0000			Inspect fire alarm system , Inspection out of date			C	
* N70E.410.2. B	B	1	CAFETE RIA			install gfci within 6 ft water supply , at water dispenser		3/18/2016		
* S5.6.e.&b	E	1	CLASSR OOM			Provide padding for sharp edges on furniture , Round off sharp corners on furniture, provide corner guards or remove		3/18/2016		
* S5.8b2&D2	C	1	RECEPTI ON			install railings min 24" on windows , main entrance doors, Storefront windows & doors need 1-1/2" safety rail at 24"-36" above the floor		5/17/2016		
S5.16. a/S5.13.x.2. b/H6A	B	1	STAFF MEN RR			install exhaust fan/vent to exterior		6/16/2016		
S5.16. a/S5.13.x.2. b/H6A	B	1	STAFF WOMEN RR			install exhaust fan/vent to exterior		6/16/2016		
* SPEC10400. 2.13	B	2	OFFICE			post fire alarm panel inside sign	2	3/18/2016		
S5.16. a/S5.13.x.2. b/H6A	B					install exhaust fan/vent to exterior		6/16/2016		





### Comprehensive Safety Inspection State Requirements for Educational Facilities


Inspection Date: 2/5/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(352)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased  
Loc. No. 7101 Broward Educational Foundation  
2300 W. Copans Road, Bay 5  
Pompano Beach, FL 33062  
Phone: (754)321-9021

Pompano Beach Fire Rescue  
100 West Atlantic Blvd. #220  
Pompano Beach, FL 33060  
Phone: (954)786-4695 Fax: (954)786-4328



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector



Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[x]FireSafety [x]Casualty [x]Sanitation

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
* N101.7.10.1. 2	C	1	STORE			install illuminated exit sign , at front of store (end of aisles) with directional to entrance door		4/5/2016		
* N13.6.2.6.2. 2	F	1	TOILET- AT KITCHE			Rpr/rpl fire sprinkler head , paint on deflector		3/6/2016		
S5.16.a.4	B	1	TOILET- MAIN AREA			repair exhaust fan , secure unit, dropped below ceiling		3/6/2016		
* N101.7.1.10. 1	C	1	WAREH OUSE			remove exit obstructions , Provide minimum 36" clear exit path at all aisles while stocking materials, at all times. Items in isles are blocking access to		3/6/2016		
* F69A.81.20	C	1	WAREH SE			install battery lighting , additional req'd	2	3/6/2016		
* N101.7.10.2	C	1	WAREH SE			install directional exit sign , at end of aisle at rear of space, toward exit door	2	3/6/2016		
* N13.26.1	F	1	9698			inspect fire sprinkler system , correct deficiencies	1	3/6/2016		
S5.7.c.1	B	1	9698			provide drainage , Dumpster must have proper drainage to sanitary sewer. Dumpsters must not drain into storm drain.		6/4/2016		
S5.2(a)7	F	1	9698			remove debris , clean up trash dumpster area at rear of building. Place trash dumpster inside dumpster enclosure.		5/5/2016		

**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/5/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased

Pompano Beach Fire Rescue  
100 West Atlantic Blvd. #220  
Pompano Beach, FL 33060  
Phone: (954)786-4695 Fax: (954)786-432

Loc. No. 7101 Broward Educational Foundation

2300 W. Copans Road, Bay 5

Pompano Beach, FL 33062

Phone: (754)321-9021

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Deficiencies Only)

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....3

Total Fire Safety Deficiencies (\*).....6 (Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....9

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire/Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

*Hector A. Javier*  
Signature of Facility Administrator

Hector A. Javier      STPP Manager      2/19/16  
Print Name Facility Administrator      Title      Date

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.

**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/17/2016


Safety Department  
200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased

Loc. No. 6015 Broward Girl's Academy Equity and Academic  
8301 South Palm Dr. Bldg 1  
Pembroke Pines, FL  
Phone: (954)322-6500

State Fire Marshal's Office  
6851 W Sunrise Boulevard, Ste 150  
Plantation, FL 33313  
Phone: (954)3-3704 Fax:



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
F13.26.1	F	1	0000			inspect fire sprinkler system , Backflow inspection past due			C	
* S5.10.e/H6A -2.0040.a.2	B	1	GROUP RR			repair bathroom partitions , 1st stall door missing		3/18/2016		
* S5.16. a/S5.13.x.2. b/H6A	B	1	GROUP RRS			install exhaust fan/vent to exterior , 2 restrooms		6/16/2016		
S5.16.b	B	1	GROUP RRS			Repair plumbing fixture , 1st stall toilet out of service		3/18/2016		
S5.13x	E	1	GROUP RRS			Clean Area , moldy walls and floor in showers, X3		2/22/2016		
S5.9/64E -11.008	B	1	GROUP RRS			Install impervious material , install tile in shower wing wall, X3 showers		3/18/2016		
S.5.9.a	B	1	SHOWE R			repair ceilings , deteriorating around vent			C	
N13.6.1.1.1	A	1	9599			Secure backflow preventer OS & Y , chain not locked		3/18/2016		
S5.12.h	B	1	001			Strap TV's to mobile cart V: TV removed			V	
* S5.9.a/ N1.13.3.3.3/ N1.13.7.4.3.	B	1	00CLAS SROOM 1			repair ceiling tiles , missing tiles		3/18/2016		
S5.12.h	B	1	002			Strap TV's to mobile cart V: TV removed			V	
S5.9.d/H6A -2.0040.3.b	B	1	00CLAS SRM 2			Repair broken floor tiles (vinyl)	2	6/16/2016		
* S5.17. b/N1.11.1.2	B	1	00CLAS SROOM 2			repair electrical outlet , 2 broken		3/18/2016		
* N1.11.1.2/ N70.406.5/ S5.17.b	B	1	00CLAS SROOM 2			install electric receptacle cover		3/18/2016		
* S5.9.a/ N1.13.3.3.3/ N1.13.7.4.3.	B	1	00CLAS SROOM 2			repair ceiling tiles , missing tiles and water damaged tiles		3/18/2016		

### Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/17/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

State Fire Marshal's Office  
6851 W Sunrise Boulevard, Ste 150  
Plantation, FL 33313  
Phone: (954)3-3704 Fax:

Broward County School District - Leased

Loc. No. 6015 Broward Girl's Academy Equity and Academic  
8301 South Palm Dr. Bldg 1  
Pembroke Pines, FL  
Phone: (954)322-6500

Not Present  
Municipal Firesafety Inspector  
(\*Fire Deficiencies Only)

Sandra Kanner  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....4  
Total Fire Safety Deficiencies (\*).....7 (Includes 0 Serious Life Safety Deficiencies\*\*)  
Total Deficiencies Cited .....11

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year  YES     NO    (NFPA 101)

Signature of Facility Administrator

Charisse E. Mosley

Print Name Facility Administrator

Asst Director

Title

2/25/10

Date

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15  YES     NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.

### Comprehensive Safety Inspection State Requirements for Educational Facilities


Inspection Date: 2/17/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

State Fire Marshal's Office  
6851 W Sunrise Boulevard, Ste 150  
Plantation, FL 33313  
Phone: ((954)3-3704 Fax: (954)828-5338

Broward County School District - Leased  
Loc. No. 6011 Broward Juvenile Detention Ctr - Whiddon  
222 Northwest 22nd Ave  
Ft. Lauderdale, FL 33311  
Phone: (954)765-6896



**Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector**

[x]FireSafety [x]Casualty [x]Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
11a801	F	P	0000			reinspect fire extinguishers , ALL Fire Extinguishers Now Due			C	
N1.13.7.3.2.4	b	P	0000			Inspect fire alarm system			C	
* S5.1.e.8.f	C	P	9599			remove debris under relocatable , both portables at extreme NW corner of the property.		5/17/2016		
* F1017.9.2.6	C	P	36N			Repair battery lighting	2	3/18/2016		
S5.8.a	B	P	36N			repair door (wood) , west side, door frame busted			C	
* S5.14.9	B	P	36N			repair light fixture , ballast	2	3/18/2016		
S5.12.h	B	P	36N			Secure bookcase/cabinet/shelving to wall , five(5) all total	2	3/18/2016		
N70E.420.2.A.1	B	P	36N			install light covers			C	
64E.13.004.3.b	B	P	119C			Repair broken floor tiles (vinyl) , replace missing tiles			C	
7.9.2.6	C	P	180N			Repair battery lighting			C	
S5.8.a	B	P	180N			repair door (wood) , dragging,must swing in both directions			C	
* F1017.9.2.6	C	P	181N			Repair battery lighting	2	3/18/2016		
* N72E420.2.A.1	B	P	299			install spacer in circuit breakers	2	3/18/2016		
* F1017.9.2.6	C	P	327C			Repair battery lighting	2	3/18/2016		
64E.13.004.3.b	B	P	327C			Repair broken floor tiles (vinyl) , thru-out; check Sub-flooring			C	
S.5.9.a	B	P	327C			repair ceilings , replace water stained tiles			C	
* S5.8.a	B	P	327C			repair door (wood) , door not latching, east side	1	3/18/2016		
* F1017.9.2.6	C	P	350VE			Repair battery lighting	2	3/18/2016		
* S5.14.9	B	P	350VE			repair light fixture , not working		3/18/2016		
53.4	B	P	350VE			repair walls			C	
* F1017.9.2.6	C	P	519C			Repair battery lighting	2	3/18/2016		
64E.13.004.3.b	B	P	519C			Repair broken floor tiles (vinyl) , under AC, possible water damage			C	
S5.8.a	B	P	519C			repair door (wood) , North door dragging			C	
* S5.14.9	B	P	519C			repair light fixture , ballast	2	3/18/2016		
* 9.a	B	P	181N4			repair walls , near floor due to water damage	1	3/18/2016		

8:30:26 AM, 2/18/2016

Status Codes: C-Completed V-Void R-Remodeled X-Demolished T-Transferred U-Under Construction  
Status Codes: C-Completed V-Void R-Remodeled X-Demolished T-Transferred U-Under Construction W-Work Order Reissued

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Bobby Glenn  
Municipal Firesafety Inspector

### Comprehensive Safety Inspection State Requirements for Educational Facilities

Fiscal Year: 2015 - 2016

Broward County School District - Leased

Loc. No. 6011 Broward Juvenile Detention Ctr - Whiddon  
222 Northwest 22nd Ave  
Ft. Lauderdale, FL 33311  
Phone: (954)765-6896

Inspection Date: 2/17/2016

State Fire Marshal's Office  
6851 W Sunrise Boulevard, Ste 150  
Plantation, FL 33313  
Phone: ((954)3-3704 Fax:

Not Present  
Municipal Firesafety Inspector  
(\*Fire Deficiencies Only)

Fire Safety     Casualty     Sanitation

R69A.58	Location		Type Def	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	M-O-C					
N70E.420.2.A.1	B	P	181N4		install light covers	1	3/18/2016		

Total Non-Fire Safety Deficiencies.....2  
Total Fire Safety Deficiencies (\*).....12 (Includes 0 Serious Life Safety Deficiencies\*\*)  
Total Deficiencies Cited .....14

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Open Fire Exit Drills during the School Year  YES     NO (NFPA 101)

Signature of Facility Administrator

*Charisse E. Mosley*

Print Name Facility Administrator

*Asst. Director*

Title

*2/25/16*

Date

Signature of Facility Administrator attesting to fire exit drills and review of initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15  YES     NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.

### Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/18/2016


Safety Department  
200A N.W. 10th Avenue  
Jakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased

Loc. No. 6017 Broward Youth Treatment Center, Whiddon-  
8301 S. Palm Dr. Bldg 2  
Pembroke Pines, FL 33325  
Phone: (954)434-8767

State Fire Marshal's Office  
6851 W Sunrise Boulevard, Ste 150  
Plantation, FL 33313  
Phone: (954)3-3704 Fax:



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

[x]FireSafety [x]Casualty [x]Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
F69A.58.005 .1	D	1	0000			repair fire alarm system , trouble signal on panel, generator problems			C	
* S5.13x	F	1	CORRID OR			remove combustibile materials , corridor in classroom wing, paper decorations on walls, per Fire Marshal		5/18/2016		
N13.26.1	F	2	0000			inspect fire sprinkler system , Backflow inspection past due			C	
S5.9/64E -11.008	B	2	KITCHE N			Install impervious material , all walls in kitchen to a height of 6' above the floor		3/19/2016		
S5.9/64E -11.008	B	2	KITCHE N			Install impervious material , Vinyl base is not permitted-Impervious floor material must wrap up 4" on wall		3/19/2016		
* S5.17.b	B	2	LIVING ROOM			repair exposed wiring , TV cord insulation separated at plug exposing wires, replace power cord		3/19/2016		
S5.16.a.4	B	2	STAFF RR			repair exhaust fan , not running		3/19/2016		
S5.9/64E -11.008	B	2	STAFF RR			Install impervious material , residential bathroom rugs in restroom are not permitted		3/19/2016		
* N13.6.1.1.1	A	2	9599			Secure backflow preventer OS & Y , chain not locked		3/19/2016		
S5.6.e.&b	E	2	107			Provide padding for sharp edges on furniture , Round off sharp corners on furniture, provide corner guards or remove		3/19/2016		
* S.5.9.a	B	2	107 RR			repair ceilings , hole in ceiling		3/19/2016		
S5.16.a.4	B	2	107 RR			repair exhaust fan , not running		3/19/2016		
S5.9.a	B	2	107 RR			rpr/rpl broken ceramic wall tiles		3/19/2016		
S5.13x	E	2	107 RR			Clean Area , floor		2/23/2016		
S5.9/64E -11.008	B	2	107 RR			Install impervious material , residential bathroom rugs in restroom are not permitted		3/19/2016		
S5.6.e.&b	E	2	109			Provide padding for sharp edges on furniture , Round off sharp corners on furniture, provide corner guards or remove		3/19/2016		
S5.16.a.4	B	2	109 RR			repair exhaust fan , not running		3/19/2016		
S5.11	B	2	109 RR			Repair unsafe/broken equipment , missing shower floor drain cover	2	3/19/2016		
S5.13x	E	2	109 RR			Clean Area , clean toilet and floors		2/23/2016		
* SD101	B	2	109 RR			Remove storage from restroom	2	3/19/2016		

Comprehensive Safety Inspection
State Requirements for Educational Facilities

Inspection Date: 2/18/2016

Safety Department
4200A N.W. 10th Avenue
Oakland Park, FL 33309
(754)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased

State Fire Marshal's Office
6851 W Sunrise Boulevard, Ste 150
Plantation, FL 33313
Phone: ((954)3-3704 Fax: (954)435-6710

Loc. No. 6017 Broward Youth Treatment Center, Whiddon-
8301 S. Palm Dr. Bldg 2

Pembroke Pines, FL 33325

Phone: (954)434-8767

Sandra Kanner
Municipal Firesafety Inspector

Not Present
Municipal Firesafety Inspector
(\*Fire Deficiencies Only)

[x]FireSafety [x]Casualty [x]Sanitation

Table with columns: R69A.58, Sub No. Para., Pri, Location (Bldg No., Room No.), Type Def M-O-C, Est Cost, Deficiency Description and Corrective Action Required, # of Times Cited, Schedule for Correction Not Later Than, Current Year Status, Work Order #

Total Non-Fire Safety Deficiencies.....13

Total Fire Safety Deficiencies (\*).....5 (Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....18

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;
Ten Fire Exit Drills during the School Year [X]YES [ ]NO (NFPA 101)

Signature of Facility Administrator
Charisse E. Mosley
Print Name Facility Administrator
Title Asst. Director
Date 2/25/16

Signature of Facility Administrator attesting to fire exit drills and review of
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [X]YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.



Comprehensive Safety Inspection
State Requirements for Educational Facilities

Inspection Date: 10/26/2015

Safety Department
4200A N.W. 10th Avenue
Oakland Park, FL 33309
21-4200

Kim Luke Lic. No. 112349
Municipal Firesafety Inspector

Fiscal Year: 2015 - 2016
Broward County School District - Leased
Loc. No. 9393 Central Area Maintenance (PPO Zone 2)
1560 NW 34 Terrace
Lauderhill, FL 33311
Phone: (754)321-1450 Fax: (754)321-1490

[x]FireSafety [x]Casualty [x]Sanitation

Lauderhill Fire Rescue
1980 NW 56th Avenue
Lauderhill, FL 33313
Phone: (954)730-2950 Fax: (954)730-2955

Matthew Newman 95515
Municipal Firesafety Inspector
(\*Fire Violations Only)

Table with columns: R69A.58, Sub No. Para, Pri, Location (Bldg No., Room No.), Type Def M-O-C, Est Cost, Deficiency Description and Corrective Action Required, # of Times Cited, Schedule for Correction Not Later Than, Current Year Status, Work Order #

Total Casualty/Sanitation Deficiencies..0
Total Fire Safety Deficiencies (\*).....3 (Includes 0 Serious Life Safety Deficiencies\*\*)
Total Deficiencies Cited .....3

Correct all violations before the next Comprehensive Safety Inspection is performed.

Signature of Facility Administrator

RON DICUNEO

Print Name Facility Administrator

MANAGER

Title

1-6-16

Date

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY; (NFPA 101)
Ten Fire Exit Drills during the School Year YES NO

Signature of Facility Administrator attesting to fire exit drills and review of
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective School District's Inspector signifies compliance with Section 1013.12(5)(a), F.S
Safety/Sanitation Inspection of Charter Schools.

Signature of the respective inspecting authority's firesafety inspector signifies compliance
with Section 1013.12(5)b, F.S., Fire Safety Inspections of Charter Schools.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [X]YES [ ]NO
Scheduled Re-inspection Date no later than June 30 of each School Year.


**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/12/2016

Safety Department  
200A N.W. 10th Avenue  
Kland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District -  
Loc. No. 8241 Central Park Swimming Pool  
9151 NW 2nd St  
Plantation, FL 33324  
Phone: (954)452-2527 Fax: (954)452-2519

Plantation Fire Rescue  
550 NW 65th Avenue  
Plantation, FL 33317  
Phone: (954)797-2150 Fax: (954)797-2136



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
* N101.7.10.1.2	C	1	INT. LOCKER -MEN			install illuminated exit sign , multiple doors in area		4/12/2016		
S5.8.d.1.e	B	1	INT. LOCKER -MEN			Replace glass mirror w/reflective metal mirror		4/12/2016		
* N101.7.10.1.2	C	1	INT. LOCKER -WOMEN			install illuminated exit sign , multiple doors in area		4/12/2016		
S5.13.x.2.b	B	1	INT. LOCKER -WOMEN			install exhaust fan/vent to exterior , or repair existing if installed. A pulling unit was not found at time of inspeciton		6/11/2016		
* N101.7.9.2.6	C	1	INT. LOCKER -WOMEN			Repair battery lighting , at corridor outside women locker room, did not work on test		3/13/2016		
S5.8.d.1.e	B	1	INT. LOCKER -WOMEN			Replace glass mirror w/reflective metal mirror		4/12/2016		
S5.16.b.2.c	b	1	INT. LOCKER -WOMEN			Remove deodorizer(s) from restroom		2/13/2016		
* N101.7.10.1.2	C	1	INT. LOCKER S			install illuminated exit sign , need exit signs/directional signs to 2 separate exits. Unit outside women locker does not lead to an exit. Exit		4/12/2016		
S5.13.x.2.b	B	1	INT. LOCKER -MEN			install exhaust fan/vent to exterior , or repair existing if installed. A pulling unit was not found at time of inspection		6/11/2016		
S5.8b2&D2	C	1	POOL VENDIN G AREA			install railings min 24" on windows , Storefront windows & doors need 1-1/2" safety rail at 24"-36" above the floor		5/12/2016		
S5.16.a.4	B	Bathho use 2	MEN			repair exhaust fan , not running		3/13/2016		
* N101.15.2.10	B	Bathho use 2	MEN			repair illuminated exit sign , did not work on test		3/13/2016		
S5.16.b.2.c	b	Bathho use 2	MEN			Remove deodorizer(s) from restroom		2/13/2016		
S5.16.a.4	B	Bathho use 1	MEN			repair exhaust fan , not running		3/13/2016		
S5.8.d.1.e	B	Bathho use 1	MEN			Replace glass mirror w/reflective metal mirror		4/12/2016		
S5.16.b.2.c	b	Bathho use 1	MEN			Remove deodorizer(s) from restroom		2/13/2016		
S5.16.a.4	B	Bathho use 1	WOMEN			repair exhaust fan , not running		3/13/2016		
S5.8.d.1.e	B	Bathho use 1	WOMEN			Replace glass mirror w/reflective metal mirror		4/12/2016		
S5.8.d.1	B	Bathho use 1	WOMEN			Replace panel w/tempered glass , framed poster with glass		3/13/2016		

7:43:40 AM, 2/22/2016

Status Codes: C-Completed V-Void R-Remodeled X-Demolished T-Transferred U-Under Construction

Status Codes: C-Completed V-Void R-Remodeled X-Demolished T-Transferred U-Under Construction W-Work Order Reissued

Ref. Codes:ANSI= Amer. Nat. Standard F=Fla. State Statute HPPS: Handbook Public Playground SafetyN=NFPA O=OSHA H=Health S=SREF Chpt 5

**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/12/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District -  
Loc. No. 8241 Central Park Swimming Pool  
9151 NW 2nd St  
Plantation, FL 33324  
Phone: (954)452-2527 Fax: (954)452-2519  
FireSafety    Casualty    Sanitation

Plantation Fire Rescue  
550 NW 65th Avenue  
Plantation, FL 33317  
Phone: (954)797-2150 Fax: (954)797-2130

Sandra Kanner  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Deficiencies Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
N70E.420.2.A.1	B	Bathhouse 1	WOMEN			install light covers , replace broken		3/13/2016		
S5.16.b.2.c	b	Bathhouse 1	WOMEN			Remove deodorizer(s) from restroom		2/13/2016		

Total Non-Fire Safety Deficiencies.....16  
 Total Fire Safety Deficiencies (\*).....5 (Includes 0 Serious Life Safety Deficiencies\*\*)  
 Total Deficiencies Cited .....21

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
 Ten Fire Exit Drills during the School Year  YES     NO    (NFPA 101)

Signature of Facility Administrator:   
 Print Name Facility Administrator: HERNAN BORJA    Title: A-P.    Date: 2-23-16

Signature of Facility Administrator attesting to fire exit drills and review of Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance with Section 1013.12(2)(c), F.S.  
 Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15  YES     NO  
 Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.


**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/17/2016

Safety Department  
1200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District - Leased  
Loc. No. 8095 Citrus Health Network  
8400 South Palm Drive  
Pembroke Pines, FL 33025  
Phone: (954)987-1731

State Fire Marshal's Office  
6851 W Sunrise Boulevard, Ste 150  
Plantation, FL 33313  
Phone: (954)3-3704 Fax: (954)435-6713



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
S5.10.i.4	C	1	CLSRMS			post exit diagrams in each room			C	
* N1.11.7/S.5. 17.1.e	B	1	KITCHE N			remove extension cords , at oven		3/18/2016		
* N1.11.7/S.5. 17.1.e	B	1	KITCHE N			remove extension cords , at refrigerator		3/18/2016		
* F69A.58.005 .1	D	1	RECEPTI ON			repair fire alarm system , telephone jack should be installed inside locked panel. Coordinate with Fire Marshal		3/18/2016		
* N72E.420.2. A	B	1	RECEPTI ON			Lock utility panel. , Fire Alarm Panels. Coordinate with Fire Marshal		3/18/2016		
S5.11	A	1	001			Remove unsafe/broken Equipment , desks with broken seats			C	
S5.12.h	B	1	001			Strap TV's to mobile cart	1	3/18/2016		
S5.10.b	E	1	001			Protect equip < 6' 8" in height , a/c units mounted on wall between classrooms 1 and 2		6/16/2016		
S5.12.b	B	1	001			Secure bookcase/cabinet/shelving to wall		3/18/2016		
S5.6.e.&b	E	1	001			Provide padding for sharp edges on furniture , Round off sharp corners on furniture, provide corner guards or remove		3/18/2016		
S5.6.e.&b	E	1	002			Provide padding for sharp edges on furniture , Round off sharp corners on furniture, provide corner guards or remove		3/18/2016		
* S5.10.i.4	C	1	003			post capacity sign , maximum 10 students , EDITED 2/17/16: Coordinate with Fire Marshal	1	3/18/2016		
S5.8b2&D2	C	1	113			install railings min 24" on windows , Storefront windows & doors need 1-1/2" safety rail at 24"-36" above the floor		5/17/2016		
S58 C1	B	Admin	041			replace exit hardware , storage cabinets have locks on the inside, provide hardware that cannot be locked from the inside V: room not found			V	
* N70E.420.2. A.1	B	Male Unit	005			install light covers	2	3/18/2016		

**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/17/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

State Fire Marshal's Office  
6851 W Sunrise Boulevard, Ste 150  
Plantation, FL 33313  
Phone: ((954)3-3704 Fax: (954)435-6711

Broward County School District - Leased  
Loc. No. 8095 Citrus Health Network  
8400 South Palm Drive  
Pembroke Pines, FL 33025  
Phone: (954)987-1731

Sandra Kanner  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Deficiencies Only)

[x]FireSafety [x]Casualty [x]Sanitation

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....6  
 Total Fire Safety Deficiencies (\*).....6 (Includes 0 Serious Life Safety Deficiencies\*\*)  
 Total Deficiencies Cited .....12

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
 Ten Fire Exit Drills during the School Year  YES [ ] NO (NFPA 101)



Signature of Facility Administrator

Andrea Swift

Asst. Principal

2/24/16

Print Name Facility Administrator

Title

Date

Signature of Facility Administrator attesting to fire exit drills and review of  
 Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
 with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15  YES [ ] NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.


### Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/11/2016

Safety Department  
4200A N.W. 10th Avenue  
Kland Park, FL 33309  
(954)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District - Leased  
Loc. No. 8052 College Plaza - Off Campus Learning Centers  
7875 Pines Blvd.  
Pembroke Pines, FL 33024  
Phone:

Pembroke Pines Fire Rescue  
9500 Pines Blvd., Bldg B  
Pembroke Pines, FL 33026  
Phone: (954)435-6700 Fax: (954)435-6713



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
S5.9/64E -11.008	B	1	BOYS TOILET			Install impervious material , wood base is not permitted; Impervious floor material must wrap up 4" on wall		3/12/2016		
* N101.15.2.1 0	B	1	CLASRO OM			repair illuminated exit sign , over double doors, battery light/exit light combo did not work on test		3/12/2016		
* S5.10.i.4	C	1	CLASSR OOM			post capacity sign , Maximum 49	2	3/12/2016		
* S5.12.b	B	1	CLASSR OOM			Secure bookcase/cabinet/shelving to wall		3/12/2016		
S5.17.b.1.e	F	1	CLASSR OOM			discontinue use of piggybacked surge strips , at microwave		3/12/2016		
* N72E.420.2. A	B	1	CLASSR OOM			Lock utility panel , electrical panel		3/12/2016		
* N1.11.7/S.5. 17.1.e	B	1	CLASSR OOM			remove extension cords , at microwave		3/12/2016		
* SD101	E	1	CLASSR OOM			Remove microwave/toaster from classroom		2/16/2016		
SD101	B	1	CLASSR OOM			Remove sign , capacity sign of 63 is incorrect	1	2/21/2016		
S5.8.d.1	B	1	CLASSR OOM & TOILET			Replace panel w/tempered glass , or plexi-glass, framed posters			C	
S5.16.b	B	1	GIRLS TOILET			Repair plumbing fixture , lavatory is loose, secure to wall and caulk between fixture and wall		3/12/2016		
S5.9/64E -11.008	B	1	GIRLS TOILET			Install impervious material , wood base is not permitted; Impervious floor material must wrap up 4" on wall		3/12/2016		
S5.8.d.e	B	1	TOILET			Replace glass mirror w/reflective metal mirror			C	
S5.15.b.5	E	1	TOILET			Faculty/staff restrooms-separate from students	2	2/12/2016		
S5.9.1	B	1	TOILET			Install impervious material , all walls in toilet rooms to a height of 4' above the floor	2	3/12/2016		
S5.16.b.6	E	1	TOILET			Provide separate restrooms for male and female students > grade 3			C	

Comprehensive Safety Inspection
State Requirements for Educational Facilities

Inspection Date: 2/11/2016

Safety Department
4200A N.W. 10th Avenue
Oakland Park, FL 33309
(754)321-4200

Fiscal Year: 2015 - 2016
Broward County School District - Leased
Loc. No. 8052 College Plaza - Off Campus Learning Centers
7875 Pines Blvd.

Pembroke Pines Fire Rescue
9500 Pines Blvd., Bldg B
Pembroke Pines, FL 33026
Phone: (954)435-6700 Fax: (954)435-6711

Sandra Kanner
Municipal Firesafety Inspector

Pembroke Pines, FL 33024
Phone:

Not Present
Municipal Firesafety Inspector
(\*Fire Deficiencies Only)

[x]FireSafety [x]Casualty [x]Sanitation

Table with columns: R69A.58, Sub No. Para., Pri, Location (Bldg No., Room No.), Type Def M-O-C, Est Cost, Deficiency Description and Corrective Action Required, # of Times Cited, Schedule for Correction Not Later Than, Current Year Status, Work Order #

Total Non-Fire Safety Deficiencies.....6
Total Fire Safety Deficiencies (\*).....7 (Includes 0 Serious Life Safety Deficiencies\*\*)
Total Deficiencies Cited .....13

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;
Ten Fire Exit Drills during the School Year [X]YES [ ]NO (NFPA 101)

Signature of Facility Administrator

Bardetta D. Haygood Principal 2/22/2016
Print Name Facility Administrator Title Date

Signature of Facility Administrator attesting to fire exit drills and review of
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [X]YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.

**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/18/2016


Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased

Loc. No. 8220 First Church of Christ, Scientist (Parking Lot)  
1260 SW 55 Terrace  
Plantation, FL 33317  
Phone: (954)587-4896

Plantation Fire Rescue  
550 NW 65th Avenue  
Plantation, FL 33317  
Phone: (954)797-2150 Fax: (954)797-2136



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
	*-*-*	*	000	9698			*No violations for this building				


Total Non-Fire Safety Deficiencies.....0

Total Fire Safety Deficiencies (\*).....0 (Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....0

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

  
Signature of Facility Administrator  
HERNAN BORDA

A.P.  
Title

2-23-16  
Date

Signature of Facility Administrator attesting to fire exit drills and review of Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.



Comprehensive Safety Inspection
State Requirements for Educational Facilities

Inspection Date: 2/26/2016

Safety Department
4200A N.W. 10th Avenue
Hallandale Park, FL 33309
(754)321-4200

Fiscal Year: 2015 - 2016
Broward County School District - Leased
Loc. No. 8047 Hallandale OCLC - Off Campus Learning Centers
821 NW 2 Avenue
Hallandale Beach, FL 33009
Phone: (954)455-9333

Hallandale Fire Rescue
121 SW 3rd Street
Hallandale, FL 33009
Phone: (954)457-1470 Fax: (954)457-1472

[Handwritten Signature]

Sandra Kanner Lic. No. 117455
Municipal Firesafety Inspector

[x]FireSafety [x]Casualty [x]Sanitation

Not Present
Municipal Firesafety Inspector
(\*Fire Violations Only)

Table with columns: R69A.58, Sub No. Para., Pri, Location (Bldg No., Room No.), Type Def M-O-C, Est Cost, Deficiency Description and Corrective Action Required, # of Times Cited, Schedule for Correction Not Later Than, Current Year Status, Work Order #. Row 1: SD101, 3, 000, 0000, Lease Terminated., 2/26/2016.

Total Non-Fire Safety Deficiencies.....0
Total Fire Safety Deficiencies (\*).....0 (Includes 0 Serious Life Safety Deficiencies\*\*)
Total Deficiencies Cited .....0

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;
Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator

Print Name Facility Administrator

Title

Date

Signature of Facility Administrator attesting to fire exit drills and review of
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.


### Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/16/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District - Leased  
Loc. No. 7033 Hispanic Unity of Florida, Inc. - Community School  
5811, 5817, 5819 Johnson Street  
Hollywood, FL 33021  
Phone: (954)964-8884

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							
* 69A.58.005.2.b.3	E	1	0000			remove door stops , all doors at corridor	2	3/17/2016		
S5.16.a.4	B	1	JANITOR			repair exhaust fan , Custodial room, if exhaust fan is connected to light switch- wire to run <b>independently, shall be maintained in an operable</b>		3/17/2016		
S5.16.a.4	B	1	JANITOR			repair exhaust fan , not working		3/17/2016		
12a	F	1	JANITOR			remove combustible materials , clear area to maintain 3' clear around water heater			C	
S5.9.0	B	1	MEN'S TOILET			Install impervious ceiling material in toilet room	2	3/17/2016		
* N101.7.10.1.2	C	1	MEN'S TOILET			install illuminated exit sign , install unit that has a battery back-up that can be tested. (Bldg. not on generator)		4/16/2016		
S5.16.b.2.c	b	1	MEN'S TOILET			Remove deodorizer(s) from restroom		2/17/2016		
S5.9.a/ N1.13.3.3.3/ N1.13.7.4.3.	B	1	TESTING ROOM			repair ceiling tiles , water damage		3/17/2016		
S5.9.0	B	1	WOMEN TOILET			Install impervious ceiling material in toilet room	2	3/17/2016		
* N101.7.10.1.2	C	1	WOMEN TOILET			install illuminated exit sign , install unit that has a battery back-up that can be tested. (Bldg. not on generator)		4/16/2016		
S5.16.a.4	B	1	WOMEN TOILET			repair exhaust fan , not running		3/17/2016		
S5.16.b.2.c	b	1	WOMEN TOILET			Remove deodorizer(s) from restroom		2/17/2016		
* S5.10.i.4	C	1	103			post capacity sign , maximum 28 students	1	3/17/2016		
10c 2	C	1	103			remove exit obstructions , rolling cabinet			C	
S5.9.a	B	1	103			repair ceiling tiles , replace water stained tiles			C	
* N101.15.2.1 1.1.2.5.c	B	1	108			Repair Door Closer , door to exterior slams		3/17/2016		
7.21.15.2	E	1	108			replace fire doors , metal exit door rusting out			C	
* S5.9.a	B	1	108			repair ceiling tiles , replace water stained tiles	1	3/17/2016		

### Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/16/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District - Leased  
Loc. No. 7033 Hispanic Unity of Florida, Inc. - Community School  
5811, 5817, 5819 Johnson Street  
Hollywood, FL 33021  
Phone: (954)964-8884

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-45

Sandra Kanner  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Deficiencies Only)

FireSafety    Casualty    Sanitation

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....7  
Total Fire Safety Deficiencies (\*).....7 (Includes 0 Serious Life Safety Deficiencies\*\*)  
Total Deficiencies Cited .....14

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

CB Shaw  
Signature of Facility Administrator

Carolina B. Shaw      Principal      2/23/16  
Print Name Facility Administrator      Title      Date

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.

Comprehensive Safety Inspection
State Requirements for Educational Facilities

Inspection Date: 2/18/2016

Safety Department
200A N.W. 10th Avenue
Oakland Park, FL 33309
(754)321-4200

Fiscal Year: 2015 - 2016
Broward County School District - Leased
Loc. No. 8240 Hope South (Parking Lot Only) - Northside
1100 N. ANDREWS AVENUE
Ft. Lauderdale, FL
Phone:

Fort Lauderdale Fire Rescue
528 NW 2nd Street
Fort Lauderdale, FL 33301
Phone: (954)828-5654 Fax: (954)828-5338

Sandra Kanner (handwritten signature)

Sandra Kanner Lic. No. 117455
Municipal Firesafety Inspector

[x]FireSafety [x]Casualty [x]Sanitation

Not Present
Municipal Firesafety Inspector
(\*Fire Violations Only)

Table with columns: R69A.58, Sub No. Para., Pri, Location (Bldg No., Room No.), Type Def M-O-C, Est Cost, Deficiency Description and Corrective Action Required, # of Times Cited, Schedule for Correction Not Later Than, Current Year Status, Work Order #.

Total Non-Fire Safety Deficiencies.....3
Total Fire Safety Deficiencies (\*).....0 (Includes 0 Serious Life Safety Deficiencies\*\*)
Total Deficiencies Cited .....3

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;
Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Iring Shearer (handwritten signature)
Signature of Facility Administrator

Principal (handwritten signature)
Title

2/22/16 (handwritten date)
Date

Print Name Facility Administrator

Signature of Facility Administrator attesting to fire exit drills and review of
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.


**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/12/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District -  
Loc. No. 8053 Jim Ward Community Center  
301 NW 46 Avenue  
Plantation, FL 33317  
Phone: (954)585-2344 Fax: (954)585-2347

Plantation Fire Rescue  
550 NW 65th Avenue  
Plantation, FL 33317  
Phone: (954)797-2150 Fax: (954)797-2136



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector


[x]FireSafety [x]Casualty [x]Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
* N13.26.1	F	1	0000			inspect fire sprinkler system , provide inspection report- riser tagged, but inspection report not found		3/13/2016		
* N101.15.2.1 0	B	1	CORRID OR			repair illuminated exit sign , exit sign next to restrooms, did not work on test		3/13/2016		
* S5.13.x.2.b	B	1	MEN GROUP RR			install exhaust fan/vent to exterior , or repair if installed, no pulling unit found at time of inspection		6/11/2016		
S5.16.b.2.c	b	1	MEN GROUP RR			Remove deodorizer(s) from restroom		2/13/2016		
* F69A.58.005 .2.b.3	E	1	TECHNO LOGY CENTER			remove door stops		3/13/2016		
S5.16.b.2.c	b	1	WOMEN GROUP RR			Remove deodorizer(s) from restroom		2/13/2016		

Total Non-Fire Safety Deficiencies.....2  
Total Fire Safety Deficiencies (\*).....4 (Includes 0 Serious Life Safety Deficiencies\*\*)  
Total Deficiencies Cited .....6

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

  
\_\_\_\_\_  
Signature of Facility Administrator

Carlotta B. Shaw                      Principal                      2/23/16  
Print Name Facility Administrator                      Title                      Date

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [x] YES [ ] NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.

**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/11/2016


Safety Department  
1200A N.W. 10th Avenue  
Jakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased

Loc. No. 6091 PACE Broward - Whiddon Rogers  
2225 N. Andrews Avenue  
Ft. Lauderdale, FL 33311  
Phone: (954)561-6939

Wilton Manors Fire Rescue  
2020 Wilton Drive,  
Wilton Manors, FL 33334  
Phone: (954)828-5223 Fax: (954)828-5223



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
S5.8.d.1	B	1	CORRID OR			Replace panel w/tempered glass , in front of student RRs, display case with glass shelves		3/12/2016		
S5.9/64E -11.008	B	1	00GIRLS RR 2			Install impervious material , At vanities-Imp. floor material must wrap up 4" around unit. Seal joints at perimeter to prevent passage of liquids behind		3/12/2016		
S5.9/64E -11.008	B	1	00GIRLS RR 3			Install impervious material , At vanities-Imp. floor material must wrap up 4" around unit. Seal joints at perimeter to prevent passage of liquids behind		3/12/2016		
N1.60/S5.13 x2	B	1	106			remove improperly stored chemicals/cleaning supplies , spray bottle without a label, in storage		3/12/2016		
N101.7.9.2.6	C	1	109			Repair battery lighting			C	
S5.8b2&D2	C	1	113			install railings min 24" on windows , Storefront windows & doors need 1-1/2" safety rail at 24"-36" above the floor		5/11/2016		
N101.7.9.2.6	C	1	113			Repair battery lighting			C	
S5.11. f/H6a2-.0040 .3.c	A	1	113			repair cabinets/casework , Round off sharp corners on furniture, provide corner guards or remove		5/11/2016		
S5.12.b	B	1	115			Secure bookcase/cabinet/shelving to wall		3/12/2016		
S5.17.b.1.e	F	1	115			discontinue use of piggybacked surge strips		3/12/2016		
S5.6.e.&b	E	1	115			Provide padding for sharp edges on furniture , Round off sharp corners on furniture, provide corner guards or remove		3/12/2016		
S5.6.e.&b	E	1	115			Provide padding for sharp edges on furniture , Round off sharp corners on pen trays or provide end caps		3/12/2016		
N1.11.1.2/ N70.406.5/ S5.17.b	B	1	116			install electric receptacle cover , over phone cord access 4 x 4 plate			C	
N1.11.1.2/ N70.406.5/ S5.17.b	B	1	116			install electric receptacle cover , replace 2 x 4 broken cover			C	
S5.6.e.&b	E	1	116			Provide padding for sharp edges on furniture , Round off sharp corners on furniture, provide corner guards or remove		3/12/2016		
* S5.6.e.&b	B	1	116			remove ignition source , candle		3/12/2016		
* S5.17	B	1	116			remove unsafe electric equipment , hot wax warmer		3/12/2016		
* N101.7.9.2.6	C	1	117			Repair battery lighting		3/12/2016		

**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/11/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016

Wilton Manors Fire Rescue  
2020 Wilton Drive,  
Wilton Manors, FL 33334  
Phone: (954)828-5223 Fax: (954)828-5223

Broward County School District - Leased  
Loc. No. 6091 PACE Broward - Whiddon Rogers  
2225 N. Andrews Avenue  
Ft. Lauderdale, FL 33311  
Phone: (954)561-6939  
[x]FireSafety [x]Casualty [x]Sanitation

Sandra Kanner  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Deficiencies Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....11  
 Total Fire Safety Deficiencies (\*).....3 (Includes 0 Serious Life Safety Deficiencies\*\*)  
 Total Deficiencies Cited .....14

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
 Ten Fire Exit Drills during the School Year  YES [ ] NO (NFPA 101)

Signature of Facility Administrator  
  
 Charisse E. Mosley Asst. Director 2/25/16  
 Print Name Facility Administrator Title Date

Signature of Facility Administrator attesting to fire exit drills and review of  
 Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
 with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15  YES [ ] NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.


**Comprehensive Safety Inspection  
State Requirements for Educational Facilities**

Inspection Date: 2/18/2016

Safety Department  
1200A N.W. 10th Avenue  
Jakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District - Leased  
Loc. No. 6016 Pompano Substance Abuse Treatment Ctr-  
3090 N. Powerline Road  
Pompano Beach, FL 33069  
Phone:

State Fire Marshal's Office  
6851 W Sunrise Boulevard, Ste 150  
Plantation, FL 33313  
Phone: ((954)3-3704 Fax: (954)786-4328



Sandra Kanner Lic. No: 117455  
Municipal Firesafety Inspector

[x]FireSafety [x]Casualty [x]Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
S5.2.a.2	B	P	8088			remove hazardous plants , Tree/plant growing up between rails in front of portable QP23N.			C	
S5.11	B	P	QP23N			Repair unsafe/broken equipment , 2 tables need legs fixed			C	
S5.11	B	P	QP23N			Repair unsafe/broken equipment , repair windows that do not close tightly	2	3/19/2016		
S5.11	B	P	QP23N			Repair unsafe/broken equipment , repair/remove broken, unused junction box at exterior of portable			C	
S5.11	B	P	QP23N			Repair unsafe/broken equipment , secure downspout at ramp	2	3/19/2016		
S5.11	B	P	QP23N			Repair unsafe/broken equipment , sharp corners on pen tray at board			C	
* S5.14.1	B	P	QP23N			post inspection report in portable		3/19/2016		
S.5.12.e	C	P	QP23N			remove carpet pieces-tripping hazard , door mat		2/19/2016		
N1.11.7/S.5.17.1.e	B	P	QP23N			remove extension cords , Projector cord poses a trip hazard		3/19/2016		
* N70E.410.2.B	B	P	QP35N			install gfci within 6 ft water supply , at receptacles by drinking water dispenser	2	3/19/2016		
S5.11	B	P	QP35N			Repair unsafe/broken equipment , repair/remove broken, unused junction box at exterior of portable			C	
S5.11	B	P	QP35N			Repair unsafe/broken equipment , replace damaged downspout at stair canopy			C	
S5.11	B	P	QP35N			Repair unsafe/broken equipment , sharp corners on pen tray at board			C	
* S5.14.1	B	P	QP35N			post inspection report in portable	2	3/19/2016		
S5.10.h/6a-2.0040.10	B	P	QP35N			Provide Pest Control , hornets nest near west door			C	
S5.7.c.4	B	P	QP183N			repair fascia (wooden) , and paint	1	3/19/2016		
S5.11	B	P	QP183N			Repair unsafe/broken equipment , sharp corner on pen tray at board			C	
* S5.14.1	B	P	QP183N			post inspection report in portable	2	3/19/2016		
S5.6.e.&b	E	P	QP183N			Provide padding for sharp edges on furniture , Round off sharp corners on furniture, provide corner guards or remove		3/19/2016		
* N1.11.7/S.5.17.1.e	B	P	QP183N			remove extension cords		3/19/2016		
SD101	A	P	QP183N			Remove plug in air fresheners CORRECTED ON SITE			C	
S5.7.c.4	B	P	QP184N			repair fascia (wooden) , and paint	1	3/19/2016		
* S5.8.a	B	P	QP184N SUB			repair door (wood) , door hits jamb, does not close properly		3/19/2016		

8:49:31 AM, 2/22/2016

Status Codes: C-Completed V-Void R-Remodeled X-Demolished T-Transferred U-Under Construction

Status Codes: C-Completed V-Void R-Remodeled X-Demolished T-Transferred U-Under Construction W-Work Order Reissued

Def. Codes: ANSI= Amer. Nat. Standard F=Fla. State Statute HPPS: Handbook Public Playground Safety N=NFA O=OSHA H=Health S=SREF Chpt 5



Safety Department  
 4200A N.W. 10th Avenue  
 Oakland Park, FL 33309  
 (754)321-4200

Sandra Kanner  
 Municipal Firesafety Inspector

**Comprehensive Safety Inspection  
 State Requirements for Educational Facilities**

Fiscal Year: 2015 - 2016

Broward County School District - Leased

Loc. No. 6016 Pompano Substance Abuse Treatment Ctr-  
 3090 N. Powerline Road  
 Pompano Beach, FL 33069

Phone:

FireSafety    Casualty    Sanitation

Inspection Date: 2/18/2016

State Fire Marshal's Office  
 6851 W Sunrise Boulevard, Ste 150  
 Plantation, FL 33313  
 Phone: (954)3-3704 Fax: (954)786-4326

Not Present  
 Municipal Firesafety Inspector  
 (\*Fire Deficiencies Only)

R69A.58	Location		Type Def	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	M-O-C					
* S5.14.1	B	P	QP184N SUB		post inspection report in portable	2	3/19/2016		
* S5.9.a/ N1.13.3.3.3/ N1.13.7.4.3.	B	P	QP184N SUB		repair ceiling tiles , replace missing tiles		3/19/2016		
S5.17a1/H6a -2.0040.4	B	P	QP184N SUB		replace burned-out light bulb(s)			C	
* N1.11.7/S.5. 17.1.e	B	1	DAY ROOM		remove extension cords , at entertainment system		3/19/2016		
S5.9/64E -11.008	B	1	STAFF RR		Install impervious material , residential bathroom rugs/mats in restroom are not permitted		3/19/2016		
S5.16.b.2.c	b	1	STAFF RR		Remove deodorizer(s) from restroom		2/19/2016		
S5.16.a.4	B	1	STUDEN T RR BY DAYRM		repair exhaust fan , not running		3/19/2016		
S5.11	B	1	9699		Repair unsafe/broken equipment , replace torn basketball net		3/19/2016		
SD101	B	1	9699		Provide pad around basketball poles , one needed			C	
SD101	B	1	9699		Provide pad around basketball poles , replace torn pad		3/19/2016		
S5.12	C	1	9699		remove unsafe/unclean furniture from use , broken chair		3/19/2016		
S5.12	C	1	9699		remove unsafe/unclean furniture from use , repair 5 metal picnic tables. Mesh is detached from frame at table and/or benches, has sharp edges		3/19/2016		

Comprehensive Safety Inspection
State Requirements for Educational Facilities

Inspection Date: 2/18/2016

Safety Department
4200A N.W. 10th Avenue
Oakland Park, FL 33309
(754)321-4200

Fiscal Year: 2015 - 2016

Broward County School District - Leased

State Fire Marshal's Office
6851 W Sunrise Boulevard, Ste 150
Plantation, FL 33313
Phone: ((954)3-3704 Fax:

Loc. No. 6016 Pompano Substance Abuse Treatment Ctr-
3090 N. Powerline Road

Pompano Beach, FL 33069

Phone:

Sandra Kanner
Municipal Firesafety Inspector

Not Present
Municipal Firesafety Inspector
(\*Fire Deficiencies Only)

[x]FireSafety [x]Casualty [x]Sanitation

Table with columns: R69A.58, Sub No. Para., Pri, Location (Bldg No., Room No.), Type Def M-O-C, Est Cost, Deficiency Description and Corrective Action Required, # of Times Cited, Schedule for Correction Not Later Than, Current Year Status, Work Order #

Total Non-Fire Safety Deficiencies.....13
Total Fire Safety Deficiencies (\*).....10 (Includes 0 Serious Life Safety Deficiencies\*\*)
Total Deficiencies Cited .....23

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;
Ten Fire Exit Drills during the School Year [X] YES [ ] NO (NFPA 101)

Signature of Facility Administrator

Charisse E. Mosley Asst. Director

Print Name Facility Administrator

Title

2/25/16
Date

Signature of Facility Administrator attesting to fire exit drills and review of

Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [X] YES [ ] NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.


### Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/26/2016

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(954)321-4200

Fiscal Year: 2015 - 2016  
Broward County School District - Leased  
Loc. No. 8049 Tamarac OCLC  
6201, 6203 NW 57 Street  
Tamarac, FL, FL 33319  
Phone: (954)683-3478

Tamarac Fire Rescue  
6000 Hiatus Road  
Tamarac, FL 33321  
Phone: (954)597-3800 Fax: (954)597-3800



Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

FireSafety    Casualty    Sanitation

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

R69A.58 Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
SD101	3	000	0000			Lease Terminated.		2/26/2016		

Total Non-Fire Safety Deficiencies.....0  
Total Fire Safety Deficiencies (\*).....0 (Includes 0 Serious Life Safety Deficiencies\*\*)  
Total Deficiencies Cited .....0

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator

Print Name Facility Administrator Title Date  
Signature of Facility Administrator attesting to fire exit drills and review of Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance with Section 1013.12(2)(c), F.S.  
Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.

Comprehensive Safety Inspection
State Requirements for Educational Facilities

Inspection Date: 2/26/2016

Safety Department
4200A N.W. 10th Avenue
Oakland Park, FL 33309
(754)321-4200

Fiscal Year: 2015 - 2016
Broward County School District - Leased
Loc. No. 8033 Word of Living God Ministry - Pompano OCLC
149 NW 26 Ave.
Pompano Beach, FL 33069
Phone: (954)917-4830

Pompano Beach Fire Rescue
100 West Atlantic Blvd. #220
Pompano Beach, FL 33060
Phone: (954)786-4695 Fax: (954)786-4328

[Handwritten Signature]

Sandra Kanner Lic. No. 117455
Municipal Firesafety Inspector

[x]FireSafety [x]Casualty [x]Sanitation

Not Present
Municipal Firesafety Inspector
(\*Fire Violations Only)

Table with columns: R69A.58, Sub No., Para., Pri., Location (Bldg No., Room No.), Type Def M-O-C, Est Cost, Deficiency Description and Corrective Action Required, # of Times Cited, Schedule for Correction Not Later Than, Current Year Status, Work Order #.

Total Non-Fire Safety Deficiencies.....0
Total Fire Safety Deficiencies (\*).....0 (Includes 0 Serious Life Safety Deficiencies\*\*)
Total Deficiencies Cited .....0

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;
Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator

Print Name Facility Administrator

Title

Date

Signature of Facility Administrator attesting to fire exit drills and review of
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.

Comprehensive Safety Inspection
State Requirements for Educational Facilities

Inspection Date: 2/26/2016

Safety Department
4200A N.W. 10th Avenue
akland Park, FL 33309
(754)321-4200

Fiscal Year: 2015 - 2016
Broward County School District - Leased
Loc. No. 8036 YMCA OCLC - Off Campus Learning Centers (FKA
408 NW 14 Terrace
Ft. Lauderdale, FL 33311
Phone: (954)467-2444

Fort Lauderdale Fire Rescue
528 NW 2nd Street
Fort Lauderdale, FL 33301
Phone: (954)828-5654 Fax: (954)828-5338

Sandra Kanner Lic. No. 117455
Municipal Firesafety Inspector

[x]FireSafety [x]Casualty [x]Sanitation

Not Present
Municipal Firesafety Inspector
(\*Fire Violations Only)

Table with columns: R69A.58, Sub No. Para., Pri, Location (Bldg No., Room No.), Type Def M-O-C, Est Cost, Deficiency Description and Corrective Action Required, # of Times Cited, Schedule for Correction Not Later Than, Current Year Status, Work Order #

Total Non-Fire Safety Deficiencies.....0
Total Fire Safety Deficiencies (\*).....0 (Includes 0 Serious Life Safety Deficiencies\*\*)
Total Deficiencies Cited .....0

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;
Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator

Print Name Facility Administrator

Title

Date

Signature of Facility Administrator attesting to fire exit drills and review of
Initial Safety Inspection report acknowledging awareness of corrected and newly discovered deficiencies.

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than June 30 of this Fiscal School Year.