


# Exhibit A

## THE SCHOOL BOARD OF BROWARD COUNTY, FLORIDA

### Post Occupancy Year End Review Timeline



## THE SCHOOL BOARD OF BROWARD COUNTY, FLORIDA

### Review of Proposed Reuse Architectural Design (Contract Bulletin No. 065)

A reuse of a Proposed Architectural Design must meet the educational requirements as specified in the District's Board approved Facility List, which are submitted to FLDOE in the Five Year Educational Plant Survey 1013.31, and the District's educational requirements as specified in District's Generic Educational Specification.

- Review OEF 208 form Facility Space Chart
- Review Educational Specifications
- Review Post Occupancy Reports(s)
- Conduct analysis of all data and make comparison to District's Educational Specifications
- Coordinate Site Visit, if practical,
- Prepare report of findings and recommendation

## ONLINE POST OCCUPANCY SURVEY

Online Post Occupancy Pre-Visitation Survey

Please completely answer all of the following survey questions. The survey information will be recorded by pressing the "submit answer" button on this page.

If you have any survey questions, please call Sandra Garzon at 754-321-1932.

### Tools

[Copy this to my account](#)

[Start over](#)

[Print](#)

[Help](#)

Name:

A red asterisk (\*) indicates required questions.

1. Date:\*

2. School Name:\*

3. Location Number:\*

4. Evaluator Name:\*

5. Select your Role:\*
- Principal
  - Assistant Principal
  - Administrator
  - Teacher
  - Other

6. If your role is "Other" please specify:

7. SITE

Security:

All areas can be directly supervised?

- Yes
- No
- N/A

8. Security:

Are there a sufficient number of security cameras?

- Yes
- No
- N/A

9. Security:

Can the site be secured?

- Yes
- No
- N/A

10. Security:

Is site adequately illuminated at night?

- Yes
- No
- N/A

11. For the school security comments please indicate the FISH number and/or detail problem in the box:

12. Parking/Drives:  
Is there sufficient parking?
- Yes
  - No
  - N/A

13. Parking/Drives:  
Is student drop off sufficient?
- Yes
  - No
  - N/A

14. For the school Parking/Drives comments please indicate the FISH number and/or detail problem in the box:

15. Ground/Landscaping:  
Are Playgrounds, Fields properly located?
- Yes
  - No
  - N/A

16. Ground/Landscaping:  
Are Play Fields properly irrigated?
- Yes
  - No
  - N/A

17. Ground/Landscaping:  
All areas can be easily reached and maintained?
- Yes
  - No
  - N/A

18. Ground/Landscaping:  
Is landscaping adequate?

- Yes
- No
- N/A

19. For the school Ground/Landscaping comments please indicate the FISH number and/or detail problem in the box:

20. General:  
Is facility easily maintained?

- Yes
- No
- N/A

21. General:  
Are there an adequate number of classrooms, and labs?

- Yes
- No
- N/A

22. General:  
Are there an adequate number of water coolers?

- Yes
- No
- N/A

23. General:  
Are there a sufficient number of restrooms?

- Yes
- No
- N/A

24. General:  
Are the restrooms properly located?
- Yes
  - No
  - N/A

25. For General comments please indicate the FISH number and/or detail problem in the box:

26. Hallways/Stairways:  
Are hallways adequately illuminated?
- Yes
  - No
  - N/A

27. Hallways/Stairways:  
Are there sufficient Tack Boards in each hallway?
- Yes
  - No
  - N/A

28. Hallways/Stairways:  
Are there sufficient electrical outlets to permit routine maintenance?
- Yes
  - No
  - N/A

29. For school Hallways/Stairways comments please indicate the FISH number and/or detail problem in the box:

30. CLASSROOMS

Classrooms - Acoustics:  
Does sound travel uniformly within area?

- Yes
- No
- N/A

31. Classrooms - Acoustics:  
Are there distracting noises present?

- Yes
- No
- N/A

32. For classrooms acoustics comments please indicate the FISH number and/or detail problem in the box:

33. Classrooms - Lighting:  
Is the space uniformly illuminated?

- Yes
- No



N/A

34. Classrooms - Lighting:  
Can the area be darkened sufficiently for presentations?

- Yes
- No
- N/A

35. For classrooms lighting comments please indicate the FISH number and/or detail problem in the box:

36. Classrooms - Size, Adequacy, & Adjacency:  
Is space adequately sized?

- Yes
- No
- N/A

37. Classrooms - Size, Adequacy, & Adjacency:  
Is teacher and student storage adequate?

- Yes
- No
- N/A

38. Classrooms - Size, Adequacy, & Adjacency:  
Are related spaces in close proximity?

- Yes
- No
- N/A

39. Classrooms - Size, Adequacy, & Adjacency:

The design and layout of the area is supportive of your primary responsibility?

- Yes
- No
- N/A

40. Classrooms - Size, Adequacy, & Adjacency:

All areas can be properly maintained?

- Yes
- No
- N/A

41. Classrooms - Size, Adequacy, & Adjacency:

All areas can be directly supervised?

- Yes
- No
- N/A

42. For classrooms size, adequacy, & adjacency comments please indicate the FISH number and/or detail problem in the box:

43. Classrooms - Furniture Fixture and Equipment (FF&E):

Has all equipment been received, setup, and is working properly?

- Yes
- No
- N/A

44. Classrooms - FF&E:

Do you have all the Basic Equipment necessary to perform your primary responsibility?

- Yes
- No
- N/A

45. Classrooms - FF&E:

Is all the equipment appropriate to the performance of your primary responsibilities?

- Yes
- No
- N/A

46. For classrooms FF&E comments please indicate the FISH number and/or detail problem in the box:

47. Classrooms - Data Communications:

Are data ports properly located?

- Yes
- No
- N/A

48. Classrooms - Data Communications:

Is there the proper number of data ports?

- Yes
- No
- N/A

49. For classrooms data communications comments please indicate the FISH number and/or detail problem in the box:

50. Classrooms - Electrical Fixtures:

Are there sufficient outlets for required equipment?

- Yes
- No

N/A

51. Classrooms - Electrical Fixtures:  
Are outlets properly located?

- Yes
- No
- N/A

52. For classrooms electrical comments please indicate the FISH number and/or detail problem in the box:

53. Classrooms - Indoor Air Quality:  
All ceiling tiles are free of stains or discolored patches?

- Yes
- No
- N/A

54. Classrooms - Indoor Air Quality:  
There is no excessive condensation on windows glass, interior surfaces of exterior walls, and on pipes and fixtures?

- Yes
- No
- N/A

55. Classrooms - Indoor Air Quality:  
Relative humidity is within acceptable range of 31-59%?

- Yes
- No
- N/A

56. Classrooms - Indoor Air Quality:  
Average temperature is maintained between 72F - 76F?

- Yes
- No

N/A

57. Classrooms - Indoor Air Quality:  
The ventilation system is free of unexpected odors?

- Yes
- No
- N/A

58. Classrooms - Indoor Air Quality:  
All Educational supplies are stored or discarded properly?

- Yes
- No
- N/A

59. Classrooms - Indoor Air Quality:  
Fresh air circulates freely within area?

- Yes
- No
- N/A

60. Classrooms - Indoor Air Quality:  
All exhaust fans are working properly?

- Yes
- No
- N/A

61. For classrooms indoor air quality comments please indicate the FISH number and/or detail problem in the box:

62. MEDIA CENTER

Media Center - Acoustics:  
Does sound travel uniformly within area?

- Yes
- No

N/A

63. Media Center - Acoustics:  
Are there distracting noises present?

- Yes  
 No  
 N/A

64. For the Media Center acoustic comments please indicate the FISH number and/or detail problem in the box:

65. Media Center - Lighting:  
Is the space uniformly illuminated?

- Yes  
 No  
 N/A


66. Media Center - Lighting:  
Can the area be darkened sufficiently for presentations?

- Yes  
 No  
 N/A

67. Media Center - Lighting:  
Can the area be darkened sufficiently for presentations?

- Yes  
 No  
 N/A

68. For the Media Center lighting comments please indicate the FISH number and/or detail problem in the box:



69. Media Center - Size, Adequacy, & Adjacency:  
Is space adequately sized?

- Yes
- No
- N/A

70. Media Center - Size, Adequacy, & Adjacency:  
Is teacher and student storage adequate?

- Yes
- No
- N/A

71. Media Center - Size, Adequacy, & Adjacency:  
Are related spaces in close proximity?

- Yes
- No
- N/A

72. Media Center - Size, Adequacy, & Adjacency:  
The design and layout of the area is supportive of your primary responsibility?

- Yes
- No
- N/A

73. Media Center - Size, Adequacy, & Adjacency:  
All areas can be properly maintained?

- Yes
- No
- N/A

74. Media Center - Size, Adequacy, & Adjacency:  
All areas can be directly supervised?

- Yes

- No
- N/A

75. For the Media Center size, adequacy, & adjacency comments please indicate the FISH number and/or detail problem in the box:

76. Media Center - Furniture Fixture and Equipment (FF&E):  
Has all equipment been received, setup, and is working properly?

- Yes
- No
- N/A

77. Media Center - FF&E:  
Do you have all the Basic Equipment necessary to perform your primary responsibility?

- Yes
- No
- N/A

78. Media Center - FF&E:  
Is all the equipment appropriate to the performance of your primary responsibilities?

- Yes
- No
- N/A

79. For the Media Center FF&E comments please indicate the FISH number and/or detail problem in the box:



80. Media Center - Data Communications:  
Are data ports properly located?

- Yes
- No
- N/A

81. Media Center - Data Communications:  
Is there the proper number of data ports?

- Yes
- No
- N/A

82. For the Media Center data communications comments please indicate the FISH number and/or detail problem in the box:

83. Media Center - Electrical Fixtures:  
Are there sufficient outlets for required equipment?

- Yes
- No
- N/A

84. Media Center - Electrical Fixtures:  
Are outlets properly located?

- Yes
- No
- N/A

85. For the Media Center electrical fixtures comments please indicate the FISH number and/or detail problem in the box:



86. Media Center - Indoor Air Quality:  
All ceiling tiles are free of stains or discolored patches?  
 Yes  
 No  
 N/A

87. Media Center - Indoor Air Quality:  
There is no excessive condensation on windows glass, interior surfaces of exterior walls, and on pipes and fixtures?  
 Yes  
 No  
 N/A

88. Media Center - Indoor Air Quality:  
Relative humidity is within acceptable range of 31-59%?  
 Yes  
 No  
 N/A

89. Media Center - Indoor Air Quality:  
Average temperature is maintained between 72F - 76F?  
 Yes  
 No  
 N/A

90. Media Center - Indoor Air Quality:  
The ventilation system is free of unexpected odors?  
 Yes  
 No  
 N/A

91. Media Center - Indoor Air Quality:  
All Educational supplies are stored or discarded properly?
- Yes
  - No
  - N/A

92. Media Center - Indoor Air Quality:  
Fresh air circulates freely within area?
- Yes
  - No
  - N/A

93. Media Center - Indoor Air Quality:  
All exhaust fans are working properly?
- Yes
  - No
  - N/A

94. For the Media Center indoor air quality comments please indicate the FISH number and/or detail problem in the box:

## 95. SKILL LABS

Skill Labs - Acoustics:  
Does sound travel uniformly within area?

- Yes
- No
- N/A

96. Skill Labs - Acoustics:  
Are there distracting noises present?

- Yes
- No
- N/A

97. For the Skill Labs acoustics comments please indicate the FISH number and/or detail problem in the box:

98. Skill Labs - Lighting:  
Is the space uniformly illuminated?

- Yes
- No
- N/A

99. Skill Labs - Lighting:  
Can the area be darkened sufficiently for presentations?

- Yes
- No
- N/A

100. For the Skill Labs lighting comments please indicate the FISH number and/or detail problem in the box:

101. Skill Labs - Size, Adequacy, & Adjacency:  
Is space adequately sized?

- Yes
- No
- N/A

102. Skill Labs - Size, Adequacy, & Adjacency:  
Is teacher and student storage adequate?

- Yes
- No

N/A

103. Skill Labs - Size, Adequacy, & Adjacency:  
Are related spaces in close proximity?

- Yes
- No
- N/A

104. Skill Labs - Size, Adequacy, & Adjacency:

The design and layout of the area is supportive of your primary responsibility?

- Yes
- No
- N/A

105. Skill Labs - Size, Adequacy, & Adjacency:

All areas can be properly maintained?

- Yes
- No
- N/A

106. Skill Labs - Size, Adequacy, & Adjacency:

All areas can be directly supervised?

- Yes
- No
- N/A

107. For the Skill Labs size, adequacy, & adjacency comments please indicate the FISH number and/or detail problem in the box:

108. Skill Labs - Furniture Fixture and Equipment (FF&E):  
 Has all equipment been received, setup, and is working properly?
- Yes
  - No
  - N/A

109. Skill Labs - FF&E:  
 Do you have all the Basic Equipment necessary to perform your primary responsibility?
- Yes
  - No
  - N/A

110. Skill Labs - FF&E:  
 Is all the equipment appropriate to the performance of your primary responsibilities?
- Yes
  - No
  - N/A

111. For the Skill Labs FF&E comments please indicate the FISH number and/or detail problem in the box:

112. Skill Labs - Data Communications:  
 Are data ports properly located?
- Yes
  - No
  - N/A

113. Skill Labs - Data Communications:  
 Is there the proper number of data ports?
- Yes
  - No
  - N/A

114. For the Skill Labs data communications comments please indicate the FISH number and/or detail problem in the box:

115. Skill Labs - Electrical Fixtures:  
Are there sufficient outlets for required equipment?

- Yes
- No
- N/A

116. Skill Labs - Electrical Fixtures:  
Are outlets properly located?

- Yes
- No
- N/A

117. For the Skill Labs electrical fixtures comments please indicate the FISH number and/or detail problem in the box:

118. Skill Labs - Indoor Air Quality:  
All ceiling tiles are free of stains or discolored patches?

- Yes
- No
- N/A

119. Skill Labs - Indoor Air Quality:  
There is no excessive condensation on windows glass, interior surfaces of exterior walls, and on pipes and fixtures?

- Yes

- No
- N/A

120. Skill Labs - Indoor Air Quality:  
 Relative humidity is within acceptable range of 31-59%?

- Yes
- No
- N/A

121. Skill Labs - Indoor Air Quality:  
 Average temperature is maintained between 72F - 76F?

- Yes
- No
- N/A

122. Skill Labs - Indoor Air Quality:  
 The ventilation system is free of unexpected odors?

- Yes
- No
- N/A

123. Skill Labs - Indoor Air Quality:  
 All Educational supplies are stored or discarded properly?

- Yes
- No
- N/A

124. Skill Labs - Indoor Air Quality:  
 Fresh air circulates freely within area?

- Yes
- No
- N/A

125. Skill Labs - Indoor Air Quality:  
 All exhaust fans are working properly?

- Yes
- No
- N/A



126. For the Skill Labs indoor air quality comments please indicate the FISH number and/or detail problem in the box:

127. MUSIC

Music Area - Acoustics:

Does sound travel uniformly within area?

- Yes
- No
- N/A

128. Music Area - Acoustics:

Are there distracting noises present?

- Yes
- No
- N/A

129. For the Music Area acoustics comments please indicate the FISH number and/or detail problem in the box:

130. Music Area - Lighting:

Is the space uniformly illuminated?

- Yes
- No
- N/A

131. Music Area - Lighting:

Can the area be darkened sufficiently for presentations?

- Yes
- No
- N/A

132. For the Music Area lighting comments please indicate the FISH number and/or detail problem in the box:

133. Music Area - Size, Adequacy, & Adjacency:

Is space adequately sized?

- Yes
- No
- N/A

134. Music Area - Size, Adequacy, & Adjacency:

Is teacher and student storage adequate?

- Yes
- No
- N/A

135. Music Area - Size, Adequacy, & Adjacency:

Are related spaces in close proximity?

- Yes
- No
- N/A

136. Music Area - Size, Adequacy, & Adjacency:

The design and layout of the area is supportive of your primary responsibility?

- Yes
- No
- N/A

137. Music Area - Size, Adequacy, & Adjacency:  
All areas can be properly maintained?

- Yes
- No
- N/A

138. Music Area - Size, Adequacy, & Adjacency:  
All areas can be directly supervised?

- Yes
- No
- N/A

139. For the Music Area size, adequacy, & adjacency comments please indicate the FISH number and/or detail problem in the box:

140. Music Area -Furniture Fixture and Equipment (FF&E):  
Has all equipment been received, setup, and is working properly?

- Yes
- No
- N/A

141. Music Area - FF&E:  
Do you have all the Basic Equipment necessary to perform your primary responsibility?

- Yes
- No
- N/A

142. Music Area - FF&E:  
Is all the equipment appropriate to the performance of your primary responsibilities?

- Yes
- No
- N/A

143. For the Music Area FF&E comments please indicate the FISH number and/or detail problem in the box:

144. Music Area - Data Communications:  
Are data ports properly located?

- Yes
- No
- N/A

145. Music Area - Data Communications:  
Is there the proper number of data ports?

- Yes
- No
- N/A

146. For the Music Area data communications comments please indicate the FISH number and/or detail problem in the box:

147. Music Area - Electrical Fixtures:  
Are there sufficient outlets for required equipment?

- Yes
- No
- N/A

148. Music Area - Electrical Fixtures:  
Are outlets properly located?

- Yes
- No

N/A

149. For the Music Area data Electrical Fixtures comments please indicate the FISH number and/or detail problem in the box:

150. Music Area - Indoor Air Quality:  
All ceiling tiles are free of stains or discolored patches?

- Yes
- No
- N/A

151. Music Area - Indoor Air Quality:  
There is no excessive condensation on windows glass, interior surfaces of exterior walls, and on pipes and fixtures?

- Yes
- No
- N/A

152. Music Area - Indoor Air Quality:  
Relative humidity is within acceptable range of 31-59%?

- Yes
- No
- N/A

153. Music Area - Indoor Air Quality:  
Average temperature is maintained between 72F - 76F?

- Yes
- No
- N/A

154. Music Area - Indoor Air Quality:  
The ventilation system is free of unexpected odors?

- Yes
- No

N/A

155. Music Area - Indoor Air Quality:  
All Educational supplies are stored or discarded properly?

- Yes
- No
- N/A

156. Music Area - Indoor Air Quality:  
Fresh air circulates freely within area?

- Yes
- No
- N/A

157. Music Area - Indoor Air Quality:  
All exhaust fans are working properly?

- Yes
- No
- N/A

158. For the Music Area indoor air quality comments please indicate the FISH number and/or detail problem in the box:

159. ART

Art Area - Acoustics:  
Does sound travel uniformly within area?

- Yes
- No
- N/A

160. Art Area - Acoustics:  
Are there distracting noises present?

- Yes
- No

N/A

161. For the Art Area acoustics comments please indicate the FISH number and/or detail problem in the box:

162. Art Area - Lighting:

Is the space uniformly illuminated?

Yes

No

N/A

163. Art Area - Lighting:

Can the area be darkened sufficiently for presentations?

Yes

No

N/A

164. For the Art Area lighting comments please indicate the FISH number and/or detail problem in the box:

165. Art Area - Size, Adequacy, & Adjacency:

Is space adequately sized?

Yes

No

N/A

166. Art Area - Size, Adequacy, & Adjacency:  
Is teacher and student storage adequate?

- Yes
- No
- N/A

167. Art Area - Size, Adequacy, & Adjacency:  
Are related spaces in close proximity?

- Yes
- No
- N/A

168. Art Area - Size, Adequacy, & Adjacency:  
The design and layout of the area is supportive of your primary responsibility?

- Yes
- No
- N/A

169. Art Area - Size, Adequacy, & Adjacency:  
All areas can be properly maintained?

- Yes
- No
- N/A

170. Art Area - Size, Adequacy, & Adjacency:  
All areas can be directly supervised?

- Yes
- No
- N/A

171. For the Art Area size, adequacy, & adjacency comments please indicate the FISH number and/or detail problem in the box:



172. Art Area - Furniture Fixture and Equipment (FF&E):  
Has all equipment been received, setup, and is working properly?

- Yes
- No
- N/A

173. Art Area - FF&E:  
Do you have all the Basic Equipment necessary to perform your primary responsibility?

- Yes
- No
- N/A

174. Art Area - FF&E:  
Is all the equipment appropriate to the performance of your primary responsibilities?

- Yes
- No
- N/A

175. For the Art Area FF&E comments please indicate the FISH number and/or detail problem in the box:

176. Art Area - Data Communications:  
Are data ports properly located?

- Yes
- No
- N/A

177. Art Area - Data Communications:  
Is there the proper number of data ports?

- Yes
- No
- N/A

# Exhibit A

178. For Art Area data communications comments please indicate the FISH number and/or detail problem in the box:

179. Art Area - Electrical Fixtures:  
Are there sufficient outlets for required equipment?

- Yes
- No
- N/A

180. Art Area - Electrical Fixtures:  
Are outlets properly located?

- Yes
- No
- N/A

181. For Art Area electrical comments please indicate the FISH number and/or detail problem in the box:

182. Art Area - Indoor Air Quality:  
All ceiling tiles are free of stains or discolored patches?

- Yes
- No
- N/A

183. Art Area - Indoor Air Quality:  
There is no excessive condensation on windows glass, interior surfaces of exterior walls, and on pipes and fixtures?

- Yes

- No
- N/A

184. Art Area - Indoor Air Quality:  
Relative humidity is within acceptable range of 31-59%?

- Yes
- No
- N/A

185. Art Area - Indoor Air Quality:  
Average temperature is maintained between 72F - 76F?

- Yes
- No
- N/A

186. Art Area - Indoor Air Quality:  
The ventilation system is free of unexpected odors?

- Yes
- No
- N/A

187. Art Area - Indoor Air Quality:  
All Educational supplies are stored or discarded properly?

- Yes
- No
- N/A

188. Art Area - Indoor Air Quality:  
Fresh air circulates freely within area?

- Yes
- No
- N/A

189. Art Area - Indoor Air Quality:  
All exhaust fans are working properly?

- Yes
- No
- N/A

190. For Art Area indoor air quality comments please indicate the FISH number and/or detail problem in the box:

191. MULTIPURPOSE/STAGE/AUDITORIUM

Multipurpose/Stage/Auditorium - Acoustics:  
Does sound travel uniformly within area?

- Yes
- No
- N/A

192. Multipurpose/Stage/Auditorium - Acoustics:  
Are there distracting noises present?

- Yes
- No
- N/A

193. For the Multipurpose/Stage/Auditorium acoustics comments please indicate the FISH number and/or detail problem in the box:

194. Multipurpose/Stage/Auditorium - Lighting:  
Is the space uniformly illuminated?

- Yes
- No
- N/A

195. Multipurpose/Stage/Auditorium - Lighting:  
Can the area be darkened sufficiently for presentations?

- Yes
- No
- N/A

196. For the Multipurpose/Stage/Auditorium lighting comments please indicate the FISH number and/or detail problem in the box:

197. Multipurpose/Stage/Auditorium - Size, Adequacy, & Adjacency:  
Is space adequately sized?

- Yes
- No
- N/A

198. Multipurpose/Stage/Auditorium - Size, Adequacy, & Adjacency:  
Is teacher and student storage adequate?

- Yes
- No
- N/A

199. Multipurpose/Stage/Auditorium - Size, Adequacy, & Adjacency:  
Are related spaces in close proximity?

- Yes
- No
- N/A

200. Multipurpose/Stage/Auditorium - Size, Adequacy, & Adjacency:  
The design and layout of the area is supportive of your primary responsibility?

- Yes
- No
- N/A

201. Multipurpose/Stage/Auditorium - Size, Adequacy, & Adjacency:  
All areas can be properly maintained?

- Yes
- No
- N/A

202. Multipurpose/Stage/Auditorium - Size, Adequacy, & Adjacency:  
All areas can be directly supervised?

- Yes
- No
- N/A

203. For the Multipurpose/Stage/Auditorium size, adequacy, & adjacency comments please indicate the FISH number and/or detail problem in the box:

204. Multipurpose/Stage/Auditorium - Furniture Fixture and Equipment (FF&E):  
Has all equipment been received, setup, and is working properly?

- Yes
- No
- N/A

205. Multipurpose/Stage/Auditorium - FF&E:  
Do you have all the Basic Equipment necessary to perform your primary responsibility?

- Yes
- No
- N/A

206. Multipurpose/Stage/Auditorium - FF&E:  
Is all the equipment appropriate to the performance of your primary responsibilities?

- Yes
- No
- N/A

207. For the Multipurpose/Stage/Auditorium FF&E comments please indicate the FISH number and/or detail problem in the box:

208. Multipurpose/Stage/Auditorium - Data Communications:  
Are data ports properly located?

- Yes
- No
- N/A

209. Multipurpose/Stage/Auditorium - Data Communications:  
Is there the proper number of data ports?

- Yes
- No
- N/A

210. For the Multipurpose/Stage/Auditorium data communications comments please indicate the FISH number and/or detail problem in the box:

211. Multipurpose/Stage/Auditorium - Electrical Fixtures:  
Are there sufficient outlets for required equipment?

- Yes
- No
- N/A

212. Multipurpose/Stage/Auditorium - Electrical Fixtures:  
Are outlets properly located?

- Yes
- No

N/A

213. For the Multipurpose/Stage/Auditorium electrical fixtures comments please indicate the FISH number and/or detail problem in the box:

214. Multipurpose/Stage/Auditorium - Indoor Air Quality:  
All ceiling tiles are free of stains or discolored patches?

- Yes
- No
- N/A

215. Multipurpose/Stage/Auditorium - Indoor Air Quality:  
There is no excessive condensation on windows glass, interior surfaces of exterior walls, and on pipes and fixtures?

- Yes
- No
- N/A

216. Multipurpose/Stage/Auditorium - Indoor Air Quality:  
Relative humidity is within acceptable range of 31-59%?

- Yes
- No
- N/A

217. Multipurpose/Stage/Auditorium - Indoor Air Quality:  
Average temperature is maintained between 72F - 76F?

- Yes
- No
- N/A

218. Multipurpose/Stage/Auditorium - Indoor Air Quality:  
The ventilation system is free of unexpected odors?

- Yes
- No



N/A

219. Multipurpose/Stage/Auditorium - Indoor Air Quality:  
All Educational supplies are stored or discarded properly?

- Yes
- No
- N/A

220. Multipurpose/Stage/Auditorium - Indoor Air Quality:  
Fresh air circulates freely within area?

- Yes
- No
- N/A

221. Multipurpose/Stage/Auditorium - Indoor Air Quality:  
All exhaust fans are working properly?

- Yes
- No
- N/A

222. For the Multipurpose/Stage/Auditorium indoor air quality comments please indicate the FISH number and/or detail problem in the box:

223. FOOD SERVICE

Food Service - Acoustics:  
Does sound travel uniformly within area?

- Yes
- No
- N/A

224. Food Service - Acoustics:  
Are there distracting noises present?

- Yes
- No

N/A

225. For the Food Service acoustics comments please indicate the FISH number and/or detail problem in the box:

226. Food Service - Lighting:  
Is the space uniformly illuminated?

- Yes
- No
- N/A

227. Food Service - Lighting:  
Can the area be darkened sufficiently for presentations?

- Yes
- No
- N/A

228. For the Food Service lighting comments please indicate the FISH number and/or detail problem in the box:

229. Food Service - Size, Adequacy, & Adjacency:  
Is space adequately sized?

- Yes
- No
- N/A

230. Food Service - Size, Adequacy, & Adjacency:  
Is teacher and student storage adequate?

- Yes
- No
- N/A

231. Food Service - Size, Adequacy, & Adjacency:  
Are related spaces in close proximity?

- Yes
- No
- N/A

232. Food Service - Size, Adequacy, & Adjacency:  
The design and layout of the area is supportive of your primary responsibility?

- Yes
- No
- N/A

233. Food Service - Size, Adequacy, & Adjacency:  
All areas can be properly maintained?

- Yes
- No
- N/A

234. Food Service - Size, Adequacy, & Adjacency:  
All areas can be directly supervised?

- Yes
- No
- N/A

235. For the Food Service size, adequacy, & adjacency comments please indicate the FISH number and/or detail problem in the box:

236. Food Service - Furniture Fixture and Equipment (FF&E):  
Has all equipment been received, setup, and is working properly?
- Yes
  - No
  - N/A

237. Food Service - FF&E:  
Do you have all the Basic Equipment necessary to perform your primary responsibility?
- Yes
  - No
  - N/A

238. Food Service - FF&E:  
Is all the equipment appropriate to the performance of your primary responsibilities?
- Yes
  - No
  - N/A

239. For the Food Service FF&E comments please indicate the FISH number and/or detail problem in the box:

240. Food Service - Data Communications:  
Are data ports properly located?
- Yes
  - No
  - N/A
241. Food Service - Data Communications:  
Is there the proper number of data ports?
- Yes
  - No
  - N/A

242. For the Food Service data communications comments please indicate the FISH number and/or detail problem in the box:

243. Food Service - Electrical Fixtures:  
Are there sufficient outlets for required equipment?

- Yes
- No
- N/A

244. Food Service - Electrical Fixtures:  
Are outlets properly located?

- Yes
- No
- N/A

245. For the Food Service electrical fixtures comments please indicate the FISH number and/or detail problem in the box:

246. Food Service - Indoor Air Quality:  
All ceiling tiles are free of stains or discolored patches?

- Yes
- No
- N/A

247. Food Service - Indoor Air Quality:  
There is no excessive condensation on windows glass, interior surfaces of exterior walls, and on pipes and fixtures?

- Yes

**Exhibit A**

- No
- N/A

248. Food Service - Indoor Air Quality:  
Relative humidity is within acceptable range of 31-59%?

- Yes
- No
- N/A

249. Food Service - Indoor Air Quality:  
Average temperature is maintained between 72F - 76F?

- Yes
- No
- N/A

250. Food Service - Indoor Air Quality:  
The ventilation system is free of unexpected odors?

- Yes
- No
- N/A

251. Food Service - Indoor Air Quality:  
All Educational supplies are stored or discarded properly?

- Yes
- No
- N/A

252. Food Service - Indoor Air Quality:  
Fresh air circulates freely within area?

- Yes
- No
- N/A

253. Food Service - Indoor Air Quality:  
All exhaust fans are working properly?

- Yes
- No
- N/A

254. For the Food Service indoor air quality comments please indicate the FISH number and/or detail problem in the box:

255. P.E AREA

P.E Area - Acoustics:

Does sound travel uniformly within area?

- Yes
- No
- N/A

256. P.E Area - Acoustics:

Are there distracting noises present?

- Yes
- No
- N/A

257. For the P.E Area acoustic comments please indicate the FISH number and/or detail problem in the box:

258. P.E Area - Lighting:

Is the space uniformly illuminated?

- Yes
- No
- N/A

259. P.E Area - Lighting:

Can the area be darkened sufficiently for presentations?

- Yes
- No
- N/A

260. For the P.E Area lighting comments please indicate the FISH number and/or detail problem in the box:

261. P.E Area - Size, Adequacy, & Adjacency:

Is space adequately sized?

- Yes
- No
- N/A

262. P.E Area - Size, Adequacy, & Adjacency:

Is teacher and student storage adequate?

- Yes
- No
- N/A

263. P.E Area - Size, Adequacy, & Adjacency:

Are related spaces in close proximity?

- Yes
- No
- N/A

264. P.E Area - Size, Adequacy, & Adjacency:

The design and layout of the area is supportive of your primary responsibility?

- Yes
- No
- N/A



265. P.E Area - Size, Adequacy, & Adjacency:  
All areas can be properly maintained?

- Yes
- No
- N/A

266. P.E Area - Size, Adequacy, & Adjacency:  
All areas can be directly supervised?

- Yes
- No
- N/A

267. For the P.E Area size, adequacy, & adjacency comments please indicate the FISH number and/or detail problem in the box:

268. P.E Area - Furniture Fixture and Equipment (FF&E):  
Has all equipment been received, setup, and is working properly?

- Yes
- No
- N/A

269. P.E Area - FF&E:  
Do you have all the Basic Equipment necessary to perform your primary responsibility?

- Yes
- No
- N/A

270. P.E Area - FF&E:  
Is all the equipment appropriate to the performance of your primary responsibilities?

- Yes
- No
- N/A

271. For the P.E Area FF&E comments please indicate the FISH number and/or detail problem in the box:

272. P.E Area - Data Communications:  
Are data ports properly located?

- Yes
- No
- N/A

273. P.E Area - Data Communications:  
Is there the proper number of data ports?

- Yes
- No
- N/A

274. For the P.E Area data communications comments please indicate the FISH number and/or detail problem in the box:

275. P.E Area - Electrical Fixtures:  
Are there sufficient outlets for required equipment?

- Yes
- No
- N/A

276. P.E Area - Electrical Fixtures:  
Are outlets properly located?

- Yes
- No

N/A

277. For the P.E Area electrical fixtures comments please indicate the FISH number and/or detail problem in the box:

278. P.E Area - Indoor Air Quality:  
All ceiling tiles are free of stains or discolored patches?

- Yes
- No
- N/A

279. P.E Area - Indoor Air Quality:  
There is no excessive condensation on windows glass, interior surfaces of exterior walls, and on pipes and fixtures?

- Yes
- No
- N/A

280. P.E Area - Indoor Air Quality:  
Relative humidity is within acceptable range of 31-59%?

- Yes
- No
- N/A

281. P.E Area - Indoor Air Quality:  
Average temperature is maintained between 72F - 76F?

- Yes
- No
- N/A

282. P.E Area - Indoor Air Quality:  
The ventilation system is free of unexpected odors?

- Yes
- No

N/A

283. P.E Area - Indoor Air Quality:  
All Educational supplies are stored or discarded properly?

- Yes
- No
- N/A

284. P.E Area- Indoor Air Quality:  
Fresh air circulates freely within area?

- Yes
- No
- N/A

285. P.E Area - Indoor Air Quality:  
All exhaust fans are working properly?

- Yes
- No
- N/A

286. For the P.E Area indoor air quality comments please indicate the FISH number and/or detail problem in the box:

287. ADMINISTRATION AND CUSTODIAL

Administration and Custodial Area - Acoustics:  
Does sound travel uniformly within area?

- Yes
- No
- N/A

288. Administration and Custodial Area - Acoustics:  
Are there distracting noises present?

- Yes
- No

N/A

289. For Administration and Custodial Area acoustics comments please indicate the FISH number and/or detail problem in the box:

290. Administration and Custodial Area - Lighting:  
Is the space uniformly illuminated?

- Yes
- No
- N/A

291. Administration and Custodial Area - Lighting:  
Can the area be darkened sufficiently for presentations?

- Yes
- No
- N/A

292. For Administration and Custodial Area lighting comments please indicate the FISH number and/or detail problem in the box:

293. Administration and Custodial Area - Size, Adequacy, & Adjacency:  
Is space adequately sized?

- Yes
- No
- N/A

294. Administration and Custodial Area - Size, Adequacy, & Adjacency:  
Is teacher and student storage adequate?

- Yes
- No
- N/A

295. Administration and Custodial Area - Size, Adequacy, & Adjacency:  
Are related spaces in close proximity?

- Yes
- No
- N/A

296. Administration and Custodial Area - Size, Adequacy, & Adjacency:  
The design and layout of the area is supportive of your primary responsibility?

- Yes
- No
- N/A

297. Administration and Custodial Area - Size, Adequacy, & Adjacency:  
All areas can be properly maintained?

- Yes
- No
- N/A

298. Administration and Custodial Area - Size, Adequacy, & Adjacency:  
All areas can be directly supervised?

- Yes
- No
- N/A

299. For Administration and Custodial Area size, adequacy, & adjacency comments please indicate the FISH number and/or detail problem in the box:

300. Administration and Custodial Area - Furniture Fixture and Equipment (FF&E):  
Has all equipment been received, setup, and is working properly?

- Yes
- No
- N/A

301. Administration and Custodial Area - FF&E:

Do you have all the Basic Equipment necessary to perform your primary responsibility?

- Yes
- No
- N/A

302. Administration and Custodial Area - FF&E:

Is all the equipment appropriate to the performance of your primary responsibilities

- Yes
- No
- N/A

303. For Administration and Custodial Area FF&E comments please indicate the FISH number and/or detail problem in the box:

304. Administration and Custodial Area - Data Communications:  
Are data ports properly located?

- Yes
- No
- N/A

305. Administration and Custodial Area - Data Communications:  
Is there the proper number of data ports?

- Yes
- No
- N/A

**Exhibit A**

306. For Administration and Custodial Area data communications comments please indicate the FISH number and/or detail problem in the box:

307. Administration and Custodial Area - Electrical Fixtures:  
Are there sufficient outlets for required equipment?

- Yes
- No
- N/A

308. Administration and Custodial Area - Electrical Fixtures:  
Are outlets properly located?

- Yes
- No
- N/A

309. For Administration and Custodial Area electrical comments please indicate the FISH number and/or detail problem in the box:

310. Administration and Custodial Area - Indoor Air Quality:  
All ceiling tiles are free of stains or discolored patches?

- Yes
- No
- N/A

311. Administration and Custodial Area - Indoor Air Quality:  
There is no excessive condensation on windows glass, interior surfaces of exterior walls, and on pipes and fixtures?

- Yes



- No
- N/A

312. Administration and Custodial Area - Indoor Air Quality:  
Relative humidity is within acceptable range of 31-59%?

- Yes
- No
- N/A

313. Administration and Custodial Area - Indoor Air Quality:  
Average temperature is maintained between 72F - 76F?

- Yes
- No
- N/A

314. Administration and Custodial Area - Indoor Air Quality:  
The ventilation system is free of unexpected odors?

- Yes
- No
- N/A

315. Administration and Custodial Area - Indoor Air Quality:  
All Educational supplies are stored or discarded properly?

- Yes
- No
- N/A

316. Administration and Custodial Area - Indoor Air Quality:  
Fresh air circulates freely within area?

- Yes
- No
- N/A

317. Administration and Custodial Area - Indoor Air Quality:  
All exhaust fans are working properly?

- Yes
- No
- N/A

318. For Administration and Custodial Area indoor air quality comments please indicate the FISH number and/or detail problem in the box:

**Submit answers**



Facility Management,  
Planning and Site  
Acquisition

Fort Lauderdale, FL

[View profile](#)

