

**2013 – 2014**

**ANNUAL COMPREHENSIVE  
SAFETY INSPECTION  
REPORTS**

**Leased or Off Campus Sites  
Broward County Public Schools**

**Submitted By:  
SAFETY DEPARTMENT  
SCHOOL BOARD OF BROWARD COUNTY, FLORIDA  
<http://www.browardschools.com>**

**DURING AN EMERGENCY, IMPORTANT INFORMATION  
FOR SCHOOLS IS AVAILABLE ON:**

**WKPX AT 88.5 ON FM RADIO  
AND**

**“BECON” on CABLE TELEVISION**

**Please contact your cable television company for the proper channel.**



Broward County Public Schools  
The School Board of Broward County, Florida

Patricia Good, Chair

Donna P. Korn, Vice Chair

Robin Bartleman

Heather P. Brinkworth

Abby M. Freedman

Laurie Rich Levinson

Ann Murray

Dr. Rosalind Osgood

Nora Rupert

Robert W. Runcie  
Superintendent of Schools

**“The School Board of Broward County, Florida, prohibits any policy or procedure which results in discrimination on the basis of age, color, disability, gender identity, gender expression, national origin, marital status, race, religion, sex or sexual orientation. Individuals who wish to file a discrimination and/or harassment complaint may call the Executive Director, Benefits & EEO Compliance at 754-321-2150 or Teletype Machine (TTY) 754-321-2158”**

[www.browardschools.com](http://www.browardschools.com)  
[www.broward.k12.fl.us/safetydept](http://www.broward.k12.fl.us/safetydept)

In a declared emergency, (754) 321-4200 is monitored 24 hours a day.



**Fiscal Year: 2013-2014**  
**Leased or Off Campus Facilities**  
**Index**

7085	Alphabetland - Coral Springs
7061	Alphabetland Margate - School Readiness
7062	Alphabetland North Lauderdale - School Readiness
5223	Alternative Education Systems
6051	AMI Kids Greater Ft. Laud. Whiddon Rogers
8070	Ann Stork Center - ESE/Whispering Pines
8071	ARC Broward Inc. - Whispering Pines Center
8090	Atlantic Shores Hospital
8081	Baby Boomers- Pre-School
7055	Baudhiun Pre-School
8078	Broward Children's Center North - Pre-school ESE Agency
8079	Broward Children's Center, South - Pre-school ESE Agency
7101	Broward Educational Foundation
8301	Broward Girl's Academy (DJJ) - Whispering Pines School
6011	Broward Juvenile Detention Center - Whiddon Rogers
6017	Broward Youth Treatment Center, Whiddon-Rogers
7075	Building Bridges Pre-School
9393	Central Area Maintenance (PPO Zone 2)
8095	Citrus Health Network
8052	College Plaza
7032	Family Success Center - Hallandale Adult (Carver Ranches)
8220	First Church of Christ, Scientist (Parking Lot Only)
7033	Hispanic Unity of Florida, Inc.
7028	Off Campus McNicol - South Broward Community
6091	PACE Broward - Whiddon Rogers
0186	Pompano Preschool/ Amanda's Place - Dave Thomas Ed. Center
6061	Pompano Substance Abuse Treatment Center-Whiddon Rogers
7102	Pre-School Edu Services-Broward Children's Center, Inc.
8230	Pre-School Edu Services-Broward Children's Center, Inc.
8049	Tamarac OCLC
8240	The Shepherd's Way – Parking Lot Only
8072	United Cerebral Palsy Center - Whispering Pines/Pre-School
8174	United Cerebral Palsy Day Training Program
8033	Word of Living God Ministry - Pompano OCLC
8036	YMCA OCLC

fka = formerly known as

OCLC = Off Campus Learning Center



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/31/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7085 Alphetland - Coral Springs  
3901 Coral Springs Drive  
954.752.9547  
Coral Springs, FL 33065

Coral Springs Fire Rescue  
2801 Coral Springs Drive  
Coral Springs, FL 33065  
Phone: (954)346-1396 Fax: (954)346-1387

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
08-aa-04	B	1	000	C		Check threshold dropoff >1/2" AFF			C	
10-b5-a	C	1	000	M	1000	install railings min 24" on windows V: not required			V	
* 09-a3-1	E	1	000	O	0	remove drapes < fire spread standard			C	
00-02-88	B	1	000	M	625	Secure bookcase/cabinet/shelving to wall			C	
02-l -6	B	1	9699	M	1500	Playground: Add sand to 12" depth			C	
* 13-a2-a6	B	1	Janitor	O	0	remove improperly stored chemicals			C	
* 16-f1-02	B	1	Receptio	O	0	install electric receptacle cover			C	
09-c1-1	B	1	Toilets	M	1875	repair bathroom partitions			C	
05-00-01	B	1	Toilets	M	875	Replace glass mirror w/reflective metal mirror			C	

Total Non-Fire Safety Deficiencies.....0

Total Fire Safety Deficiencies (\*).....0

(Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....0

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/3/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 7061 Alphetland Margate - School Readiness  
2851 N. SR #7  
954.975.9549  
Margate, FL 33063

Margate Fire Rescue  
600 Rock Island Road  
Margate, FL 33063  
Phone: (954)971-7010 Fax: (954)971-4561

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
10-b5-a	C	1	Glass	M	1000	install railings min 24" on windows			C	
* 10-A -5	B	1	Main Ent	O	0	remove artwork/material > 20% wall space			C	
* 16c 1	C	1	Main/offi ce	M	375	Repair battery lighting		4/2/2014		
02-I -6	B	1	Playgrou	M	1500	Playground: Add sand to 12" depth			C	
* 16-c -1	C	1	Pre-ks	M	375	Repair battery lighting			C	
* 10-12-g	C	1	Rooms	O	0	post exit diagrams in each room			C	
05-00-01	B	1	Toilets	M	875	Replace glass mirror w/reflective metal mirror			C	

Total Non-Fire Safety Deficiencies.....0

Total Fire Safety Deficiencies (\*).....1

Total Deficiencies Cited .....1

(Includes .....0 Serious Life Safety Deficiencies\*\*)

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/4/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7062 Alpharetland North Lauderdale - School  
7540 Southgate Blvd.  
754.720.7547  
North Lauderdale, FL 33068

N. Lauderdale Fire Rescue  
6151 Bailey Road  
No. Lauderdale, FL 33068  
Phone: (954)720-4315 Fax: (954)720-9428

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Steve Springs 808370  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
13-u1-6a	B	1	9698	M	156	Provide signage to read the following:			C	
* 16-g -01	B	1	9698	M	438	replace damaged light fixture			C	
02-l -6	B	1	9699	M	1500	Playground: Add sand to 12" depth			C	
02-l -10	B	1	9699	O	0	Playground: Need proper clearance for equip			C	
02-a -5	B	1	9699	M	625	remove trees			C	
* 16-f2-02	B	1	Artstora	O	0	install light covers			C	
* 16-f2-02	B	1	Cafeteri	O	0	install light covers			C	
* 10-L2-c	C	1	Cafeteri	M	157	post capacity sign			C	
* 11-a8-01	F	1	Cafeteri	M	38	reinspect fire extinguishers			C	
* 16-c -1	C	1	Cafeteri	M	375	Repair battery lighting			C	
* 16c 1	C	1	Class	M	375	Repair battery lighting, main classroom			C	
* 10-12-g	C	1	Clrms.	O	0	post exit diagrams in each room			C	
* 16-f1-02	B	1	Copyroo m	O	0	install electric receptacle cover			C	
* 16-e -2	D	1	Elecpa n e	M	1000	repair fire alarm system			C	
* cs-01-05	B	1	Elecpa n e	M	1250	Repair/Secure Electrical Panel Box			C	
10-b5-a	C	1	Glass	M	1000	install railings min 24" on windows	2	6/2/2014		
* 11-a8-01	F	1	Kitchen	M	38	reinspect fire extinguishers			C	
16-05-01	A	1	Pre-k	O	0	Provide childproof protective recept cover			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/4/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7062 Alphabetland North Lauderdale - School  
7540 Southgate Blvd.  
754.720.7547  
North Lauderdale, FL 33068

N. Lauderdale Fire Rescue  
6151 Bailey Road  
No. Lauderdale, FL 33068  
Phone: (954)720-4315 Fax: (954)720-9428

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Steve Springs 808370  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 16-g -02	F	1	Receptio	O	0	discontinue use of piggybacked surge strips			C	
* 11-a8-01	F	1	Receptio	M	38	reinspect fire extinguishers			C	
* 16-f1-02	B	1	Toddler	O	0	install electric receptacle cover			C	
* 16-f1-07	B	1	Toddler	M	250	install gfci within 6 ft water supply			C	
16-05-01	A	1	Toddler	O	0	Provide childproof protective recept cover			C	
05-00-01	B	1	Toddler	M	875	Replace glass mirror w/reflective metal mirror			C	
* 16-c -	C	1	Toilet	M	625	install battery lighting			C	
05-00-01	B	1	Toilets	M	875	Replace glass mirror w/reflective metal mirror			C	

Total Non-Fire Safety Deficiencies.....1

Total Fire Safety Deficiencies (\*).....0

(Includes .....0.....Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....1

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year ☐ YES ☐ NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 ☐ YES ☐ NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 5223 Alternative Education Systems  
5925 McKinley Street  
954.963.9549  
Hollywood, FL 33021

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							
* 02-c -03	B	1	9599	M	3500	fence in electric transformer (8')			C	
11-h2-2	B	1	9699	O	0	Provide pad around basketball poles			C	
* 10-12-g	C	1	Classrm s	O	0	post exit diagrams in each room			C	
000288	B	1	Classrm s	M	625	Secure bookcase/cabinet/shelving to wall		3/30/2014		
* 16-g -02	F	1	Clstrm.	O	0	discontinue use of piggybacked surge strips			C	
S5.8	E	1	Exits Doors	M	1200	Change of level at doors and thresholds to be 1/2 or less in height.		4/29/2014		
S58 C1	B	1	Mech Rm	M	488	replace exit hardware, A/C rm next to toilets has lock on the inside, provide hardware that cannot be locked from the inside		3/30/2014		
02-l -6	B	1	Playgrd.	M	1500	Playground: Add sand to 12" depth			X	
S5.9.1	B	1	Toilets	O	0	Install impervious material, all walls in toilet rooms to a height of 4' above the floor		3/30/2014		
S5.9.1	B	1	Toilets	O	0	Install impervious material, Vinyl base is not permitted-Impervious floor material must wrap up 4" on wall		3/30/2014		
S5.16.b.6	E	1	Toilets	M	11500	Provide separate restrooms for male and female students > grade 3.		3/30/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 5223 Alternative Education Systems  
5925 McKinley Street  
954.963.9549  
Hollywood, FL 33021

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....6

Total Fire Safety Deficiencies (\*).....0

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....6

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/10/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 6051 AMI Kids Greater Ft. Laud. Whiddon Rogers  
3220 SW 4 Ave  
954.764.9547  
Ft. Lauderdale, FL 33316

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety    ☒ Casualty    ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 09-a -5	E	1	000	C	250	check flame spread interior surfaces			C	
* 95-17-2	B	1	000	M	175	Install Fish/Room Number	2	4/9/2014		
01-02-01	B	1	000	O	0	Strap TV's to mobile cart	4	4/9/2014		
* 08-b -2	E	1	10a	M	3750	install rated fire doors	3	9/6/2014		
* 16-f1-01	B	1	001	M	63	install junction box cover			C	
* 08-c -1	C	1	011	M	438	remove/replace key deadbolts			C	
* 16-c -1	C	1	011	M	375	Repair battery lighting			C	
* 09-c0-01	B	1	111	M	2500	repair walls			C	
* 08-c -2	B	1	012	O	0	remove lock/latch from exit door			C	
* 09-c1-01	B	1	004	M	625	install proper hardware (door)			C	
* 12-g -1	C	1	004	O	0	remove furnishings blocking exit			C	
* 08-a -02	B	1	004	M	438	repair door (metal)			C	
* 16-f1-14	B	1	005	O	0	remove adapters			C	
* 10-h -3	D	1	006	M	1875	install smoke detector	4	4/9/2014		
* 02-c -03	B	1	8088	M	3500	fence in electric transformer (8")			C	
13-u1-6a	B	1	8088	M	156	Provide signage to read the following:			C	
02-c8-2	B	1	9699	M	1250	repair fence			C	
* 16-g -02	F	1	Bus.mgr.	O	0	discontinue use of piggybacked surge strips			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/10/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 6051 AMI Kids Greater Ft. Laud. Whiddon Rogers  
3220 SW 4 Ave  
954.764.9547  
Ft. Lauderdale, FL 33316

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
* 08-g -I		C	1	Clrms.	M	157	install emergency escape sign	2	4/9/2014		
* 10-12-g		C	1	Clrms.	O	0	post exit diagrams in each room			C	
* 16-g -02		F	1	De#2	O	0	discontinue use of piggybacked surge strips			C	
* 16-f1-09		B	1	Dir.oper	O	0	remove extension cords			C	
* 16-e -2		D	1	Electric	M	1000	repair fire alarm system			C	
* 16-a -2		C	1	Mainentr	M	313	repair electric exit sign			C	
* 16-f2-01		B	1	Outside	M	250	repair light fixture			C	
* 16-f1-09		B	1	Resourc e	O	0	remove extension cords			C	
02-d2-2		B	1	Sidewalk	M	1250	Rpr/Rpl sidewalk (concrete)			C	
15a421		B	1	Student Restroo ms	M	1875	install exhaust fan/vent to exterior		7/8/2014		
* 09-a0-01		B	1	Toilets	M	3125	repair ceilings			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/10/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 6051 AMI Kids Greater Ft. Laud. Whiddon Rogers  
3220 SW 4 Ave  
954.764.9547  
Ft. Lauderdale, FL 33316

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C						

Total Non-Fire Safety Deficiencies.....2

Total Fire Safety Deficiencies (\*).....4 (Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....6

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/27/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8070 Ann Stork Center - ESE/Whispering Pines  
1790 SW 43 Way  
954.584.9545  
Ft. Lauderdale, FL 33317

Broward Sheriff's Office Dept of Fire  
2601 W. Broward Blvd. #3061  
Fort Lauderdale, FL 33312  
Phone: (954)831-8210 Fax: (954)831-8218

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 11-a8-01	F	Admi	Corridor	M	38	reinspect fire extinguishers			C	
* 12-g -1	C	Admi	Corridor	O	0	remove furnishings blocking exit			C	
* 15-b -5	B	Admi	Elec.rm.	O	0	Remove storage from electrical room.			C	
* 16-e -2	D	Admi	Elec.rm.	M	1000	repair fire alarm system			C	
* 16-g -02	F	Admi	Humanre I	O	0	discontinue use of piggybacked surge strips	2	3/29/2014		
* 13-o0-04	E	Admi	Kitchen	M	437	repair hood			C	
80-02-06	B	Admi	Linen	M	5000	Repair Roof			C	
* 15-a -5	B	Admi	Mech.	O	0	remove storage from mechanical rooms			C	
00-00-50	A	Admi	Mech. rm.	O	0	Remove Guillotine Paper Cutters			C	
* 16-g -02	F	Admi	Receptio	O	0	discontinue use of piggybacked surge strips			C	
* 16-f1-09	B	Admi	Receptio	O	0	remove extension cords			C	
S5.8.c.2	E	Admin	Classroom	M	250	Install door closer., NE door to playground		3/13/2014		
* 16e 16	D	Admin	Corridor	M	1500	Repair magnetic/hydraulic door release, top magnet missing on W.dbl door		8/26/2014		
09-a -29	B	Dtp	000	O	0	remove unrated cloth/paper covering window			C	
* 10-a5-1	B	Dtp	Art	M	438	repair door closure			C	
* 08-g2-1	C	Dtp	Clrms	C	3750	install emergency escape window	3	5/28/2014		
** 2 -a -5	F	Dtp	Clrms	M	7500	LSC: Provide protected corridors/stairs	3	2/27/2014		
* 08-c -1	C	Dtp	Clrms.	M	438	remove/replace key deadbolts			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/27/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8070 Ann Stork Center - ESE/Whispering Pines  
1790 SW 43 Way  
954.584.9545  
Ft. Lauderdale, FL 33317

Broward Sheriff's Office Dept of Fire  
2601 W. Broward Blvd. #3061  
Fort Lauderdale, FL 33312  
Phone: (954)831-8210 Fax: (954)831-8218

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety    ☒ Casualty    ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 16-f1-09	B	Dtp	Confere n	O	0	remove extension cords			C	
* 12-a -	F	Dtp	Kitchen	O	0	remove combustible materials			C	
* 09-b0-01	B	Dtp	Kitchen	O	0	repair ceiling tiles			C	
* cs-01-05	B	Dtp	Kitchen	M	1250	Repair/Secure Electrical Panel Box			C	
* 12-a -	F	Dtp	Shed	O	0	remove combustible materials			C	
* 16-f2-02	B	Dtp	Toilets	O	0	install light covers			C	
* 09-a3-1	E	Dtp	Toilets	O	0	remove drapes < fire spread standard			C	
* 16-f1-15	B	Dtp	Toilets	O	0	remove unsafe electric equipment			C	
05-00-01	B	Dtp	Toilets	M	875	Replace glass mirror w/reflective metal mirror			C	
10-b5-a	C	Ps-a	000	M	1000	install railings min 24" on windows	3	5/28/2014		
01-02-01	B	Ps-a	000	O	0	Strap TV's to mobile cart			C	
16-05-01	A	Ps-a	00a	O	0	Provide childproof protective recept cover			C	
* 16-f1-07	B	Ps-a	011	M	250	install gfci within 6 ft water supply	3	3/29/2014		
* cs-01-05	B	Ps-a	9599	M	1250	Repair/Secure Electrical Panel Box			C	
* 16-f1-15	B	Ps-a	Baby Rm.	O	0	remove unsafe electric equipment			C	
cs-01-20	B	Ps-a	Baby Rm.	M	2500	Repair unsafe/broken equipment			C	
* 02-c -03	B	Ps-a	Playgrou	M	3500	fence in electric transformer (8')	2	3/29/2014		
02-13-7	B	Ps-a	Playgrou	M	5000	Playground: Repair/Replace Equipment			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/27/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8070 Ann Stork Center - ESE/Whispering Pines  
1790 SW 43 Way  
954.584.9545  
Ft. Lauderdale, FL 33317

Broward Sheriff's Office Dept of Fire  
2601 W. Broward Blvd. #3061  
Fort Lauderdale, FL 33312  
Phone: (954)831-8210 Fax: (954)831-8218

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
02-13-5	B	Ps-a	Playgrou	O	0	remove sharp objects			C	
16-05-01	A	Ps-a	Therapy	O	0	Provide childproof protective recept cover			C	
* 09-b0-01	B	Ps-a	Therapy	O	0	repair ceiling tiles			C	
00-02-88	B	Ps-a	Therapy	M	625	Secure bookcase/cabinet/shelving to wall			C	
* 16-f1-07	B	Ps-b	000	M	250	install gfci within 6 ft water supply			C	
10-b5-a	C	Ps-b	000	M	1000	install railings min 24" on windows			C	
* 15-a5-a3	B	Ps-b	Red	O	0	remove storage < 18" from ceiling			C	
* 10-12-g	C	Ps-b	003	O	0	post exit diagrams in each room			C	
* 16-f1-07	B	Ps-b	Clrms.	M	250	install gfci within 6 ft water supply			C	
* 16-e -2	D	Ps-b	Facp	M	1000	repair fire alarm system			C	
02-l -6	B	Ps-b	Playgrou	M	1500	Playground: Add sand to 12" depth	2	3/29/2014		
02-13-7	B	Ps-b	Playgrou	M	5000	Playground: Repair/Replace Equipment			C	
02-13-5	B	Ps-b	Playgrou	O	0	remove sharp objects			C	
05-00-01	B	Ps-b	Toilets	M	875	Replace glass mirror w/reflective metal mirror			C	



# **Comprehensive Safety Inspection State Requirements for Educational Facilities**

Inspection Date: 2/27/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 8070 Ann Stork Center - ESE/Whispering Pines  
1790 SW 43 Way  
954.584.9545  
Ft. Lauderdale, FL 33317

Broward Sheriff's Office Dept of Fire  
2601 W. Broward Blvd. #3061  
Fort Lauderdale, FL 33312  
Phone: (954)831-8210 Fax: (954)831-8218

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C						

Total Non-Fire Safety Deficiencies.....3

Total Fire Safety Deficiencies (\*).....6

(Includes .....1.Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....9

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

\_\_\_\_\_  
Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

\_\_\_\_\_  
Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8071 ARC Broward Inc. - Whispering Pines Center  
10250 NW 53 Street  
954.746.9547  
Sunrise, FL 33351

Sunrise Fire Rescue  
10440 West Oakland Park Blvd.  
Sunrise, FL 33351  
Phone: (954)746-3470 Fax: (954)572-2223

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Monique Bean 54972  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
10b5a	C	1	000	M	1000	install railings min 24" on windows, storefronts need 1-1/2" safety rail at 24"-36" above the floor		5/29/2014		
* 16-f1-07	B	1	126	M	250	install gfci within 6 ft water supply V: Not SBBC			V	
16-05-01	A	1	133	O	0	Provide childproof protective recept cover V: Not SBBC			V	
00-02-88	B	1	133	M	625	Secure bookcase/cabinet/shelving to wall V: Not SBBC			V	
* S58 C1	B	1	134	M	488	replace exit hardware, latch/padlock on classroom storage door is not permitted		3/30/2014		
* 15a5a3	B	1	134 Storage	O	0	Remove storage <18" from ceiling		3/1/2014		
* 09b001	B	1	134 Storage	O	0	repair ceiling tiles, missing section of ceiling grid		3/30/2014		
* N15.3.2.4	F	1	1.3414e +11	O	0	Remove alcohol-based hand sanitizer >43 oz. per room/area		3/1/2014		
12g10	A	1	1.3414e +11	M	2500	repair cabinets/casework, round off sharp corners on classroom casework and RR changing tables or provide corner guards		5/29/2014		
S5.9.0	B	1	1.3414e +11	O	0	Install impervious ceiling material in toilet room		3/30/2014		
S5.9.1	B	1	1.3414e +11	O	0	Install impervious material, all walls in toilet rooms to a height of 4' above the floor		3/30/2014		
050001	B	1	1.3414e +11	M	875	Replace glass mirror w/reflective metal mirror		4/29/2014		
* 16g 02	F	1	135	O	0	discontinue use of piggybacked surge strips		3/30/2014		
cs0101	A	1	135 & 137	O	0	Remove unsafe/broken Equipment, string/cord for artwork from wall to wall across room		3/30/2014		
S58 C1	B	1	1351371 39	M	488	replace exit hardware, latch/padlock on classroom storage door is not permitted		3/30/2014		
* 09b001	B	1	139 Storage	O	0	repair ceiling tiles, warped ceiling tile		3/30/2014		
* 09-a -5	E	1	164	C	250	check flame spread interior surfaces V: Not SBBC			V	
* 16-f1-07	B	1	165	M	250	install gfci within 6 ft water supply V: Not SBBC			V	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8071 ARC Broward Inc. - Whispering Pines Center  
10250 NW 53 Street  
954.746.9547  
Sunrise, FL 33351

Sunrise Fire Rescue  
10440 West Oakland Park Blvd.  
Sunrise, FL 33351  
Phone: (954)746-3470 Fax: (954)572-2223

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Monique Bean 54972  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							
* 10-h -3	D	1	Clrms.	M	1875	install smoke detector			C	

Total Non-Fire Safety Deficiencies.....7

Total Fire Safety Deficiencies (\*).....6 (Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....13

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year ☐ YES ☐ NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 ☐ YES ☐ NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8090 Atlantic Shores Hospital  
4545 North Federal Highway  
954.771.9547  
Ft. Lauderdale, FL 33308

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 10-g -1	F	1	Backflo w	M	414	inspect fire sprinkler system			C	
* 16-e -2	D	1	Facp	M	1000	repair fire alarm system			C	
* 10-g -1	F	1	Riser	M	414	inspect fire sprinkler system			C	
* 10-12-g	C	1	Rtcboys	O	0	post exit diagrams in each room			C	
02-13-5	B	1	Rtcboys	O	0	remove sharp objects			C	
* 10-a5-1	B	1	Rtcboys	M	438	repair door closure			C	
00-02-88	B	1	Rtcboys	M	625	Secure bookcase/cabinet/shelving to wall			C	
* 10-12-g	C	1	Rtcgirls	O	0	post exit diagrams in each room			C	
00-02-88	B	1	Rtcgirls	M	625	Secure bookcase/cabinet/shelving to wall			C	
* 11a339	B	2	Office	M	156	post fire alarm panel inside sign		4/4/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8090 Atlantic Shores Hospital  
4545 North Federal Highway  
954.771.9547  
Ft. Lauderdale, FL 33308

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C						

Total Non-Fire Safety Deficiencies.....0

Total Fire Safety Deficiencies (\*).....1 (Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....1

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 4/2/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8081 Baby Boomers- Pre-School  
1735 East Atlantic Boulevard  
954.946.9549  
Pompano Beach, FL 33060

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

[x]FireSafety [x]Casualty [x]Sanitation

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

Code Ref:		Location		Type Def	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	M-O-C	Cost					
	B	1	000			Remove electric appliance from room			C	
BCCO 7-5.02(f)(1)	B	1	000			Replace glass mirror with tempered/safety mirror	2			
* NFPA-72	b	1	000			Inspect fire alarm system, inspection is past due				
ANSI A100.1	A	1	000			Remove unsafe/broken Equipment, need blind keepers throughout				
BCCO 7-5.01(k)	B	1	2nd FI Toilet			Install impervious material, on floor, has wood floor, Impervious floor material must wrap up 4" on wall				
BCCO 7-5.01(k)	B	1	2nd FI Toilet			Install impervious material, all walls in toilet rooms to a height of 4' above the floor				
* NFPA-101 7.2.1.3.3	B	1	2nd FI Corridor			repair threshold dropoff >1/2" AFF, at exit to exterior stair, concrete stoop				
* NFPA-70/ BCCO 7-5.01(K)	B	1	2nd FI. Lang. arts			repair light fixture, in storage room, secure to wall				
BCCO 7-5.03(f)	B	1	9699			Playground: Need proper clearance for equip				
BCCO 7-5.03(e)	B	1	9699			Playground: Repair/Replace Equipment, all stationary equipment shall be firmly anchored				
PPSH 3.3.1	B	1	9699			repair fence, at playground has openings greater than 3-1/2 inches and less than 9 inches				
BCCO 7-5.03(f)	B	1	9699			repair unsafe play area, equipment covered with tarp and weighted with bricks				
BCCO 7-5.03(f)	B	1	9699			repair unsafe play area, exposed landscape fabric through mulch is a tripping hazard				
BCCO 7-5.03(e)	B	1	9699			repair unsafe play area, play tunnel with edge on brick pavers				
BCCO 7-5.03(h)/ PPSH 3.7	B	1	9699			repair unsafe play area, tires need proper drainage / mosquito breeding condition				
BCCO 7-5.02(a)/(f)	B	1	Art Room			Secure bookcase/cabinet/shelving to wall				
* NFPA -101 7.10.8.5	C	1	Clsrms.			post exit diagrams in each room	2			
BCCO 7-05.02(a)/(f)	A	1	Kitchen			Remove unsafe/broken Equipment, dish storage shelf tower				



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 8081 Baby Boomers- Pre-School

1735 East Atlantic Boulevard

954.946.9549

Pompano Beach, FL 33060

Inspection Date: 4/2/2014

Pompano Beach Fire Rescue

120 SW 3rd Street

Pompano Beach, FL 33061

Phone: (954)786-4695 Fax: (954)786-4328

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Code Ref:		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							
BCCO 7-5.01(k)	B	1	Kitchen Toilet			Install impervious material, all walls in toilet rooms to a height of 4' above the floor				
BCCO 7-5.01(k)	B	1	Kitchen Toilet			Install impervious material, on floor, has wood floor and base, (dried vomit stain on floor, wall & base), Imp. floor material must wrap up 4" on wall				
* NFPA-101 7.2.1.3.3	B	1	Living Room			repair threshold dropoff >1/2" AFF, at door to exterior				
	B	1	Playgrou			Playground: Repair/Replace Equipment V: undefined equipment			V	
*	B	1	Speech			remove adapters			C	
	C	1	Stair			install railings min 24" on windows V: Not required			V	
	B	1	Stair			Provide signage to read the following: V: no description provided			V	
* NFPA-101 7.2.2.5.3	B	1	Stair			remove storage under stairs--NFPA V: Not required per AHJ			V	
* NFPA-101 7.7.1.1	C	1	Stair 1st Fl.			Repair battery lighting				
*	B	1	Toilet			Remove storage from restroom			C	
	B	1&2	Playgrd			Playground: Repair/Replace Equipment V: undefined equipment			V	
	B	2	000			Replace glass mirror w/reflective metal mirror V: No longer leased by SBBC			V	
*	B	2	001			Remove storage from restroom V: No longer leased by SBBC			V	
	B	2	001			Replace glass with tempered/plexi glass V: No longer leased by SBBC			V	
	C	2	1,2,3,&4			install railings min 24" on windows V: No longer leased by SBBC			V	
	C	2	1,2,3&4			install railings min 24" on windows V: No longer leased by SBBC			V	
*	C	2	002			Repair battery lighting V: No longer leased by SBBC			V	
*	B	2	8088			Repair/Secure Electrical Panel Box V: No longer leased by SBBC			V	
*	B	2	Clrms.			Check threshold dropoff >1/2" AFF V: No longer leased by SBBC			V	



Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

# Comprehensive Safety Inspection State Requirements for Educational Facilities

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8081 Baby Boomers- Pre-School  
1735 East Atlantic Boulevard  
954.946.9549  
Pompano Beach, FL 33060

Inspection Date: 4/2/2014

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Code Ref:		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							
*	C	2	Clrms.			post exit diagrams in each room V: No longer leased by SBBC			V	
*	B	2	Storeroo			remove storage < 18" from ceiling V: No longer leased by SBBC			V	

Total Non-Fire Safety Deficiencies.....15

Total Fire Safety Deficiencies (\*).....6 (Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....21

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

0

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 4/1/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7055 Baudhiun Pre-School  
7600 SW 36 Street  
954.262.9542  
Davie, FL 33314

City of Davie Fire Rescue  
6901 Orange Drive  
Davie, FL 33314  
Phone: (954)797-1229 Fax: (954)797-1234

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Cyrus Cramer 148388  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
*	cs0110	B	1	000	O	0	Remove storage from restroom, various classroom RRs have excessive storage on floor area & various shelves have storage which could fall on children		5/1/2014		
*	16-f1-09	B	1	2117	O	0	remove extension cords			C	
	12g10	A	1	2117	M	2500	repair cabinets/casework, plastic laminate at window bench		6/30/2014		
	12g10	A	1	2119	M	2500	repair cabinets/casework, plastic laminate at window bench		6/30/2014		
*	16-g -02	F	1	2123	O	0	discontinue use of piggybacked surge strips			C	
*	16-f1-09	B	1	2123	O	0	remove extension cords			C	
	02-13-5	B	1	2123	O	0	remove sharp objects V: insufficient information			V	
*	16e44	D	1	2123 Rr	O	0	Clear area around strobe light.		5/1/2014		
	cs0120	B	1	2125	M	2500	Repair unsafe/broken equipment, round off corner on board's marker tray or provide corner guards		5/1/2014		
	000288	B	1	2125	M	625	Secure bookcase/cabinet/shelving to wall		5/1/2014		
	02-13-5	B	1	2128	O	0	remove sharp objects V: insufficiedt information			V	
	12g10	A	1	2128	M	2500	repair cabinets/casework, plastic laminate at window bench		6/30/2014		
*	16f102	B	1	2133	O	0	install electric receptacle cover, loose cover		5/1/2014		
*	16-f1-09	B	1	2133	O	0	remove extension cords	2	5/1/2014		
	cs0120	B	1	2139 Rr	M	2500	Repair unsafe/broken equipment, sharp corner on wall-mounted cabinet		5/1/2014		
*	16-f1-09	B	1	2141	O	0	remove extension cords	2	5/1/2014		
*	cs0110	B	1	2149	O	0	Remove storage from restroom, shower area storage is excessive. Storage on shelving units with wheels is excessive and a falling hazard		5/1/2014		
	01-02-01	B	1	2149	O	0	Strap TV's to mobile cart V: Not found			V	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 4/1/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7055 Baudhiun Pre-School  
7600 SW 36 Street  
954.262.9542  
Davie, FL 33314

City of Davie Fire Rescue  
6901 Orange Drive  
Davie, FL 33314  
Phone: (954)797-1229 Fax: (954)797-1234

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Cyrus Cramer 148388  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type						
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
* 16-f1-02	B	1	2157	O	0	install electric receptacle cover			C	
* 16-a -2	C	1	2169	M	313	repair electric exit sign			C	
cs0120	B	1	8087	M	2500	Repair unsafe/broken equipment, detached pipe/support on canvas cover outside classrooms, by playground		5/1/2014		
* 12g 1	C	1	Corridor	O	0	remove furnishings blocking exit, in front of 2123- corridor used for tutoring is not permitted		6/30/2014		
15b603	B	1	Corridor	M	125	repair water fountain, next to 2172- reinstall louvered wall cover under drinking fountains		7/30/2014		
10-b5-a	C	1	Glassdrs	M	1000	install railings min 24" on windows V: Not required			V	
16f202	B	1	N103	O	0	install light covers, playground RR		5/1/2014		
02-l -10	B	1	Plygrds	O	0	Playground: Need proper clearance for equip V: Not found			V	
* 16-f1-09	B	2	2143	O	0	remove extension cords			C	
05-2D-04	E	2	9599	M	5000	Provide fence separation from water>1 ft deep			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 4/1/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7055 Baudhiun Pre-School  
7600 SW 36 Street  
954.262.9542  
Davie, FL 33314

City of Davie Fire Rescue  
6901 Orange Drive  
Davie, FL 33314  
Phone: (954)797-1229 Fax: (954)797-1234

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Cyrus Cramer 148388  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C						

Total Non-Fire Safety Deficiencies.....9

Total Fire Safety Deficiencies (\*).....7 (Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....16

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year ☐ YES ☐ NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 ☐ YES ☐ NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8078 Broward Children's Center North - Pre-school ESE  
25 SE 20 Ave.  
954.946.9549  
Pompano, FL 33060

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
cs0120	B	1	000	M	2500	Repair unsafe/broken equipment, blind keepers must be properly secured and height requires adjustment. Many not being used		4/4/2014		
13p29	F	1	9699	O	0	clean floor area, within electrical equipment fence/enclosure		6/3/2014		
021 8	B	1	9699	M	500	Playground: Rpr/Rpl Poured-In-Place Rubber Safety Surface, torn areas		4/4/2014		
02c82	B	1	9699	M	1250	repair fence, NW corner of play area, secure bottom rail		4/4/2014		
02131	B	1	9699	M	6250	repair unsafe play area, store bye bye buggies away from electrical panels and enclosing fence		4/4/2014		
* 09c10	B	1	9699	M	488	replace exit hardware, gate exit hardware is not permitted to require special knowledge for operation		4/4/2014		
000288	B	1	Boys Toilet	M	625	Secure bookcase/cabinet/shelving to wall, wire shelf has arm missing on one side and is not secured to wall on the other		4/4/2014		
13a2a6b	B	1	Cafet. Storage	O	0	remove improperly stored chemicals/cleaning supplies, bleach on wire shelf needs spillage containment- (6 gallon bottles)		4/4/2014		
* 16f107	B	1	Cafeteria	M	250	install gfci within 6 ft water supply, at sink		4/4/2014		
12g10	A	1	Cafeteria	M	2500	repair cabinets/casework, repair hinge on door under sink		6/3/2014		
* 09b001	B	1	Cafeteria	O	0	repair ceiling tiles, missing tile		4/4/2014		
* 09a32	E	1	Classrm A	O	0	attach fire rating labels to curtains		4/4/2014		
* 09b001	B	1	Classrm B	O	0	repair ceiling tiles		4/4/2014		
cs0120	B	1	Classrm C	M	2500	Repair unsafe/broken equipment, broken blind		4/4/2014		
cs0101	A	1	Classrm F	O	0	Remove unsafe/broken Equipment, string for artwork		4/4/2014		
* 16f107	B	1	Corr. By Classrm D	M	250	install gfci within 6 ft water supply, replace painted gfci		4/4/2014		
* 000004	A	1	Corridor	C	0	Check Fire Rating, pass-thru window between corridor and office is not rated, rating required		3/5/2014		
* 10c 2	C	1	Corridor	O	0	remove exit obstructions, wheel chairs outside classrooms		4/4/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8078 Broward Children's Center North - Pre-school ESE  
25 SE 20 Ave.  
954.946.9549  
Pompano, FL 33060

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
09c001b	B	1	Corridor	M	2500	repair walls, secure vinyl base at rear door to play area		4/4/2014		
S58 C1	B	1	Director Office	M	488	replace exit hardware, has lock on inside, provide hardware that cannot be locked from the inside		4/4/2014		
10-b5-a	C	1	Glass	M	1000	install railings min 24" on windows	2	6/3/2014		
S5.9.1	B	1	Kitchen	O	0	Install impervious material, all walls to a height of 6' above the floor		4/4/2014		
S5.9.1	B	1	Kitchen	O	0	Install impervious material, VCT floor is not permitted, Vinyl base is not permitted-Impervious floor material must wrap up 4" on wall		4/4/2014		
* 000004	A	1	Program Mgr.	C	0	Check Fire Rating, window at corridor wall requires a fire rating		3/5/2014		
S58 C1	B	1	Program Mgr. Off.	M	488	replace exit hardware, has lock on inside, provide hardware that cannot be locked from the inside		4/4/2014		
* 16-a -1	C	1	S.hallwa	M	625	install directional exit sign			C	
* 16-a -	C	1	Smke Drs	C	625	install illuminated exit sign			C	
* 10-h -3	D	1	Smke Drs	M	1875	install smoke detector	3	4/4/2014		
96-09-4a	B	1	Smke Drs	C	2500	Provide engineering inspection	3	7/3/2014		
S58 C1	B	1	Social Worker Off	M	488	replace exit hardware, has lock on inside, provide hardware that cannot be locked from the inside		4/4/2014		
* 09b001	B	1	Therapy Rm.	O	0	repair ceiling tiles, water damage		4/4/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10

Loc. No. 8078 Broward Children's Center North - Pre-school ESE  
25 SE 20 Ave.  
954.946.9549  
Pompano, FL 33060

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type						
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #

Total Non-Fire Safety Deficiencies.....18

Total Fire Safety Deficiencies (\*).....11

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....29

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year ☐ YES ☐ NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 ☐ YES ☐ NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 1/14/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8079 Broward Childrens Center, South - Pre-school  
3891 Stirling Rd.  
954.584.9545  
Dania Beach, FL 33312

Broward Sheriff's Office Dept of Fire  
2601 W. Broward Blvd. #3061  
Fort Lauderdale, FL 33312  
Phone: (954)831-8210 Fax: (954)831-8218

Victoria Stanford Lic. No. 112821  
Municipal Firesafety Inspector

Mike Rizzo 25778  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
* 12g 1	C		1	000	O	0	remove furnishings blocking exit, all blinds to be above emergency escape sign/window pane.		4/14/2014		
* 13a2a6	B		1	000	O	0	remove improperly stored chemicals, bleach and other cleaning chemicals found throughout. Lock from students.		2/13/2014		
* 16g 02	F		1	102	O	0	discontinue use of piggybacked surge strips		2/13/2014		
* 08c 5	E		1	106	O	0	remove door stops, Door cannot be blocked open.		2/13/2014		
* 12g 1	C		1	109	O	0	remove furnishings blocking exit, Emergency Escape window		4/14/2014		
* 16-c -1	C		1	110	M	375	Repair battery lighting			C	
S5(8)(c)1	B		1	110	M	488	replace exit hardware, privacy lock readily opened from inside and opened from outside without a special tool (key).		2/13/2014		
* 16c 1	C		1	112	M	375	Repair battery lighting		2/13/2014		
S5(8)(c)1	B		1	112	M	488	replace exit hardware, privacy lock readily opened from inside and opened from outside without a special tool (key).		2/13/2014		
* 13a2b1	B		1	113	O	0	label containers, cleaning supplies		2/13/2014		
* 09d 8	F		1	113	O	0	remove carpet pieces<fire spread floor, or provide fire rating (Class 2 or above)		2/13/2014		
* 09d 8	F		1	114	O	0	remove carpet pieces<fire spread floor, or provide fire rating (Class 2 or above)		2/13/2014		
09aa19	B		1	116	M	1250	Replace panel w/tempered glass, Fish tank.		2/13/2014		
09aa19	B		1	117	M	1250	Replace panel w/tempered glass, Fish Tank		2/13/2014		
* 09d 8	F		1	118	O	0	remove carpet pieces<fire spread floor, or provide fire rating (Class 2 or above)		2/13/2014		
* 12g 1	C		1	118	O	0	remove furnishings blocking exit, escape window		4/14/2014		
* 16c 1	C		1	118	M	375	Repair battery lighting, by restroom		2/13/2014		
* 13a2b1	B		1	119	O	0	label containers, cleaning supplies, and properly store.		2/13/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 1/14/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8079 Broward Childrens Center, South - Pre-school  
3891 Stirling Rd.  
954.584.9545  
Dania Beach, FL 33312

Broward Sheriff's Office Dept of Fire  
2601 W. Broward Blvd. #3061  
Fort Lauderdale, FL 33312  
Phone: (954)831-8210 Fax: (954)831-8218

Victoria Stanford Lic. No. 112821  
Municipal Firesafety Inspector

Mike Rizzo 25778  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety    ☒ Casualty    ☒ Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
* 09d 8	F		1	119	O	0	remove carpet pieces<fire spread floor, or provide fire rating (Class 2 or above)		2/13/2014		
* 16f109	B		1	119	O	0	remove extension cords		2/13/2014		
* 10-a5-1	B		1	120	M	438	repair door closure			C	
* 09d 8	F		1	121	O	0	remove carpet pieces<fire spread floor, or provide fire rating (Class 2 or above)		2/13/2014		
* 11a 2	F		1	123	M	125	install bracket for fire extinguisher		2/13/2014		
* 01-01-09	B		1	123	M	125	Provide master keys for key box			C	
13u16a	B		1	8088	M	156	Provide signage to read the following:, Roof Truss Sign-Outside Front of Building per Fire Department location		4/14/2014		
02l 10	B		1	9699	O	0	Playground: Need proper clearance for equip, 6 feet clearance around all equipment. Remove tricycles and any other items within area.		2/13/2014		
05-01-1a	B		1	Clrms.	O	0	Replace glass with tempered/plexi glass			C	
02l 8	B		1	Playgrd	M	500	Playground: Rpr/Rpl Poured-In-Place Rubber Safety Surface, multiple areas in playground		2/13/2014		
13p28	F		1	Playgrd	M	313	repair damaged equipment, wood box near spring play equipment has loose corner.		4/14/2014		
* 16g 02	F		1	Warehs	O	0	discontinue use of piggybacked surge strips		2/13/2014		
* 10c 2	C		1	Warehs	O	0	remove exit obstructions, Move shelving to allow exiting from back.		2/13/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 1/14/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8079 Broward Childrens Center, South - Pre-school  
3891 Stirling Rd.  
954.584.9545  
Dania Beach, FL 33312

Broward Sheriff's Office Dept of Fire  
2601 W. Broward Blvd. #3061  
Fort Lauderdale, FL 33312  
Phone: (954)831-8210 Fax: (954)831-8218

Victoria Stanford Lic. No. 112821  
Municipal Firesafety Inspector

Mike Rizzo 25778  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....8

Total Fire Safety Deficiencies (\*).....19

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....27

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/18/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7101 Broward Educational Foundation  
2300 W. Copans Road, Bay 5  
754.321.7543  
Pompano Beach, FL 33062

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 10g 1	F	1	000	M	414	inspect fire sprinkler system, inspection tags missing on riser and backflow		4/17/2014		
* 11a801	F	1	000	M	38	reinspect fire extinguishers		4/17/2014		
* 10-g -4	F	1	Fdc	M	63	replace caps on F.D. siamese			C	
* 16c	C	1	Store	M	625	install battery lighting, additional req'd. Replace exit sign over main entrance with a combination exit/emergency light		4/17/2014		
* 16f109	B	1	Store	O	0	remove extension cords, at checkout desk		4/17/2014		
* 16c	C	1	Warehse	M	625	install battery lighting, additional req'd		4/17/2014		
* 16a 1	C	1	Warehse	M	625	install directional exit sign, at end of aisle at rear of space, toward exit door		4/17/2014		
* 10-e -2	E	1	Warehse	M	250	seal horizontal openings			C	

Total Non-Fire Safety Deficiencies.....0

Total Fire Safety Deficiencies (\*).....6 (Includes .....0.....Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....6

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year ☐ YES ☐ NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 ☐ YES ☐ NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/27/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8301 Broward Girl's Academy (DJJ) - Whispering Pines  
8301 South Palm Dr. Bldg 1  
Pembroke Pines, FL 33025  
Phone: (954)322-6500

Pembroke Pines Fire Rescue  
9500 Pines Blvd., Bldg B  
Pembroke Pines, FL 33026  
Phone: (954)435-6700 Fax: (954)435-6713

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							
* 10g 1	F	1	000	M	414	inspect fire sprinkler system, Backflow inspection past due		4/26/2014		
09c001b	B	1	000	M	2500	repair walls, patch holes in walls and ceilings in classroom 1, 2 and corridor		4/26/2014		
cs0120	B	1	Classrm 1	M	2500	Repair unsafe/broken equipment, missing data plug cover		4/26/2014		
cs0101	A	1	Classrm 2	O	0	Remove unsafe/broken Equipment, missing data plug cover		4/26/2014		
000167	B	1	Classrm 2	M	6250	Repair broken floor tiles (vinyl)		7/25/2014		

Total Non-Fire Safety Deficiencies.....4

Total Fire Safety Deficiencies (\*).....1

Total Deficiencies Cited .....5

(Includes .....0.....Serious Life Safety Deficiencies\*\*)

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/12/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 6011 Broward Juvenile Detention Ctr - Whiddon  
222 Northwest 22nd Ave  
954.765.9547  
Ft. Lauderdale, FL 33311

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type						
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
* _* _*	*	1	00*	*		*No violations for this building	1813	3/12/2014		*
11h22	B	1	9699	O	0	Provide pad around basketball poles, four(4) poles		4/11/2014		
16-f2-06	B	P	000	O	0	replace burned-out light bulb(s)			C	
* 11a801	F	P	000	M	38	reinspect fire extinguishers, ALL Fire Extinguishers Now Due		4/11/2014		
* 11-a8-01	F	P	136n	M	38	reinspect fire extinguishers V: No such Fish #			V	
* 16-c -1	C	P	136n	M	375	Repair battery lighting V: no such number			V	
00-02-88	B	P	136n	M	625	Secure bookcase/cabinet/shelving to wall V: no such Fish #			V	
01-02-01	B	P	136n	O	0	Strap TV's to mobile cart V: no such FISH #			V	
* 11-a8-01	F	P	180n	M	38	reinspect fire extinguishers			C	
* 16c 1	C	P	180n	M	375	Repair battery lighting		4/11/2014		
* cs-01-05	B	P	180n	M	1250	Repair/Secure Electrical Panel Box			C	
* 16-c -1	C	P	181	M	375	Repair battery lighting			C	
* 11-a8-01	F	P	181n	M	38	reinspect fire extinguishers			C	
* 16c 1	C	P	181n	M	375	Repair battery lighting		4/11/2014		
* 16-f2-05	B	P	299	M	188	install spacer in circuit breakers	2	4/11/2014		
* 11-a8-01	F	P	299	M	38	reinspect fire extinguishers			C	
* 16-c -1	C	P	299	M	375	Repair battery lighting			C	
* 16c 1	C	P	327c	M	375	Repair battery lighting		4/11/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/12/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 6011 Broward Juvenile Detention Ctr - Whiddon  
222 Northwest 22nd Ave  
954.765.9547  
Ft. Lauderdale, FL 33311

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
000167	B	P	327c	M	6250	Repair broken floor tiles (vinyl), thru-out; check Sub-flooring		7/10/2014			
* 08a 01	B	P	327c	M	625	repair door (wood), closing problem		4/11/2014			
* 16f201	B	P	327c	M	250	repair light fixture, Ballast		4/11/2014			
* 11-a8-01	F	P	350ve	M	38	reinspect fire extinguishers			C		
* 16c 1	C	P	350ve	M	375	Repair battery lighting		4/11/2014			
* 09-c0-01	B	P	350ve	M	2500	repair walls	2	4/11/2014			
01-02-01	B	P	350ve	O	0	Strap TV's to mobile cart			C		
* 16c 1	C	P	36n	M	375	Repair battery lighting		4/11/2014			
* 16f201	B	P	36n	M	250	repair light fixture, ballast		4/11/2014			
000288	B	P	36n	M	625	Secure bookcase/cabinet/shelving to wall, five(5) all total		4/11/2014			
* 11-a8-01	F	P	519c	M	38	reinspect fire extinguishers			C		
* 16c 1	C	P	519c	M	375	Repair battery lighting		4/11/2014			
* 08a 01	B	P	519c	M	625	repair door (wood), North door dragging		4/11/2014			
* 16f201	B	P	519c	M	250	repair light fixture, ballast		4/11/2014			
* 11-a8-01	F	Port	000	M	38	reinspect fire extinguishers			C		
* 16-f1-04	B	Port	181n	O	0	install light switch cover			C		
* 16-c -1	C	Port	181n	M	375	Repair battery lighting			C		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/12/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 6011 Broward Juvenile Detention Ctr - Whiddon  
222 Northwest 22nd Ave  
954.765.9547  
Ft. Lauderdale, FL 33311

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C						

Total Non-Fire Safety Deficiencies.....4

Total Fire Safety Deficiencies (\*).....14

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....18

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/27/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 6017 Broward Youth Treatment Center, Whiddon-  
8301 S. Palm Dr. Bldg 2  
954.434.9544  
Pembroke Pines, FL 33325

Pembroke Pines Fire Rescue  
9500 Pines Blvd., Bldg B  
Pembroke Pines, FL 33026  
Phone: (954)435-6700 Fax: (954)435-6713

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 10g 1	F	2	000	M	414	inspect fire sprinkler system, Backflow inspection past due		4/26/2014		
* cs0110	B	2	109 Rr	O	0	Remove storage from restroom		4/26/2014		
cs0120	B	2	109 Rr	M	2500	Repair unsafe/broken equipment, missing shower floor drain cover		4/26/2014		
09c 1	B	2	109 Rr	M	938	rpr/rpl broken ceramic wall tiles, at shower		4/26/2014		
* 12a	F	2	Corridor	O	0	remove combustible materials, delivery of boxes		6/25/2014		
S5.12.e	C	2	Lobby	O	0	remove carpet pieces-tripping hazard, door mat with curled edge		3/28/2014		
* 16 aa 3	B	2	Lobby	M	250	repair illuminated exit sign, at door to exterior, battery		4/26/2014		

Total Non-Fire Safety Deficiencies.....3

Total Fire Safety Deficiencies (\*).....4

(Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....7

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7075 Building Bridges Pre-School  
140 S.E. 28 Avenue  
954.545.9545  
Pompano Beach, FL 3306

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 880102B	b	1	000	O	0	Inspect fire alarm system		3/6/2014		
cs0120	B	1	000	M	2500	Repair unsafe/broken equipment, install blind cord keepers all blinds		4/4/2014		
* 16-g -02	F	1	Vpk	O	0	discontinue use of piggybacked surge strips			C	
* 16-f1-09	B	1	Vpk	O	0	remove extension cords			C	
* 16-c -1	C	1	Vpk	M	375	Repair battery lighting			C	
cs0101	A	1	1 Yr Classrm	O	0	Remove unsafe/broken Equipment, chain for artwork across room		4/4/2014		
* 16-f2-02	B	1	2 Yearol	O	0	install light covers	2	4/4/2014		
* 16-f1-09	B	1	2 Yearol	O	0	remove extension cords			C	
16f202	B	1	2 Yr Classrm	O	0	install light covers, in storage rm.		4/4/2014		
S5.8	E	1	2 Yr Classrm	M	1200	Change of level at doors and thresholds to be 1/2 or less in height., has step at exterior door		5/4/2014		
16f202	B	1	2 Yr Classrm	O	0	install light covers		4/4/2014		
* 09d 8	F	1	2 Yr Classrm	O	0	remove carpet pieces<fire spread floor		4/4/2014		
08a 03	B	1	2 Yr Classrm	M	187	repair/replace threshold, at door to exterior, broken. Replace with threshold less than 1/2 inch in ht.		4/4/2014		
* 15a5a3	B	1	3 Yr Classrm	O	0	Remove storage <18" from ceiling, at storage		3/6/2014		
* 09a001	B	1	3 Yr Classrm	M	3125	repair ceilings, secure loose ceiling tiles		4/4/2014		
S5.9.1	B	1	3 Yr Old Toilet	O	0	Install impervious material, ceramic tile base around sink cabinetc		4/4/2014		
09c001b	B	1	3 Yr Old Toilet	M	2500	repair walls, vinyl wall covering is not permitted in toilet rooms and wall has mold		4/4/2014		
* 16f106	B	1	8088	M	250	install weather proof gfci, outside wall facing playground		4/4/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7075 Building Bridges Pre-School  
140 S.E. 28 Avenue  
954.545.9545  
Pompano Beach, FL 3306

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
13-p2-9	F	1	9599	O	0	clean floor area			C	
02d22	B	1	9599	M	1250	Rpr/Rpl sidewalk (concrete), holes at walk to front door		4/4/2014		
* 202020	A	1	9599	O	0	Secure exterior gates of school campus, front gate not secured to prevent children in 3-yr old classrm from exiting property or provide proper hwr or		3/6/2014		
02-l -6	B	1	9699	M	1500	Playground: Add sand to 12" depth			C	
02-l -10	B	1	9699	O	0	Playground: Need proper clearance for equip			C	
02-c8-1	B	1	9699	M	625	remove unsafe fence			C	
02c82	B	1	9699	M	1250	repair fence, openings bet. pickets must be less than 3 1/2 inches at equipment enclosure and fence at water		4/4/2014		
02l31	B	1	9699	M	6250	repair unsafe play area, secure area with loose pavers, unsecured bench and other building materials from access by children		4/4/2014		
20-20-20	A	1	9699	O	0	Secure exterior gates of school campus	3	3/6/2014		
* 09b001	B	1	Corridor	O	0	repair ceiling tiles, in front of 2 year classroom		4/4/2014		
10-b5-a	C	1	Glass	M	1000	install railings min 24" on windows			C	
09-c -1	B	1	Peach	M	938	rpr/rpl broken ceramic wall tiles			C	
S5.8	E	1	Pk To Play Area	M	1200	Change of level at doors and thresholds to be 1/2 or less in height.		5/4/2014		
* 02-c -03	B	1	Playgrd	M	3500	fence in electric transformer (8')			C	
20-20-20	A	1	Playgrou	O	0	Secure exterior gates of school campus V: Duplicate			V	
* 16-f2-02	B	1	Storage	O	0	install light covers	2	4/4/2014		
* 09-a0-01	B	1	Storage	M	3125	repair ceilings			C	
* cs-01-10	B	1	Toilet	O	0	Remove storage from restroom	2	4/4/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7075 Building Bridges Pre-School  
140 S.E. 28 Avenue  
954.545.9545  
Pompano Beach, FL 3306

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
00-01-67	B	1	Toilet	M	6250	Repair broken floor tiles (vinyl) V: Impervious floor required, new violation issued			V	
* 16-f1-07	B	1	Toilets	M	250	install gfci within 6 ft water supply	2	4/4/2014		
* 16-f2-02	B	1	Toilets	O	0	install light covers			C	
05-00-01	B	1	Toilets	M	875	Replace glass mirror w/reflective metal mirror	2	5/4/2014		

Total Non-Fire Safety Deficiencies.....14

Total Fire Safety Deficiencies (\*).....11

(Includes .....0.....Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....25

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection Audit State Requirements for Educational Facilities

Initial Inspection: Jan 13, 2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754) 321-4200

Fiscal Year: 2013-2014

Broward County School District - Off Campus Site  
Central Area Maintenance (PPO Zone 2) Loc. No: 9393  
1560 NW 34 Terrace  
Lauderhill, FL 33311  
(754) 321-1450

Lauderhill Fire Rescue  
1980 NW 56th Avenue  
Lauderhill, FL 33313  
(954) 730-3058

Kim Luke #112349  
Municipal Firesafety Inspector

[x] Fire Safety [x] Casualty [x] Sanitation

\* Laura Lillie #143078  
Municipal Firesafety Inspector  
(Fire Violations only)

69A-58	Pri	Location		Type Def.	Est. Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Scheduled for Correction Not Later Than	Current Year Status	Work Order #
No. Sub Para.		Bldg No.	Room No.	M-O-C						
13 u1 6a	B	0	9698	M	156	Provide signage to read the following: <i>Emergency Gate</i>		Apr 13, 2014		
* 16 c 1	C	1	000	M	375	Repair battery lighting <i>all battery lightning</i>		Feb 12, 2014		
* 10 c 2	C	1	118	O	0	remove exit obstructions <i>exterior of 118 hallway</i>		Feb 12, 2014		
* 16 c 1	C	1	130	M	375	Repair battery lighting <i>at South Wall over top of Breaker Panels</i>	1	Feb 12, 2014	W	
* 16 f2 05	B	1	130	M	188	install spacer in circuit breakers <i>in bay area</i>		Feb 12, 2014		
* 11 a9 02	F	1	130	M	157	post exterior fire extinguisher sign		Feb 12, 2014		
* 05 15 2	F	1	9599	M		Provide Access to Fire Hydrant <i>at SE grassy area, Fire Hydrant fenced in</i>			C	

Total Non-Fire Safety Deficiencies 1  
Total Fire Safety Deficiencies(\*): 5 (Includes 0 Serious Life Safety Deficiencies\*\*)  
Total Deficiencies Cited: 6

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY:  
Ten Fire Exit Drills during the School Year [ ] Yes [ ] No (NFPA 101)

Signature of Facility Administrator Attesting to Fire Exit Drills  
and Review of Report Acknowledging Awareness of Discovered Deficiencies.

Signature Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance with Section 1013.12(2)(c), F. S.  
Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] Yes [ ] No

Scheduled Re-inspection Date no later than: Jun 20, 2014



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/26/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8095 Citrus Health Network  
8400 South Palm Drive  
954.987.9549  
Pembroke Pines, FL 33025

Pembroke Pines Fire Rescue  
9500 Pines Blvd., Bldg B  
Pembroke Pines, FL 33026  
Phone: (954)435-6700 Fax: (954)435-6713

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Damian Phang 96866  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety    ☒ Casualty    ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 10-g -1	F	1	Backflo w	M	414	inspect fire sprinkler system			C	
* 16-f2-01	B	1	Clstrm.2	M	250	repair light fixture			C	
00-02-88	B	1	Clstrm.2	M	625	Secure bookcase/cabinet/shelving to wall	2	3/28/2014		
* 09-a3-1	E	1	Clstrm.4	O	0	remove drapes < fire spread standard			C	
* 16-f1-09	B	1	Clstrm.4	O	0	remove extension cords			C	
* 10-12-g	C	1	Clstrms.	O	0	post exit diagrams in each room	2	3/28/2014		
* 16-e3-1	D	1	Facp	M	188	post fire alarm tag			C	
* 16-a -21	F	1	Hs&ms	O	0	Repair electric exit sign (bulbs)			C	
* 10-g -1	F	1	Riser	M	414	inspect fire sprinkler system			C	
S58 C1	B	Admin	041	M	488	replace exit hardware, storage cabinets have locks on the inside, provide hardware that cannot be locked from the inside		3/28/2014		
* 11a901	F	Admin	042	O	0	make fire extinguisher accessible		3/28/2014		
* 16e34	D	Admin	042	O	0	make pull station accessible		3/28/2014		
cs0101	A	Admin	042	O	0	Remove unsafe/broken Equipment, round off corners on boards' pen trays or provide corner guards		3/28/2014		
000288	B	Admin	042	M	625	Secure bookcase/cabinet/shelving to wall		3/28/2014		
000288	B	Admin.	041	M	625	Secure bookcase/cabinet/shelving to wall		3/28/2014		
16f202	B	Male Unit	005	O	0	install light covers		3/28/2014		
* 13a2a3	B	Male Unit	005	O	0	remove ignition source, candle, corrected on site			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/26/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8095 Citrus Health Network  
8400 South Palm Drive  
954.987.9549  
Pembroke Pines, FL 33025

Pembroke Pines Fire Rescue  
9500 Pines Blvd., Bldg B  
Pembroke Pines, FL 33026  
Phone: (954)435-6700 Fax: (954)435-6713

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Damian Phang 96866  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....6

Total Fire Safety Deficiencies (\*).....3

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....9

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/26/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8052 College Plaza  
7875 Pines Blvd  
Pembroke Pines, FL 33024  
Phone: (322)322-9039

Pembroke Pines Fire Rescue  
9500 Pines Blvd., Bldg B  
Pembroke Pines, FL 33026  
Phone: (954)435-6700 Fax: (954)435-6713

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Damian Phang 96866  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety    ☒ Casualty    ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							
* 09-a -5	E	1	Classroom	C	250	check flame spread interior surfaces			C	
10-b5-a	C	1	Classroom	M	1000	install railings min 24" on windows V: Not required			V	
09-d -79	E	1	Classroom	M		repair torn carpet	4	2/26/2014		
00-02-88	B	1	Classroom	M	625	Secure bookcase/cabinet/shelving to wall	3	3/28/2014		
* 10L2c	C	1	Classroom	M	157	post capacity sign, Maximum 49		3/28/2014		
* 16c 1	C	1	Classroom	M	375	Repair battery lighting		3/28/2014		
09aa19	B	1	Classroom & Toilet	M	1250	Replace panel w/tempered glass, or plexi-glass, framed posters		3/28/2014		
* 16-f1-09	B	1	Clstrm.	O	0	remove extension cords			C	
S5.15.b.5	E	1	Toilet	O	0	Faculty/staff restrooms-separate from students		2/27/2014		
S5.9.1	B	1	Toilet	O	0	Install impervious material, all walls in toilet rooms to a height of 4' above the floor		3/28/2014		
S5.16.b.6	E	1	Toilet	M	11500	Provide separate restrooms for male and female students > grade 3.		3/28/2014		
05-00-01	B	1	Toilet	M	875	Replace glass mirror w/reflective metal mirror	2	4/27/2014		



Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 8052 College Plaza  
7875 Pines Blvd  
Pembroke Pines, FL 33024  
Phone: (322)322-9039

Pembroke Pines Fire Rescue  
9500 Pines Blvd,, Bldg B  
Pembroke Plnes, FL 33026  
Phone: (954)435-6700 Fax: (954)435-6713

Damian Phang 96866  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety

☒ Casualty

☒ Sanitation

R69A.58		Location		Type	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No.	Para.	Bldg No.	Room No.	Def M-O-C						

Total Non-Fire Safety Deficiencies.....7

Total Fire Safety Deficiencies (\*).....2 (Includes .....0.Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....9

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/25/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7032 Family Success Center - Hallandale Adult (Carver)  
4733 SW 18 Street  
954.985.9549  
West Park, FL 33023

Broward Sheriff's Office Dept of Fire  
2601 W. Broward Blvd. #3061  
Fort Lauderdale, FL 33312  
Phone: (954)831-8210 Fax: (954)831-8218

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Roger Gonzalez 23092  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
cs0131	B	1	000	O	0	Provide Maintenance Log for AED, pads are expired		3/27/2014		
cs-01-20	B	1	Aed	M	2500	Repair unsafe/broken equipment			C	
* 16-g -02	F	1	102	O	0	discontinue use of piggybacked surge strips			C	
* 1012g	C	1	102	O	0	post exit diagrams in each room, exit diagram has the incorrect orientation		3/27/2014		
* 16c 1	C	1	102	M	375	Repair battery lighting, fixture marked with red dot not lighting with power down		3/27/2014		
05-00-01	B	1	102	M	875	Replace glass mirror w/reflective metal mirror V: Mirror not found			V	
01-02-01	B	1	102	O	0	Strap TV's to mobile cart V: TV not found			V	
S5.8	E	1	Corridor	M	1200	Change of level at doors and thresholds to be 1/2 or less in height., exit door to exterior next to 102		4/26/2014		
* 16-a -2	C	1	Exits	M	313	repair electric exit sign			C	
S5.9	B	1	Men's Toilet	O	0	Install impervious ceiling material in toilet room		3/27/2014		
S58 C1	B	1	Men's Toilet	M	488	replace exit hardware, or deactivate locking mechanism on the inside of the toilet room, provide hardware that cannot be locked from the inside		3/27/2014		
* 16-c -1	C	1	Waiting	M	375	Repair battery lighting			C	
S5.9	B	1	Women's Toilet	O	0	Install impervious ceiling material in toilet room		3/27/2014		
S58 C1	B	1	Women's Toilet	M	488	replace exit hardware, or deactivate locking mechanism on the inside of the toilet room, provide hardware that cannot be locked from the inside		3/27/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/25/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10

Loc. No. 7032 Family Success Center - Hallandale Adult (Carver  
4733 SW 18 Street  
954.985.9549  
West Park, FL 33023

Broward Sheriff's Office Dept of Fire  
2601 W. Broward Blvd. #3061  
Fort Lauderdale, FL 33312  
Phone: (954)831-8210 Fax: (954)831-8218

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Roger Gonzalez 23092  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....6

Total Fire Safety Deficiencies (\*).....2

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....8

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year ☐ YES ☐ NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 ☐ YES ☐ NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/31/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10

Loc. No. 8220 First Church of Christ, Scientist (Parking Lot Only)  
1260 SW 55 Terrace  
Plantation, FL 33317

Plantation Fire Rescue  
550 NW 65th Avenue  
Plantation, FL 33317  
Phone: (954)797-2150 Fax: (954)797-2136

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							
*-*-*	*	0	9698	*	0	*No violations for this building				

Total Non-Fire Safety Deficiencies.....0

Total Fire Safety Deficiencies (\*).....0 (Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....0

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

\_\_\_\_\_  
Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

\_\_\_\_\_  
Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7033 Hispanic Unity of Florida, Inc.  
5811 Johnson Street  
954.964.9549  
Hollywood, FL 33021

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type						
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
* 10-12-g	C	1	000	O	0	post exit diagrams in each room			C	
01-02-01	B	1	000	O	0	Strap TV's to mobile cart			C	
* 08c 5	E	1	000	O	0	remove door stops, all doors at corridor		3/30/2014		
* 10-c -2	C	1	100	O	0	remove exit obstructions V: Not SBBC			V	
* 16-f1-09	B	1	100	O	0	remove extension cords V: Not SBBC			V	
* 16-g -02	F	1	101	O	0	discontinue use of piggybacked surge strips V: Not SBBC			V	
* 10c 2	C	1	103	O	0	remove exit obstructions, rolling cabinet		3/30/2014		
000288	B	1	108	M	625	Secure bookcase/cabinet/shelving to wall		3/30/2014		
10-b5-a	C	1	Glassdrs	M	1000	install railings min 24" on windows	2	5/29/2014		
* 12a	F	1	Janitor	O	0	remove combustible materials, clear area to maintain 3' clear around water heater		5/29/2014		
* 09b001	B	1	Janitor	O	0	repair ceiling tiles, replace missing tile		3/30/2014		
15a42	B	1	Janitor	M	313	repair exhaust fan, replace missing exhaust fan cover		3/30/2014		
S5.9.0	B	1	Men's Toilet	O	0	Install impervious ceiling material in toilet room		3/30/2014		
* 13-a2-a3	B	1	Test Rm.	O	0	remove ignition source			C	
S5.9.0	B	1	Women Toilet	O	0	Install impervious ceiling material in toilet room		3/30/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7033 Hispanic Unity of Florida, Inc.  
5811 Johnson Street  
954.964.9549  
Hollywood, FL 33021

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type						
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #

Total Non-Fire Safety Deficiencies.....5

Total Fire Safety Deficiencies (\*).....4

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....9

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7028 Off Campus McNicol - South Broward Community  
1405 South 28 Ave.  
954.921.9549  
Hollywood, FL 33022

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
01-02-01	B	1	000	O	0	Strap TV's to mobile cart	3	3/30/2014		
* 12a	F	1	000	O	0	remove combustible materials, improperly stored chemicals on site		5/29/2014		
09c001b	B	1	002/ Corridor	M	2500	repair walls, water intrusion at exterior door		3/30/2014		
* 16c 1	C	1	002/ Passage	M	375	Repair battery lighting		3/30/2014		
* 16f107	B	1	100/ Corridor	M	250	install gfci within 6 ft water supply, at water fountain, next to 108 and 109		3/30/2014		
* 16f201	B	1	100/ Corridor	M	250	repair light fixture, ballast at corridor next to closet 004		3/30/2014		
09c001b	B	1	100/ Corridor	M	2500	repair walls, water damage, next to 104		3/30/2014		
* 16c 1	C	1	101b/ Lobby	M	375	Repair battery lighting		3/30/2014		
* 16-c -1	C	1	102	M	375	Repair battery lighting			C	
010201	B	1	102	O	0	Strap TV's to mobile cart		3/30/2014		
* 1605c	A	1	103	O	0	remove unsafe electric heaters, corrected on site			C	
* 16-f1-09	B	1	104	O	0	remove extension cords	3	3/30/2014		
* 16-f1-15	B	1	104	O	0	remove unsafe electric equipment	4	3/30/2014		
* 16f115	B	1	104	O	0	remove unsafe electric equipment, toaster oven (duplicate violation for clarification of outstanding uncorrected violation)		3/30/2014		
* 16c 1	C	1	104	M	375	Repair battery lighting		3/30/2014		
* 12a	F	1	105	O	0	remove combustible materials, box of sterno, corrected on site			C	
* 16-f1-09	B	1	105	O	0	remove extension cords			C	
* 15a5a3	B	1	105	O	0	Remove storage <18" from ceiling		3/1/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7028 Off Campus McNicol - South Broward Community  
1405 South 28 Ave.  
954.921.9549  
Hollywood, FL 33022

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety    ☒ Casualty    ☒ Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
* 09b001	B		1	105	O	0	repair ceiling tiles, broken tile		3/30/2014		
* 09a001	B		1	105	M	3125	repair ceilings, hole in A/C closet		3/30/2014		
* 09c001	B		1	105	M	2500	repair walls, hole in A/C closet		3/30/2014		
cs0120	B		1	108	M	2500	Repair unsafe/broken equipment, clogged lavatory		3/30/2014		
* 16f109	B		1	110	O	0	remove extension cords		3/30/2014		
* 12a	F		1	112	O	0	remove combustible materials, gas-powered blower, corrected on site			C	
* 09a32	E		1	113	O	0	attach fire rating labels to curtains		3/30/2014		
* 1605c	A		1	113	O	0	remove unsafe electric heaters		3/30/2014		
* 09a32	E		1	117	O	0	attach fire rating labels to curtains		3/30/2014		
cs0120	B		1	118	M	2500	Repair unsafe/broken equipment, a/c thermostat		3/30/2014		
* 16f107	B		1	119	M	250	install gfci within 6 ft water supply, at water fountain next to men's toilet		3/30/2014		
* 08c 5	E		1	119	O	0	remove door stops, at door to corridor		3/30/2014		
* 10-L2-c	C		1	122	M	157	post capacity sign	3	3/30/2014		
* 16f109	B		1	122	O	0	remove extension cords		3/30/2014		
00-02-88	B		1	123	M	625	Secure bookcase/cabinet/shelving to wall	3	3/30/2014		
* 09b001	B		1	125	O	0	repair ceiling tiles, warped tile		3/30/2014		
09c 1	B		1	125	M	938	rpr/rpl broken ceramic wall tiles, under lavatory		3/30/2014		
* 16f109	B		1	126	O	0	remove extension cords		3/30/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7028 Off Campus McNicol - South Broward Community  
1405 South 28 Ave.  
954.921.9549  
Hollywood, FL 33022

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 15-a5-a3	B	1	126	O	0	remove storage < 18" from ceiling	3	3/30/2014		
09c001b	B	1	126	M	2500	repair walls, water intrusion at wall by exit door		3/30/2014		
09c001b	B	1	127	M	2500	repair walls, water damage at rear door		3/30/2014		
* 12a	F	1	127a	O	0	remove combustible materials, goof off and detatured alcohol, corrected on site		5/29/2014		
* 15a5a3	B	1	127a	O	0	Remove storage <18" from ceiling		3/1/2014		
* 15a5a3	B	1	128	O	0	Remove storage <18" from ceiling		3/1/2014		
16-g0-3	B	1	129	O	0	Remove electric appliance from room			C	
16f202	B	1	129a	O	0	install light covers		3/30/2014		
cs0120	B	1	129a	M	2500	Repair unsafe/broken equipment, A/C thermostat		3/30/2014		
* 16-f1-09	B	1	129b	O	0	remove extension cords			C	
* 15a5a3	B	1	129b	O	0	Remove storage <18" from ceiling		3/1/2014		
* 08c 2	B	1	133	O	0	remove lock/latch from exit door		3/30/2014		
* 08a 02	B	1	133	M	438	repair door (metal), rusted electrical room door		3/30/2014		
cs0120	B	1	133	M	2500	Repair unsafe/broken equipment, electrical panel surge protector LEDs not lit		3/30/2014		
* 16f102	B	1	203	O	0	install electric receptacle cover, replace broken cover next to door to playground		3/30/2014		
09c001b	B	1	203	M	2500	repair walls, water intrusion at window		3/30/2014		
02d22	B	1	203	M	1250	Rpr/Rpl sidewalk (concrete), crack at exterior door threshold		3/30/2014		
cs0120	B	1	203a	M	2500	Repair unsafe/broken equipment, A/C thermostat		3/30/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7028 Off Campus McNicol - South Broward Community  
1405 South 28 Ave.  
954.921.9549  
Hollywood, FL 33022

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
S5.9.1	B		1	203b	O	0	Install impervious material, ., Vinyl base is not permitted-Impervious floor material must wrap up 4" on wall		3/30/2014		
S5.9.1	B		1	203b	O	0	Install impervious material, ceiling		3/30/2014		
S5.9.1	B		1	203b	O	0	Install impervious material, VCT is not permitted in food prep area/kitchen		3/30/2014		
16f202	B		1	203c	O	0	install light covers		3/30/2014		
* 09b001	B		1	203c	O	0	repair ceiling tiles, warped tile		3/30/2014		
S5.9.0	B		1	203e	O	0	Install impervious ceiling material in toilet room		3/30/2014		
* 1012g	C		1	203e	O	0	post exit diagrams in each room, empty frame by door		3/30/2014		
09c001b	B		1	203e	M	2500	repair walls, water damage behind ceramic tile next to lavatory and tile has detached		3/30/2014		
S5.9.0	B		1	203f	O	0	Install impervious ceiling material in toilet room		3/30/2014		
* 16f2e	B		1	203f	O	0	Lock utility panel., wall clean-out		3/30/2014		
cs0120	B		1	203f	M	2500	Repair unsafe/broken equipment, toilet tank valve doesnt close when flushed		3/30/2014		
* 09a001	B		1	8088	M	3125	repair ceilings, exterior soffit near playground has rusted framing		3/30/2014		
* 09a001	B		1	8088	M	3125	repair ceilings, exterior soffit outside of corridor 002, delaminated stucco and cracks		3/30/2014		
* 08c 2	B		1	9599	O	0	remove lock/latch from exit door, at the two fence gates to playing field between the two buildings		3/30/2014		
* 08c302	C		1	9599	M	500	repair panic hardware, at two fence gates to playing field between the two buildings		3/30/2014		
cs0120	B		1	9599	M	2500	Repair unsafe/broken equipment, garbage receptacle inside site drain at grass area between bldg 2 and middle school		3/30/2014		
02d22	B		1	9698	M	1250	Rpr/Rpl sidewalk (concrete), at front of building at parking area, broken and cracked		3/30/2014		
02c82	B		1	9699	M	1250	repair fence, at tennis court by parking area, fabric not tied to post at SW corner		3/30/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 7028 Off Campus McNicol - South Broward Community  
1405 South 28 Ave.  
954.921.9549  
Hollywood, FL 33022

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
	00-02-88	B	1	Adult-ed	M	625	Secure bookcase/cabinet/shelving to wall	4	3/30/2014		
*	01-01-09	B	1	Main Ele	M	125	Provide master keys for key box	3	3/30/2014		
	cs-01-31	B	1	Receptio	O	0	Provide Maintenance Log for AED			C	
*	16-f1-09	B	1	Receptio	O	0	remove extension cords			C	
	13-p2-8	F	1	Toilet	M	313	repair damaged equipment V: Insufficient info			V	
	96094a	B	1 & 2	000	C	2500	Provide engineering inspection, evidence of water intrusion throughout, including stucco issues		6/28/2014		
*	10-L2-c	C	2	202	M	157	post capacity sign	2	3/30/2014		
*	100h3	D	2	202	M	800	Repair smoke/heat detector, dirty head trouble signal on FACP-WO# j639291		3/30/2014		
	cs-01-31	B	2	202a	O	0	Provide Maintenance Log for AED			C	
*	16-f1-09	B	2	202a	O	0	remove extension cords			C	
*	S5.9.1	B	2	203b	O	0	Install impervious material, to 6' above the floor in food prep/kitchen area		3/30/2014		
	16-g0-3	B	2	203b	O	0	Remove electric appliance from room			C	
	64e 1	E	2	8088	O	0	Clean Area, south wall mechanical vent with missing grill has evidence of pigeons nesting, clean where evident & possibly in ducts		3/5/2014		
	100000	B	2	8088	O	0	Provide Pest Control, south wall in by tennis courts, pigeons in mechanical vent/ducts		3/5/2014		
*	16f201	B	2	8088	M	250	repair light fixture, by playground, broken, on exterior wall		3/30/2014		
	15a43	B	2	8088	M	312	replace missing grill for exhaust fan, exterior south wall by tennis courts is missing, pigeons nesting		3/30/2014		
*	09b001	B	2	Janitor	O	0	repair ceiling tiles, missing grid section at tile ceiling		3/30/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 2/28/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10

Loc. No. 7028 Off Campus McNicol - South Broward Community  
1405 South 28 Ave.  
954.921.9549  
Hollywood, FL 33022

Hollywood Fire Rescue  
2741 Stirling Road  
Hollywood, FL 33021  
Phone: (954)967-4404 Fax: (954)967-4585

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....32

Total Fire Safety Deficiencies (\*).....44

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....76

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 6091 PACE Broward - Whiddon Rogers  
2225 N. Andrews Avenue  
954.561.9545  
Ft. Lauderdale, FL 33311

Wilton Manors Fire Rescue  
524 NE 21st. Court  
Wilton Manors, FL 33305  
Phone: (954)390-2110 Fax: (954)390-2199

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety    ☒ Casualty    ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 08-c -5	E	1	000	O	0	remove door stops			C	
* 16-f1-09	B	1	104	O	0	remove extension cords			C	
* 16-c -1	C	1	106	M	375	Repair battery lighting			C	
16-g0-3	B	1	107	O	0	Remove electric appliance from room			C	
* 16-f1-09	B	1	107	O	0	remove extension cords			C	
* 16-g -02	F	1	109	O	0	discontinue use of piggybacked surge strips			C	
01-01-01	A	1	111	O	0	Remove plug in air fresheners			C	
* 16-g -02	F	1	115	O	0	discontinue use of piggybacked surge strips			C	
* 12-a -	F	1	116	O	0	remove combustible materials			C	
10-b5-a	C	1	126	M	1000	install railings min 24" on windows	2	6/3/2014		
* 16-c -1	C	1	143	M	375	Repair battery lighting			C	
* 15-a -5	B	1	2ndflr.	O	0	remove storage from mechanical rooms			C	
* 16-f1-09	B	1	Clrms.	O	0	remove extension cords			C	
* 16-f1-15	B	1	Clrms.	O	0	remove unsafe electric equipment			C	
* 10-a6-1	B	1	Corridor	M	438	Install Door Closure	2	4/4/2014		
10-b5-a	C	1	Glass	M	1000	install railings min 24" on windows	2	6/3/2014		
* 16-c -1	C	1	Mechani c	M	375	Repair battery lighting			C	
* 16-c -1	C	1	Toilet	M	375	Repair battery lighting			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 6091 PACE Broward - Whiddon Rogers  
2225 N. Andrews Avenue  
954.561.9545  
Ft. Lauderdale, FL 33311

Wilton Manors Fire Rescue  
524 NE 21st. Court  
Wilton Manors, FL 33305  
Phone: (954)390-2110 Fax: (954)390-2199

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 16-c -1	C	2	164	M	375	Repair battery lighting			C	
* 16-c -1	C	2	169	M	375	Repair battery lighting			C	
* 10g 1	F	2	8088	M	414	inspect fire sprinkler system, punch date on riser at E.ext. wall		4/4/2014		

Total Non-Fire Safety Deficiencies.....2

Total Fire Safety Deficiencies (\*).....2 (Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....4

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection Audit State Requirements for Educational Facilities

Initial Inspection: Jul 31, 2013

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754) 321-4200

Fiscal Year: 2013-2014

Broward County School District - Off Campus Site  
Pompano Preschool/ Amanda's Place - Dave Thomas Ed. Center Loc. No: 0186  
1401 NE 4 St  
Pompano Beach, FL, FL 33060  
(754) 322-9911

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
(954) 786-4695

Donna Luzadder #157416  
Municipal Firesafety Inspector

[x] Fire Safety [x] Casualty [x] Sanitation

\* Not Present  
Municipal Firesafety Inspector  
(Fire Violations only)

69A-58	Pri	Location		Type Def.	Est. Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Scheduled for Correction Not Later Than	Current Year Status	Work Order #
No. Sub Para.		Bldg No.	Room No.	M-O-C						
09 c0 03	C	0	8088	M	1,250	repair masonry wall (exterior) <i>Covered area westside of building</i>		Aug 30, 2013		
10 10 10	B	0	9599	M	1,000	Remove unused equipment <i>Rebar sticking up out of the ground</i>		Aug 30, 2013		
** 2 a 5	F	1	000	M	7,500	LSC: Provide protected corridors/stairs <i>Corr.not 1/2 hr.rated transfr.grilles in walls.</i>	3	Jul 31, 2013		
* 08 b 2	E	1	000	M	3,750	install rated fire doors <i>Corr.drs.not 20 minute rated or 1-3/4"SBWC.</i>	3	Jan 27, 2014		
* 08 c 5	E	1	000	O	0	remove door stops <i>Remove all door stops from corridor walls.</i>	3	Aug 30, 2013		
* 08 c 5	E	1	212	O	0	remove door stops <i>Corridor door propped open.</i>	3	Aug 30, 2013		
* 10 a6 1	B	1	216	M		Install Door Closure			C	
* 08 b 2	E	1	216	M	3,750	install rated fire doors <i>Dutch dr.not appr.install1-3/4"SBWCor20min.dr.</i>	2	Jan 27, 2014		
* 08 c 5	E	1	218	O	0	remove door stops	2	Aug 30, 2013		
* 10 a6 1	B	1	220	M		Install Door Closure			C	
* 08 c 5	E	1	221	O		remove door stops <i>Corridor door.</i>			C	
* 08 c 5	E	1	222	O	0	remove door stops	2	Aug 30, 2013		
* 16 f1 09	B	1	223	O		remove extension cords			C	
* 16 f1 09	B	1	224	O		remove extension cords			C	
* 16 c 1	C	1	226	M		Repair battery lighting <i>Emerg.Lgt.out in corridor by #226.</i>			C	
* 08 92 2	C	1	226	M	1,062	Repair emergency escape window <i>Emerg.esc.wind. warped&amp;difficult to open&amp;close.</i>	1	Sep 29, 2013		
* 16 e 2	D	1	FACP	M	1,000	repair fire alarm system <i>Repair def.stated in Annual FA Syst.Insp.Rpt.</i>	1	Aug 30, 2013		
16 05 01	A	1	CLSRMS.	O		Provide childproof protective recept cover <i>Use plastic inserts in all open elec.receptacles</i>			C	
* 10 a5 1	B	1	211&213	M	438	repair door closer <i>Repair doors to close&amp;latch properly.</i>	1	Aug 30, 2013		
10 b5 a	C	1	CORRIDOR	M	1,000	install railings min 24" on windows <i>Nd.chair rail1-1/2",24"-36"aff ctrl.@trophy case</i>	2	Oct 29, 2013		
* 09 b0 01	B	12	004	O	0	repair ceiling tiles <i>west doors</i>		Aug 30, 2013		
* 10 a5 1	B	12	004	M	438	repair door closer <i>both ends of hall not latching /slamming shut</i>		Aug 30, 2013		
* 08 92 2	C	12	1217	M	1,062	Repair emergency escape window <i>Window nor opening</i>		Sep 29, 2013		
80 12 08	B	12	1218	M	6,250	Repair broken floor tiles (ceramic) <i>holes</i>		Nov 28, 2013		
80 12 08	B	12	1222	M	6,250	Repair broken floor tiles (ceramic) <i>cracked and missing</i>		Nov 28, 2013		
09 c 1	B	12	1222	M	938	rpr/rpl broken ceramic wall tiles <i>missing</i>		Aug 30, 2013		



# Comprehensive Safety Inspection Audit State Requirements for Educational Facilities

Initial Inspection: Jul 31, 2013

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754) 321-4200

Fiscal Year: 2013-2014

Broward County School District - Off Campus Site  
Pompano Preschool/ Amanda's Place - Dave Thomas Ed. Center Loc. No: 0186  
1401 NE 4 St  
Pompano Beach, FL, FL 33060  
(754) 322-9911

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
(954) 786-4695

☒ Fire Safety    ☒ Casualty    ☒ Sanitation

69A-58	Pri	Location		Type Def.	Est. Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Scheduled for Correction Not Later Than	Current Year Status	Work Order #
No. Sub Para.		Bldg No.	Room No.	M-O-C						

Total Non-Fire Safety Deficiencies 6

Total Fire Safety Deficiencies(\*): 13 (Includes 1 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited: 19

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY:

Ten Fire Exit Drills during the School Year ☐ Yes ☐ No (NFPA 101)

\_\_\_\_\_  
Signature of Facility Administrator attesting to fire exit drills and  
review of Re-inspection report acknowledging awareness of corrected and  
newly discovered deficiencies.

\_\_\_\_\_  
Signature Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance with Section 1013.12(2)(c), F. S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 ☐ Yes ☐ No

Scheduled Re-inspection Date no later than: Jun 20, 2014



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 1/7/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 6061 Pompano Substance Abuse Treatment Ctr-  
3090 N. Powerline Road

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Pompano Beach, FL 33069

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
100000	B	P	8088	O	0	Provide Pest Control, Remove all wasps nests around portables.		1/12/2014		
02a 4	B	P	8088	O	0	remove hazardous plants, Tree/plant growing up between rails in front of portable QP23N.		2/6/2014		
* S5.(2)(f)7e	A	P	9599	M	1000	Provide barrier @ drop greater than 18"., secure railing section at end of elevated portable platform between portables QP184NSub and QP183N.		1/12/2014		
* 16f101	B	P	Qp183n	M	63	install junction box cover, missing cover at data box		2/6/2014		
* 02a 01	B	P	Qp183n	O	0	post inspection report in portable		2/6/2014		
cs0120	B	P	Qp183n	M	2500	Repair unsafe/broken equipment, sharp corner on pen tray at board		2/6/2014		
cs0120	B	P	Qp183n	M	2500	Repair unsafe/broken equipment, Window handle and base loose.		2/6/2014		
09c001b	B	P	Qp183n	M	2500	repair walls, repair rotted wood at window sill		2/6/2014		
* 02b 1d2	B	P	Qp183n	M	156	Replace faded signs, Fire Alarm Pull Station Inside and Fire Extinguisher Inside		2/6/2014		
* 16f101	B	P	Qp184ns ub	M	63	install junction box cover, missing cover at data box		2/6/2014		
* 02a 01	B	P	Qp184ns ub	O	0	post inspection report in portable		2/6/2014		
16f206	B	P	Qp184ns ub	O	0	replace burned-out light bulb(s)		2/6/2014		
02b 1d	B	P	Qp184ns ub	M	157	Replace signs, Fire Alarm Pull Station Inside and Fire Extinguisher Inside		2/6/2014		
* 08a 01	B	P	Qp23n	M	625	repair door (wood), door sticks- difficult to open		2/6/2014		
* 10c9cb	B	P	Qp23n	M	625	repair ramp, handrail extension is required on both sides of ramp bottom landing-extend on one side		2/6/2014		
cs0120	B	P	Qp23n	M	2500	Repair unsafe/broken equipment, repair windows that do not close tightly		2/6/2014		
cs0120	B	P	Qp23n	M	2500	Repair unsafe/broken equipment, repair/remove broken, unused junction box at exterior of portable		2/6/2014		
cs0120	B	P	Qp23n	M	2500	Repair unsafe/broken equipment, secure downspout at ramp		2/6/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 1/7/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 6061 Pompano Substance Abuse Treatment Ctr-  
3090 N. Powerline Road

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Pompano Beach, FL 33069

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
	cs0120	B	P	Qp23n	M	2500	Repair unsafe/broken equipment, sharp corners on pen tray at board		2/6/2014		
*	09c10	B	P	Qp23n	M	488	replace exit hardware, or repair - broken door handle		2/6/2014		
*	02b 1d2	B	P	Qp23n	M	156	Replace faded signs, Fire Alarm Pull Station Inside and Fire Extinguisher Inside		2/6/2014		
*	16f107	B	P	Qp35n	M	250	install gfci within 6 ft water supply, at receptacles by drinking water dispenser		2/6/2014		
*	02a 01	B	P	Qp35n	O	0	post inspection report in portable		2/6/2014		
*	08a 01	B	P	Qp35n	M	625	repair door (wood), door does not open-sticks		2/6/2014		
*	10c9cb	B	P	Qp35n	M	625	repair ramp, handrail extension is required on both sides of ramp bottom landing-extend on one side		2/6/2014		
	cs0120	B	P	Qp35n	M	2500	Repair unsafe/broken equipment, repair/remove broken, unused junction box at exterior of portable		2/6/2014		
	cs0120	B	P	Qp35n	M	2500	Repair unsafe/broken equipment, replace damaged downspout at stair canopy		2/6/2014		
	cs0120	B	P	Qp35n	M	2500	Repair unsafe/broken equipment, sharp corners on pen tray at board		2/6/2014		
*	02b 1d2	B	P	Qp35n	M	156	Replace faded signs, Fire Alarm Pull Station inside and Fire Extinguisher Inside.		2/6/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 1/7/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 6061 Pompano Substance Abuse Treatment Ctr-  
3090 N. Powerline Road

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Pompano Beach, FL 33069

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type						
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #

Total Non-Fire Safety Deficiencies.....14

Total Fire Safety Deficiencies (\*).....15

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....29

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10

Loc. No. 7102 Pre-School Edu Svcs-Broward Children's Center,  
200 SE 19th Avenue  
954.943.9549  
Pompano Beach, FL 33060

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
	10-b5-a	C	1	010	M	1000	install railings min 24" on windows			C	
*	10a61b	B	1	010	M	438	Repair Door Closure, missing where previously installed		4/4/2014		
*	09a001	B	1	8088	M	3125	repair ceilings, main entrance exterior entrance soffit and fascia		4/4/2014		
*	880102B	b	1	9699	O	0	Inspect fire alarm system		3/6/2014		
	02l 8	B	1	9699	M	500	Playground: Rpr/Rpl Poured-In-Place Rubber Safety Surface, excessive gaps at patches are a tripping hazard		4/4/2014		
	02c82	B	1	9699	M	1250	repair fence, ht. minimum 4', max. picket spacing 3 1/2 inches at play area		4/4/2014		
*	16f111	B	1	Entrance	M	625	repair exposed wiring, missing light fixture at exterior in front of doors		4/4/2014		
	02-c8-2	B	1	Playgrd	M	1250	repair fence	2	4/4/2014		
	02-l3-7	B	1	Playgrou	M	5000	Playground: Repair/Replace Equipment V: Description not provided			V	
	13-u1-6a	B	1	Playgrou	M	156	Provide signage to read the following: V: Description not provided			V	
	02-c8-2	B	1	Plygrd	M	1250	repair fence	2	4/4/2014		
*	10-g -1	F	1	Riser	M	414	inspect fire sprinkler system			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/5/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10

Loc. No. 7102 Pre-School Edu Svcs-Broward Children's Center,  
200 SE 19th Avenue  
954.943.9549  
Pompano Beach, FL 33060

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C						

Total Non-Fire Safety Deficiencies.....4

Total Fire Safety Deficiencies (\*).....4 (Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....8

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 4/2/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8230 Pre-School Edu Svcs-Broward Children's Center,  
114 SE 20 AVENUE  
POMPANO BEACH, FL 33060  
Phone: (954)943-7336

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
02I31	B		1	9699	M	6250	repair unsafe play area, tree roots under safety surface are a tripping hazard and rubber is tearing		5/2/2014		
09b001	B		1	Classroom	O	0	repair ceiling tiles, tiles with water damage		5/2/2014		
09b001	B		1	Corridor	O	0	repair ceiling tiles, tile with water damage		5/2/2014		
* 10-a6-1	B		1	Ppec	M	438	Install Door Closure			C	
* 16-f1-07	B		1	Ppec	M	250	install gfci within 6 ft water supply	2	5/2/2014		
02-I3-7	B		1	Ppec	M	5000	Playground: Repair/Replace Equipment			C	
* 16-e3-1	D		1	Ppec	M	188	post fire alarm tag			C	
* 13u16a	B		1	Ppec	M	156	Provide signage to read the following:, at both sides of door to corridor, "keep door closed"		7/1/2014		
* 16-a -21	F		1	Ppec	O	0	Repair electric exit sign (bulbs)			C	
* 16-e -2	D		1	Ppec	M	1000	repair fire alarm system			C	



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 4/2/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8230 Pre-School Edu Svcs-Broward Children's Center,  
114 SE 20 AVENUE  
POMPANO BEACH, FL 33060  
Phone: (954)943-7336

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							

Total Non-Fire Safety Deficiencies.....3

Total Fire Safety Deficiencies (\*).....2 (Includes .....0.Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....5

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/4/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8049 Tamarac OCLC  
6201 NW 57 Street  
954.683.9546  
Tamarac, FL, FL 33319

Tamarac Fire Rescue  
6000 Hiatus Road  
Tamarac, FL 33321  
Phone: (954)597-3800 Fax: (954)597-3800

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

[X] FireSafety [x]Casualty [x]Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
13-u1-6a	B	1	9698	M	156	Provide signage to read the following:			C	
08-aa-04	B	1	Classroom	C		Check threshold dropoff >1/2" AFF	3	3/4/2014		
* 10-g -1	F	1	Classroom	M	414	inspect fire sprinkler system	2	4/3/2014		
* 11-a8-01	F	1	Classroom	M	38	reinspect fire extinguishers			C	
* 16-c -1	C	1	Classroom	M	375	Repair battery lighting			C	
* 16-a -2	C	1	Classroom	M	313	repair electric exit sign			C	
* 11a801	F	1	Classroom m	M	38	reinspect fire extinguishers, pass due as of 3/01/2014(All)		4/3/2014		
* 08a 04	B	1	Classroom m	M	450	repair threshold dropoff >1/2" AFF, at SE Exit Door		7/2/2014		
10-b5-a	C	1	Lobby	M	1000	install railings min 24" on windows	3	6/2/2014		
* 10-L2-c	C	1	Lobby	M	157	post capacity sign			C	
* 16-f1-02	B	1	O/s Wall	O	0	install electric receptacle cover			C	
* 16-f1-09	B	1	Stage	O	0	remove extension cords			C	
* 16-f1-07	B	1	Toilets	M	250	install gfci within 6 ft water supply	3	4/3/2014		
05-00-01	B	1	Toilets	M	875	Replace glass mirror w/reflective metal mirror	3	5/3/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/4/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8049 Tamarac OCLC  
6201 NW 57 Street  
954.683.9546  
Tamarac, FL, FL 33319

Tamarac Fire Rescue  
6000 Hiatus Road  
Tamarac, FL 33321  
Phone: (954)597-3800 Fax: (954)597-3800

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C						

Total Non-Fire Safety Deficiencies.....3

Total Fire Safety Deficiencies (\*).....4 (Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....7

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;  
Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/26/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 8240 THE SHEPARD'S WAY - PARKING LOT ONLY

1100 N. ANDREWS AVENUE

Fort Lauderdale, FL

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.							
02d53	B	1	9698	M	313	repair holes in asphalt driveway, SE EXIT FROM DRIVEWAY		4/25/2014		

Total Non-Fire Safety Deficiencies.....1

Total Fire Safety Deficiencies (\*).....0 (Includes 0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....1

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/10/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 8072 United Cerebral Palsy Center - Whispering  
3150 SW 13 Ct.  
954.584.9545  
Ft. Lauderdale, FL 33312

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety      ☒ Casualty      ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 16-f1-09	B	1	005	O	0	remove extension cords			C	
cs-01-01	A	1	9699	O	0	Remove unsafe/broken Equipment			C	
* 16-g -02	F	1	Confere n	O	0	discontinue use of piggybacked surge strips			C	
16-g0-3	B	1	Confere n	O	0	Remove electric appliance from room			C	
02-l -6	B	1	Playgrd	M	1500	Playground: Add sand to 12" depth			C	
02-l -10	B	1	Playgrd	O	0	Playground: Need proper clearance for equip			C	
02-l3-7	B	1	Playgrd	M	5000	Playground: Repair/Replace Equipment			C	
02-l3-7	B	1	Playgrou	M	5000	Playground: Repair/Replace Equipment			C	

Total Non-Fire Safety Deficiencies.....0

Total Fire Safety Deficiencies (\*).....0

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....0

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/10/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8174 United Cerebral Palsy Day Training Program  
1331 SW 31 Avenue-BCPS Comp.Clsm.  
954.584.9545  
Fort Lauderdale, FL 33312

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety    ☒ Casualty    ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 08-g2-1	C	1	Comp. rm.	C	3750	install emergency escape window			C	
* 10-12-g	C	1	Comp. rm.	O	0	post exit diagrams in each room			C	
* 16-f1-09	B	1	Comp. rm.	O	0	remove extension cords			C	
* 00-00-02	A	1	Comp. rm.	O	0	Remove Knockout/Exit Direction			C	
* 08-c -1	C	1	Comp. rm.	M	438	remove/replace key deadbolts			C	
* 16-e -2	D	1	Facp	M	1000	repair fire alarm system			C	

Total Non-Fire Safety Deficiencies.....0

Total Fire Safety Deficiencies (\*).....0

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....0

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/4/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8033 Word of Living God Ministry - Pompano OCLC  
149 NW 26 Ave.  
954.917.9549  
Pompano Beach, FL 33069

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58	Sub No. Para.	Pri	Location		Type Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
*	16f107	B	1	Classrm	M	250	install gfci within 6 ft water supply, at water dispenser		4/3/2014		
*	16-c -1	C	1	Classrm	M	375	Repair battery lighting			C	
*	11-a8-01	F	1	Classrm.	M	38	reinspect fire extinguishers			C	
*	16-g -02	F	1	Classroo	O	0	discontinue use of piggybacked surge strips			C	
*	16-c -1	C	1	Classroo	M	375	Repair battery lighting			C	
*	16-a -2	C	1	Classroo	M	313	repair electric exit sign			C	
	10-b5-a	C	1	Glass	M	1000	install railings min 24" on windows V: Not required on doors			V	
*	16-e3-1	D	1	Lobby	M	188	post fire alarm tag			C	
*	15-a -5	B	1	Mech	O	0	remove storage from mechanical rooms	4	4/3/2014		
	S5.9.1	B	1	Men's Toilet	O	0	Install impervious material, all walls in toilet rooms to a height of 4' above the floor		4/3/2014		
	S58 C1	B	1	Men's Toilet	M	488	replace exit hardware, has lock on the inside, provide hardware that cannot be locked from the inside		4/3/2014		
*	16g 02	F	1	Office	O	0	discontinue use of piggybacked surge strips		4/3/2014		
*	16-c -1	C	1	Toilet	M	375	Repair battery lighting	3	4/3/2014		
	05-00-01	B	1	Toilet R	M	875	Replace glass mirror w/reflective metal mirror	4	5/3/2014		
	S5.9.1	B	1	Women's Toielt	O	0	Install impervious material, wood supports at HC stall sink and main room counter must be impervious		4/3/2014		
	S5.9.1	B	1	Women's Toilet	O	0	Install impervious material, all walls in toilet rooms to a height of 4' above the floor		4/3/2014		
	cs0101	A	1	Women's Toilet	O	0	Remove unsafe/broken Equipment, glass vase on counter		4/3/2014		



# **Comprehensive Safety Inspection State Requirements for Educational Facilities**

Inspection Date: 3/4/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014

Broward County School District - Cadre 10

Loc. No. 8033 Word of Living God Ministry - Pompano OCLC

149 NW 26 Ave.

954.917.9549

Pompano Beach, FL 33069

Pompano Beach Fire Rescue  
120 SW 3rd Street  
Pompano Beach, FL 33061  
Phone: (954)786-4695 Fax: (954)786-4328

Sandra Kanner Lic. No. 117455  
Municipal Firesafety Inspector

Victoria Burgess 159644  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety☒ Casualty☒ Sanitation

R69A.58		Location		Type						
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Est Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #

Total Non-Fire Safety Deficiencies.....6

Total Fire Safety Deficiencies (\*).....4

(Includes .....0 Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....10

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ]YES [ ]NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ]YES [ ]NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/3/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8036 YMCA OCLC  
408 NW 14 Terrace  
954.467.9544  
Ft. Lauderdale, FL 33311

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
02-c8-2	B	1	9599	M	1250	repair fence	2	4/2/2014		
* 10-L2-c	C	1	Assembl y	M	157	post capacity sign	3	4/2/2014		
05-00-01	B	1	Classroom	M	875	Replace glass mirror w/reflective metal mirror			C	
* 10a61	B	1	Classroom	M	438	Install Door Closure, classroom NW exit		4/2/2014		
* 16-g -02	F	1	Complab	O	0	discontinue use of piggybacked surge strips			C	
* 16-f1-02	B	1	Complab	O	0	install electric receptacle cover			C	
* 16-c -1	C	1	Corridor	M	375	Repair battery lighting	2	4/2/2014		
* 16-a -2	C	1	Corridor	M	313	repair electric exit sign			C	
* 16c 1	C	1	Exercise Room	M	375	Repair battery lighting, East wall		4/2/2014		
* 11-a8-01	F	1	Kitchen	M	38	reinspect fire extinguishers			C	
* 12-a -	F	1	Kitchen	O	0	remove combustible materials			R	
* 16-f1-13	B	1	Kitchen	M	125	repair electrical outlet			C	
* 08-c -2	B	1	Large Rm	O	0	remove lock/latch from exit door			C	
* 16-c -1	C	1	Largerm	M	375	Repair battery lighting			C	
* 16-a -2	C	1	Mainentr	M	313	repair electric exit sign			C	
* 16c 1	C	1	Men's Restroom	M	375	Repair battery lighting		4/2/2014		
* 16c 1	C	1	Multipur pose	M	375	Repair battery lighting, two(2)		4/2/2014		
* 08-b -2	E	1	Storeroo	M	3750	install rated fire doors	2	8/30/2014		



# Comprehensive Safety Inspection State Requirements for Educational Facilities

Inspection Date: 3/3/2014

Safety Department  
4200A N.W. 10th Avenue  
Oakland Park, FL 33309  
(754)321-4200

Fiscal Year: 2013 - 2014  
Broward County School District - Cadre 10  
Loc. No. 8036 YMCA OCLC  
408 NW 14 Terrace  
954.467.9544  
Ft. Lauderdale, FL 33311

Fort Lauderdale Fire Rescue  
528 NW 2nd Street  
Fort Lauderdale, FL 33301  
Phone: (954)828-5654 Fax: (954)828-5338

Bobby Glenn Lic. No. 53045  
Municipal Firesafety Inspector

Not Present  
Municipal Firesafety Inspector  
(\*Fire Violations Only)

☒ FireSafety ☒ Casualty ☒ Sanitation

R69A.58		Location		Type	Est	Deficiency Description and Corrective Action Required	# of Times Cited	Schedule for Correction Not Later Than	Current Year Status	Work Order #
Sub No. Para.	Pri	Bldg No.	Room No.	Def M-O-C	Cost					
* 12-a -	F	1	Storeroo	O	0	remove combustible materials			C	
* 09-b0-01	B	1	Storeroo	O	0	repair ceiling tiles	3	4/2/2014		
* 16c 1	C	1	Women Rr	M	375	Repair battery lighting		4/2/2014		
* 10a61	B	1	Gym	M	438	Install Door Closure		4/2/2014		

Total Non-Fire Safety Deficiencies.....1

Total Fire Safety Deficiencies (\*).....10

(Includes .....0.....Serious Life Safety Deficiencies\*\*)

Total Deficiencies Cited .....11

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY;

Ten Fire Exit Drills during the School Year [ ] YES [ ] NO (NFPA 101)

Signature of Facility Administrator attesting to fire exit drills and review of  
Initial Safety Inspection report acknowledging awareness of corrected  
and newly discovered deficiencies.

Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance  
with Section 1013.12(2)(c), F.S.

Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

All fire doors visually inspected for compliance with NFPA 7.2.1.15 [ ] YES [ ] NO

Scheduled Re-inspection Date no later than end of Fiscal School Year.