

*The School Board Of Broward County, Florida***The Building Department**

Lee Martin, Chief Building Official

DATE: January 21, 2005

EXHIBIT 1TO: Dr. Pamela Garwood, Principal
Lake Forest Elementary SchoolFROM: Lee Martin, Chief Building Official
The Building DepartmentSUBJECT: Lake Forest Elementary School
Location No. 0831, Project No.0831-9901
Buildings 4 and 5
Temporary Certificate of Occupancy

Pursuant to Chapter 106.1 of the Florida Building Code, 2001, a Temporary Certificate of Occupancy was issued this date for Building 4 and 5 at Lake Forest Elementary School. Effective January 21, 2005 this Temporary Certificate of Occupancy for Lake Forest Elementary School is being issued for a 90-day period contingent upon the completion of all listed items on the final inspection reports attached.

1. Provide smoke detector on underside of roof deck to protect the fire alarm control panel in the main electrical room.
2. Provide fire dampers for the A/C duct penetrations at storage room numbers 428 and 429. *Storage shall not be permitted until fire dampers are installed.

This Temporary Certificate of Occupancy will no longer be valid upon the expiration date of April 21, 2005, therefore, the subject building(s) shall not be occupied beyond that date without correction of the deficiencies listed attached.

If we can be of further assistance please call me at 754-321-4810.

LEM/RFM/tll

cc: Donnie Carter, Deputy Superintendent, Operations
Michael Garretson, Deputy Superintendent, Facilities and Construction Management
Mr. Samuel Gregg, South Area Superintendent
Derrick Ragland, Executive Director, Project Management
C. Rebecca Blackwood, Senior Supervisor, Building
Ronald Morgan, Senior Supervisor, Trades
Building Inspector
Project Management File
Building Department File - Lake Forest Elementary School

Rock Island Elementary Annex
2301 NW 26th Street, Ft. Lauderdale, FL 33311
Phone: 754-321-4800 Fax: 754-321-3389